



Log # TXX-6722
File # 10110
909.5
Ref. # 10CFR50.55(e)

September 14, 1987

William G. Council
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
DG FUEL OIL TANK VENT MISSILE PROTECTION
SDAR: CP-87-25 (INTERIM REPORT)

Gentlemen:

On June 29, 1987, we verbally notified your Mr. Shannon Phillips of a deficiency involving failure to provide missile protection for the diesel fuel oil storage tank vent piping. Additionally, portions of the vent piping were determined not to be seismically designed as required. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e).

Our evaluation for possible effects of these conditions is continuing. The next report on this issue will be submitted no later than November 20, 1987.

Very truly yours,

A handwritten signature in cursive script that reads 'W. G. Council'.

W. G. Council

BSD/gj

c - Mr. K. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8709180339 870914
PDR ADDCK 05000445
S PDR

IE27
1/0