PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-IV-87-47

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region IV staff on this date.

FACILITY: Louisiana Power Waterford 3 Taft, Louisiana	Licensee Emergency Classification: Notification of Unusual Event
DN: 50-382	Site Area Emergency General Emergency X Not Applicable

SUBJECT: PLANT SHUTDOWN GREATER THAN 48 HOURS

The licensee shut down the reactor plant because of a reactor coolant pump seal leak. The leakage was approximately 5 gpm on Coolant Pump 2B. The licensee plans to replace the leaking seal and conduct other maintenance items. The shutdown is estimated to last from 7 to 10 days.

The licensee does not plan to issue a press release.

The state of Louisiana has been informed.

Region IV received notification of this occurrence by telecon from the SRI at 8:00 a.m. (CDT) September 21, 1987. Region IV has informed NRR.

This information has been confirmed with a licensee representative.

CONTACT: J. P. Jaudon (FTS 728-8140)

DISTRIBUTION:

H. St. Chairman Zech Comm. Bernthal Comm. Roberts Comm. Carr ACRS SECV	MNBB EDO PA OGC MPA	E/W OIA AEOD VIB OE	Willste NMSS RES	MAIL: ADM:DMB (Original) DOT:(Trans only) FAX: TNPO NSAC GPA (Air
SECY CA PDR	Phillips NRR DCS	_		RRI NRC OC LICENSEE:
Pecienal Offices				(Reactor Licensee)

Regional Offices

D:DRSP

LJCallan:cs 9/21/87

RA **RDMa** 9/21/87

8709240532 870921 PDR 1&E PNO-IV-87-047 PDR Transmitted via 5520 9/21/87 @ 3:15 p.m.

IE34

......