

October 12, 1971

H. L. Price, Director of Regulation

D. C. COOK NUCLEAR PLANT

The ACRS has recommended that an independent analysis of the ice-condenser containment for the D. C. Cook Plant be implemented in connection with the O. L. review for this facility.

This analysis should be to investigate the adequacy of the ice-condenser performance, particularly the time-pressure history following the LOCA.

Original Signed by
R. F. Fraley

R. F. Fraley
Executive Secretary

cc: P. A. Morris, DRL

bcc: ACRS Members

8707090517 870610
PDR FOIA
THOMAS87-40 PDR