

CALCULATION/PROBLEM COVER SHEET



Calculation/Problem No: 111-27
 Title: Thermal Load Evaluation
 Client: Tigeo Project: CPSE 3
 Job No: 0210-040

Design Input/References:

Notes within

Assumptions:

Wind within

Method:

Load within

Remarks:

REV. NO.	REVISION	APPROVED	DATE
0	Original Issue	W.L. Gandy	5-7-82
1	Revised to include Expanded Numerical Evaluation	G.C. Gandy	2-25-87
2	Extended to include Stress & Tension	R.Kagounder	5-5-87
	B709290329 B70923 PDR ADDCK 05000445 A PDR		

TABLE OF CONTENTS

Page

1.0 INTRODUCTION	3
2.0 PRECEDENT	5
3.0 METHODOLOGY	5
3.1 ~ SYSTEM SLACK	
3.2 ~ EXPECTED THERMAL GROWTH	
4.0 RESULTS	11
4.1 ~ SYSTEM SLACK	
4.2 ~ EXPECTED GROWTH	
4.3 ~ "WORST CASE" SUPPORT EVALUATION FOR COMBINED SHEAR AND TENSION EFFECTS	
4.4 ~ "WORST CASE" SUPPORT EVALUATION FOR SHEAR EFFECTS	
5.0 CONCLUSIONS	30
6.0 REFERENCES	34
7.0 FIGURES	37

2

Thermal Load Evaluation				
REV	BY	DATE	CHECKED	DATE
2	JAH	5/5/87	DWS	5/5/87
1	JAH	2/5/87	RNL	7/6/87
IMPELL		JOB NO 0210-041		PAGE
CORPORATION		CALC NO		2 OF 47
M - 27				

1.0 INTRODUCTION

The question of thermal loading on cable tray supports has been raised by CPGNA in Issue No. 19 of the Independent Assessment Program; i.e., "For supports installed in the Reactor Building, the loads associated with a LOCA may be applicable, including pipe whip, jet impingement and thermal loads." This statement is based upon the load combinations specified in Section 3.8.4.3 of the CPSES FSAR [1] for Other Seismic Category I Structures." Several of these load combinations include the thermal loads associated with postulated thermal accident conditions.

The purpose of this calculation is to evaluate thermal load effects on cable tray supports and their anchorages and determine whether or not such loads need to be included in the design verification effort of cable tray systems at CPSES.

According to load combinations specified in the CPSES FSAR [1], which are consistent with those given in the NEC Standard Electrical Plan (SEP), thermal loading must be accounted when present and when the thermal loading could affect structural performance. Both the SEP and FSAR criteria specifically exclude thermal loads in cases where these loads are secondary and self-limiting in nature and where the materials are ductile. Given these conditions, thermal loads cannot lead to structural or system failure and thus do not need to be considered.

					Thermal Load Evaluation		
REV	BY	DATE	CHECKED	DATE	IMPELLA CORPORATION		PAGE
1	++	2/5/87	ZRE	2/6/87	JOB NO CALC NO	0210-041 M-27	OF 47

The exclusion of thermal loading in the analysis + the cable trays and support members is justified on the high level of ductility inherent in the mild carbon steel material. Furthermore, it will be shown that for the steel-to-concrete anchorages (the least ductile part of the cable tray system) the thermal displacements are self limited to values which preclude structural failure. The FSAE and SEP criteria for exclusion of thermal loading are therefore satisfied.

					Thermal Load Evaluation		
REV	BY	DATE	CHECKED	DATE	IMPELL CORPORATION		PAGE
1	HRA	2-5-87	RML	7/6/87	JOB NO 0210-041 CALC NO M-27		1 OF 47

2.0 PRECEDENT

Impell has performed a review of the FSARs and related design documents of other nuclear power plants - including Millstone 2, Braewood, Byron, Catawba, and Diablo Canyon. None of these plants have considered thermal loads in the evaluation of cable tray systems. All of these plants are of the same Westinghouse NPP design as CPSES and share the same licensing position of not considering thermal loads in the evaluation of cable tray systems.

3.0 METHODOLOGY

The cable tray systems at CPSES Unit 1 are comprised of light gage steel trays and structural steel supports. Static tests of cable trays [2] show that the cable trays are indeed ductile by displaying a large nonlinear region on load-deflection curves before reaching the ultimate load. The cable tray supports are composed of structural tee sections. The inherent ductility of the mild carbon steel material ensures that the SRP/FSAR criteria are met (secondary, self-limiting loads and ductile materials); for the trays and supports and thermal loads need not be evaluated. It must be shown, however, that this conclusion can be applied to the case of steel-to-concrete anchorage details. Since the ductility of these connections could be governed by the behavior of concrete instead of steel, they might be susceptible to thermal loading even though the trays and supports are not. The following steps will be used to evaluate the susceptibility of steel-to-concrete anchorages to thermal loading.

					Thermal Load Evaluation		
REV	BY	DATE	CHECKED	DATE	JOB NO	0210-041	PAGE
					CALC NO	M-27	5 OF 47
1	HRT	2/5/87	RHK	2/6/87	IMPELL		

3.1 System Slack

|2>

A worst case condition will be considered, this being a straight run of cable tray with the maximum allowable spacing between longitudinal supports of 40 ft. Longitudinal supports are braced in the longitudinal direction therefore restraining the thermal growth of the cable tray. By using the maximum allowable spacing of 40 ft. [10] between longitudinal supports the thermal expansion will be maximized.

|2>

This 40 ft. system would contain at least three tray splices, two tier-to-tray connections and two support-to-structure connections.

Typically, the average bolt hole for anchorages is $1/8"$ [9] oversized and other bolt holes are $1/16"$ oversized [4]. Assuming these bolt hole oversizes, the expected slack in the system will be shown to be SIGNIFICANT. (SEE |2> Section 4.1).

Thermal Load Evaluation				
REV	BY	DATE	CHECKED	DATE
2	DWJ	4/30/87	JKA	4/30/87
1	JAA	2/5/87	JIK	2/6/87

IMPELL  CORPORATION

JOB NO 0210-041
CALC NO A1-27

PAGE 6 OF 47

3.2 Expected Thermal Growth



Thermal growth of three conditions needs to be considered: a) thermal growth during normal operation and shutdown conditions, b) maximum thermal growth during a postulated break inside containment in conjunction with a seismic event and c) maximum thermal growth that could occur at any time.

a) Operating Thermal Loads

During normal operation and shutdown conditions the maximum temperature change is relatively small (less than 50° Fahrenheit, [10]) and since the temperature change occurs gradually, the building structures will heat up at the same rate as the cable tray systems. Therefore, an effective coefficient of expansion equal to the difference in the coefficients of expansion for steel [5] and concrete [11] (the difference is approximately 1.0×10^{-6}) can be used.

Thermal Load Evaluation				
REV	BY	DATE	CHECKED	DATE
2	AT	5/5/87	DWS	5/5/87
	HAD	2/5/87	RML	3/6/87
IMPELL		CORPORATION		JOB NO 0210-041 CALC NO M-27
				PAGE 7 OF 47

b) Accident Thermal and Seismic

The probability that a Loss of Coolant Accident (LOCA) occurs in conjunction with a seismic event is not a credible event, unless the seismic event initiates the LOCA. Given such circumstances, the maximum temperature rise during an earthquake must be determined. Once determined, the maximum temperature change would be used to determine the thermal growth and thus the possible subsequent thermal loading. A worst case situation can be postulated based upon the following conservative assumptions:

1. The LOCA is initiated simultaneously with the onset of the Safe Shutdown Earthquake (SSE) so that the maximum time possible is allowed for temperature changes to occur.
2. The maximum seismic loading occurs at the end of the SSE (i.e. at $t = 10$ seconds) concurrent with the maximum thermal effect.
3. The LOCA which occurs is the Double-Ended Pump Suction Guillotine (DEPSG); i.e. the one producing the most rapid changes in temperature [1]. (Figure 1)
4. The cable trays are exposed to the LOCA environment over 100% of their surface area (inside and out).

					Thermal Load Evaluation		
REV	BY	DATE	CHECKED	DATE	JOB NO	0210-041	PAGE
					CALC NO	M-27	B OF 47
1	HRT	2/5/87	AKL	7/16/87	IMPELL	4	CORPORATION

Given these worst-case conditions, temperature changes in the coke trays can be evaluated through the following equation [8]:

$$T_t = (T_0 - T_a) e^{\frac{-2ht}{PCL}} + T_a \quad (1)$$

where: T_t = tray temperature at time, t ($^{\circ}$ F)

T_0 = initial tray temperature ($^{\circ}$ F)

T_a = ambient temperature at time, t ($^{\circ}$ F)

h = heat transfer coefficient at time, t (BTU/HR ft.² F)

P = tray material density (LB/FT³)

C = tray specific heat (BTU/LB. $^{\circ}$ F)

L = tray thickness (FT)

Equation 1 has been evaluated numerically at one-second intervals with the results given in Section 4.0 of this calculation. Knowing the tray temperature at ten seconds after the earthquake is initiated, the expected thermal growth for this condition can be calculated (see Section 4.2 or this calc.).

Thermal Load Evaluation				
REV	BY	DATE	CHECKED	DATE
2	DWS	4/30/87	HAT	4/30/87
1	HAT	2/15/87	PKL	2/16/87



JOB NO 0210-041

CALC NO

n1-27

PAGE 9 OF 47

C) ACCIDENT THERMAL LOADS

FOR THE CONDITIONS WHERE MAXIMUM THERMAL GROWTH COULD OCCUR AT ANY TIME DURING THE ACCIDENT, THE MOST CRITICAL CASE[1] IS THE 0.908 FT²-SPLIT STEAM LINE BREAK (SLB) AT 70% POWER. THE SLB TEMPERATURE PROFILE (FIGURE 3) SHOWS THE MAXIMUM TEMPERATURE CHANGE INSIDE CONTAINMENT. SINCE THERE IS NO HEAT TRANSFER DATA FOR THE SLB, IT WILL BE ASSUMED CONSERVATIVELY THAT THE CABLE TRAY TEMPERATURES CHANGE AT THE SAME RATE AS THE VAPOR INSIDE CONTAINMENT. ALSO, THE TEMPERATURE CHANGE OF THE INTERNAL CONCRETE STRUCTURES (FIGURE 4) WILL BE TAKEN INTO ACCOUNT. THE RESULTS APPEAR IN SECTION 4.0 OF THIS CALCULATION.

THERMAL LOAD EVALUATION				
REV	BY	DATE	CHECKED	DATE
2	DWS	4/30/87	HFA	4/30/87
IMPELL			JOB NO 0210-041 CALC NO M-27	PAGE 10 OF 47

4.0 RESULTS

4.1 System Slack

The available slack in the system can be estimated as follows:

two support-to-structure connections : $2 \times 1/8'' = 0.25''$

three tray splices : $3 \times 1/16'' = 0.1875''$

two tray-to-tier connections : $2 \times 1/16'' = 0.125''$

total slack = $0.5625''$

Half of this total will be used assuming that the bolts are centered in the bolt holes.

A reasonable estimate of the slack available for free growth ...

4.2 Expected Growth

a) Operating Thermal Loads

During normal operation the temperature change is relatively small (less than 50°F) and the coefficient of thermal expansion can be taken as the difference between concrete and steel ($1.0 \times 10^{-6} \text{ in/in}^{\circ}\text{F}$). With these conditions, the thermal expansion can be shown to be small even for the worst case of a 40 ft. straight tray run:

$$\begin{aligned}\Delta &= \alpha \Delta T L \\ &= (1.0 \times 10^{-6} \text{ in/in}^{\circ}\text{F})(50^{\circ}\text{F})(40 \text{ ft})(12 \text{ in/ft}) \\ &= 0.02 \text{ in}\end{aligned}$$

This expansion is insignificant, especially in comparison of the total slack available in the system.

Thermal Load Evaluation							
REV	BY	DATE	CHECKED	DATE	JOB NO	PAGE	
1	HAT	2/15/87	Rru	2/16/87	0210-041	11	OF
					IMPELL	47	

b) Accident Thermal and Seismic

The tray temperature is determined for the critical time interval of 0 to 10 seconds. The DEPSG controls with the ambient temperature profile shown in Figure 1. The tray thickness, L, will be for the lightest trays (16 gage material) used at CPSES, those that are the fastest to change temperature. The following data is used with Equation 1 to find the tray temperature at one second intervals:

$$T_t = (T_0 - T_a) e^{\frac{-2ht}{\rho CL}} + T_a$$

$T_0 = 120^\circ F$ (initial tray/ambient temperature)

$h = 5$ at $t=0$ and 75 at $t=10$ with linear variation (BTU/HR·FT²·°F) [8]

$\rho = 490$ LB/FT³ [4]

$C = 0.11$ BTU/LB·°F [5]

$L = 0.005292$ FT (16g Galv. Tray) [12]

					Thermal Load Evaluation		
					JOB NO	PAGE	
REV	BY	DATE	CHECKED	DATE	CALC NO	OF	
1	TRH	2/5/87	/	1/1/87	M-27	47	



Equation 1 evaluated at 1-sec intervals
as follows:

t (sec)	T_o (°F)	T_a (REF. Fig. 1) (BTU/LB.°F) (°F)	h	T_e (°F)
1	120.0	153	12	120.7
2	120.7	179	19	122.8
3	122.8	194	26	126.3
4	126.3	204	33	131.1
5	131.1	212	40	137.2
6	137.2	219	47	144.4
7	144.4	225	54	152.4
8	152.4	230	61	161.1
9	161.1	234	68	170.1
10	170.1	238	75	179.3

Thermal Load Evaluation				
REV	BY	DATE	CHECKED	DATE
1	TRN	2/5/87	2TRN	1/6/87



JOB NO 0210-041
CALC NO
M - 27

PAGE 13 OF 47

The maximum 10-second change in tray temp is

$$179 - 120 = 59^{\circ}\text{F}$$

The thermal growth would be

$$\Delta = \alpha \Delta T L$$

where Δ = thermal growth

α = coefficient of thermal expansion

ΔT = change in temperature

L = length of tray

$$\Delta = [6.8 \times 10^{-5} \text{ in/in.F}] (59^{\circ}\text{F}) (40\text{F+}) (2 \text{ in/ft}) \quad [5]$$

$$\Delta = 0.19''$$

Clearly the slack in the system, 0.28", is more than enough to accommodate the entire thermal growth 0.19". without generating any thermal loads in the system. The vibrations caused by the seismic excitation will ensure that slippage does occur and that the system slack will be mobilized as necessary. IN ADDITION, IT WILL BE SHOWN IN THE NEXT SECTION THAT THE ANCHORAGES QUALIFY DURING THE WORST THERMAL LOAD WHICH MAY OCCUR AT ANY TIME DURING AN ACCIDENT, EVEN WITHOUT CONSIDERING THE SLACK AVAILABLE IN THE SYSTEM.

GIVEN THESE WORST-CASE CONDITIONS, ACCIDENT THERMAL LOADING CAN NOT DEVELOP CONCURRENTLY WITH SEISMIC LOADING. THEREFORE, THE LOAD COMBINATION OF SSE PLUS LOCA NEED NOT BE CONSIDERED FOR THE STEEL TO CONCRETE ANCHORAGES OR ANY OTHER PART OF THE CABLE TRAY SYSTEMS.

Thermal Load Evaluation

REV	BY	DATE	CHECKED	DATE	JOB NO	PAGE
2	DWS	4/30/87	TTF	4/30/87	0210-041	47
1	+FA	2/15/87	K+K	2/16/87	CALC NO	OF 47



M-27

c) Accident - Thermal Loads

The maximum temperature change occurs for a 0.908 FT² - Split Steam Line Break (Figure 3). From Figure 3 it can be seen that the maximum temperature change is 212°F occurring approx. 90 seconds into the SLB. At the same time, the temperature of the internal concrete structures (Figure 4) has increased approximately 39°F. It will be assumed conservatively that the cable tray temperatures change at the same rate as the vapor inside containment since no heat transfer data is available for the SLB. The relative temperature change would be $212^{\circ}\text{F} - 39^{\circ}\text{F} = 173^{\circ}$. Given this data the thermal growth would be:

$$\Delta = (6.8 \times 10^{-6} \text{ in/in}^{\circ}\text{F}) (173^{\circ}\text{F}) (40 \text{ ft}) / (2^{\circ}\text{F/in})$$

$$\Delta = 0.56 \text{ "}$$

THIS CONDITION REPRESENTS THE WORST CASE THERMAL LOAD SINCE THE CABLE TRAY HAS AN UNLIMITED AMOUNT OF TIME TO HEAT UP DURING THE ACCIDENT CONDITION. IT HAS BEEN SHOWN IN SECTION 4.1 THAT AT LEAST 0.28 INCHES OF SLACK EXISTS IN A 40 FOOT STRAIGHT TRAY RUN. AS AN ADDITIONAL CONSERVATISM, HOWEVER, THIS AVAILABLE SLACK WILL NOT BE CONSIDERED FOR THE SLB ACCIDENT.

TO DEMONSTRATE THAT THERMAL LOADS NEED NOT BE EVALUATED, IT WILL BE SHOWN THAT THE STEEL TO CONCRETE ANCHORAGE IS CAPABLE OF WITHSTANDING THE TENSION AND SHEAR FORCES INDUCED BY A 0.56 INCH DISPLACEMENT OF THE CABLE TRAY.

Thermal Load Evaluation

REV	BY	DATE	CHECKED	DATE	JOB NO	PAGE
2	DWS	4/30/87	LAA	4/30/87	2210-041	
1	HAN	2/5/87	PTK	7/6/87	CALC NO	
					M-27	



APPLYING THIS DISPLACEMENT HAS TWO ADDITIONAL IMPLICATIONS. FIRST, AS MENTIONED EARLIER, IT NEGLECTS THE EFFECTS OF GAPS WHOSE EXISTENCE HAS BEEN DOCUMENTED IN REFERENCE 9. SECOND, THIS APPROACH ASSUMES THAT NO RESTRAINT TO THERMAL GROWTH IS SUPPLIED BY THE SUPPORT; THE TRAY IS ASSUMED TO DISPLACE THE FULL 0.56 INCHES IN SPITE OF THE FORCE APPLIED TO IT BY THE LONGITUDINAL SUPPORT. THIS IS CONSERVATIVE BECAUSE IN ACTUALITY THE SUPPORT WILL RESTRAIN THE TRAY PRIOR TO THE FULL 0.56 INCH DISPLACEMENT.

TO IMPLEMENT THE PLAN DESCRIBED ABOVE, THE THERMAL DISPLACEMENT WAS APPLIED TO THE VERY SHORT BRADED CANTILEVER SHOWN IN FIGURE 5. THIS CONFIGURATION WAS CHOSEN BECAUSE A BRADED CANTILEVER IS THE STIFFEST TYPE OF LONGITUDINAL SUPPORT COMMONLY USED AT CPSES. FURTHERMORE, A VERY SHORT LENGTH (3'-0) AND STIFF SECTIONS (A 'T' SECTION MADE FROM TWO CG48.2s FOR THE CANTILEVER, AND A 4 \times 3 \times $\frac{3}{8}$ FOR THE BRACE) WERE ASSUMED. TWO BOLT ANCHORAGES WITH A TYPICAL ORIENTATION, AS SHOWN IN FIGURE 5, ARE ASSUMED. THIS SUPPORT CONFIGURATION WAS CHOSEN TO PROVIDE A "WORST-CASE" EVALUATION OF COMBINED SHEAR AND TENSION LOADING ON THE BOLTS.

THE SUPPORT WAS MODELLED IN DETAIL IN ACCORDANCE WITH THE MODELLING PROCEDURE SPECIFIED IN REFERENCE 6, INCLUDING THE MAPPING OF THE ECCENTRICITY BETWEEN THE TIER CG AND TRAY &.

THERMAL LOAD EVALUATION				
REV	BY	DATE	CHECKED	DATE
2 DWS	H/30/87 HAI	4/30/87		
IMPELL			JOB NO 0210-041 CALC NO M-27	PAGE 16 OF 47

TO DETERMINE THE CRITICAL TRAY ALONG THE CANTILEVER, THE SUPPORT WAS ANALYZED USING THE IMPELL LINEAR ELASTIC MODEL FOR THE ANCHOR [27]. ANCHORAGE REACTIONS WERE COMPUTED FOR A GIVEN DISPLACEMENT AT THE POTENTIAL TRAY LOCATION - midway along the cantilever length and near the cantilever end bracing location. THE SUPERPIPE ANALYSIS WERE DONE WITH THE ELEMENTS [25] AND [26]. THE RESULTS CLEARLY INDICATED THAT THE MAXIMUM ANCHORAGE REACTIONS OCCURRED NEAR THE BRACE ATTACHMENT POINT AND THAT THE TRAY WAS LOCATED NEAR THE CANTILEVER END. A LOCATION SLIGHTLY INSIDE THE END BRACING ATTACHMENT POINT WAS CHOSEN TO LOCATE THE TRAY #3 AS SHOWN IN FIGURE 4.

SINCE THE DISPLACEMENT IS APPLIED IN THE LONGITUDINAL DIRECTION OF THE TRAY, THE CLIP STIFFNESS USED IN THIS DIRECTION WAS TAKEN FROM STATIC CLAMP TEST RESULTS (REF [24]) OBTAINED FOR THE STIFFEST LONGITUDINAL CLIP TYPICALLY FOUND AT CPSES. THIS STIFFNESS CAN BE OBTAINED FROM THE PLOT SHOWN IN FIGURE 6. A DIAGRAM OF THE CLIP IS SHOWN IN FIGURE 7. THE CLIP STIFFNESSES IN THE REMAINING DIRECTIONS ARE INPUT AS RIGID. ALL SUPPORT AND CLIP MODELING WAS DONE IN ACCORDANCE WITH THE PROCEDURES SPECIFIED IN REFERENCE 6. NOTE THAT FIGURES 6 & 7 ARE FROM REFERENCE 24.

THIS SUPPORT MODEL WAS THEN ANALYZED FOR THE FULL 0.56" LONGITUDINAL DISPLACEMENT AT THE TRAY LOCATION. USING SUPERPIPE, SECTION 4.3 ASSESSES THE THERMAL GROWTH EFFECTS IF 1" HILTI KWIK BOLTS ARE ASSUMED FOR THE SUPPORT ANCHORAGE.

A SIMILAR ASSESSMENT IS PERFORMED FOR 1" RICHMOND INSERTS. THESE BOLTS REPRESENT THE SMALLEST SIZES USED FOR CPSES LONGITUDINAL CABLE TRAY SUPPORTS.

THERMAL LOAD EVALUATION				
REV	BY	DATE	CHECKED	DATE
E	TAN	5/15/87	DWS	5/5/87
		JOB NO 0210-041 CALC NO		PAGE 17 OF 47
		M-27		

4.3 "WORST CASE" SUPPORT EVALUATION FOR COMBINED SHEAR AND TENSION EFFECTS.

a) 1" Ø HILTI KWIK BOLTS

IN PERFORMING THE SUPERPIPE ANALYSIS, BASE ANGLE ANCHORAGE STIFFNESS WAS ASSUMED TO BE EQUAL TO THE ACTUAL STIFFNESS VALUE AS THE CASE MIGHT NOT BE A COUPLE WITH THE PIPING. DUE TO THE DIRECTION OF TRAY GROWTH ASSUMED TO OCCUR IN PLATE 5, THIS PLACES THE BRACE READING ANCHOR BOLTS IN MAXIMIZING TENSION.

THE FOLLOWING STEIFNESSES WERE USED:

SANTIAGEO ANCHORAGE

BRACE ANCHORAGE

$K_x = \text{RIGID}$

$K_x = 40 \times 10^6$

$K_y = 2800 \text{ KIP-IN/RAD}$

$K_y = 2800 \text{ KIP-IN/RAD}$

THE REMAINING ANCHORAGE DEGREES OF FREEDOM ARE CONSIDERABLY LARGER AND THEREFORE CONSERVATIVELY ASSUMED TO BE RIGID. THE ANCHORAGE CONFIGURATION ASSUMED AND ANCHORAGE COORDINATE AXES ARE ILLUSTRATED IN FIGURE B. THE SAME ANCHORAGE WITH MINIMUM SPACING, IS USED FOR THE TWO PLATES.

THE HIGHEST LOADS FROM THE SUPERPIPE ANALYSIS [21], WHICH WERE FOUND AT THE BRACE ANCHORAGE, WERE THEN USED TO QUALIFY THE ANCHOR BOLTS USING THE CDC NON-LINEAR PROGRAM BASEPLATE II [28]. AS SHOWN IN FIGURE B, A TWO BOLT BASE ANGLE WAS MODELED SINCE ONE BOLT BASE ANGLES ARE NOT USED FOR LONGITUDINAL SUPPORTS. THE MANUFACTURER'S SPECIFIED MINIMUM CENTER-TO-CENTER SPACING WAS ASSUMED AND THE LOADS WERE ASSUMED TO ACT HALFWAY UP THE FREE LEG, WITH THE ATTACHMENT LOCATION DIRECTLY IN LINE WITH ONE OF THE BOLTS. BOTH OF THESE ASSUMPTIONS MAXIMIZED THE TENSION GENERATED IN THE CRITICAL BOLT.

THERMAL LOAD EVALUATION				
REV	BY	DATE	CHECKED	DATE
2	JAT	5/5/87	DWS	5/5/87



JOB NO. 0210-041	PAGE 18 OF 47
CALC NO.	
M-27	

TO ANALYZE THE FIGURE 8 MODEL IN BASE RII, A NON-LINEAR TENSION STIFFNESS WAS INPUT FOR THE 1" HILTIS BOLTS. THE LOAD DISPLACEMENT CURVE FOR TENSION WAS TAKEN FROM MANUFACTURER'S TEST DATA (REFERENCE [1]) AND IS SHOWN IN FIGURE 9. A BI-LINEAR TENSION LOAD-DISPLACEMENT CURVE WAS GENERATED USING THE AVERAGE RECORDED SLIP AND ULTIMATE DISPLACEMENTS FROM THE FIVE TEST SAMPLES SINCE NO LOAD-DISPLACEMENT CURVES WERE PRESENTED IN REFERENCE [14]. THE CURVE CORRESPONDS TO AN EMBEDMENT DEPTH OF A 1/2" EMBEDMENT DEPTHS AT CPSES. FOR 1" HILTIS ARE TYPICALLY MUCH GREATER. A CONSTANT BOLT SHEAR STIFFNESS OF 111 KIP/IN, TAKEN FROM REFERENCE [13] WAS USED.

THE FOLLOWING REACTIONS, TAKEN FROM THE REFERENCE [2] SUPERPIPE ANALYSIS, WERE APPLIED TO THE BASE RII ATTACHMENT LOCATION:

$$\begin{array}{ll} F_x = 5690 \text{ lb} & M_x = 8940 \text{ lb-in} \\ F_y = 1020 \text{ lb} & M_y = 11820 \text{ lb-in} \\ F_z = 5360 \text{ lb} & M_z = 8940 \text{ lb-in} \end{array}$$

THE ABOVE LOADS WERE APPLIED SIMULTANEOUSLY IN A SINGLE LOAD CASE. DIFFERENT LOAD COMBINATIONS WERE CREATED BY REVERSING LOAD DIRECTIONS IN ORDER TO MAXIMIZE THE LOADING ON THE CRITICAL BOLT. THE RESULTING MAXIMUM LOADS WERE [17]:

$$\begin{aligned} T_{\max} &= 8411 \text{ lb} \\ S_{\max x} &= 2849 \text{ lb} \\ S_{\max y} &= 2601 \text{ lb} \\ S_{\max} &= \left[(S_{\max x})^2 + (S_{\max y})^2 \right]^{1/2} = 3858 \text{ lb.} \end{aligned}$$

THE BOLTS WERE THEN QUALIFIED USING THE FOLLOWING INTERACTION EQUATION FROM REFERENCE [18] AND

					THERMAL LOAD EVALUATION		
					JOB NO	1210-C-1	PAGE
REV	BY	DATE	CHECKED	DATE	CALC NO		19
-	DWS	5/5/87			M-27		OF 47



AVERAGE ULTIMATE LOADS FROM REFERENCE [14]
BASED ON 4 1/2" EMBEDMENT.

$$\frac{T_{MAX}}{T_{ULT}} + \frac{S_{MAX}}{S_{ULT}} \leq 1.0 \quad T_{ULT} = 16019 \text{ lb } [14] \\ S_{ULT} = 26877 \text{ in-lb } [14]$$

$$\frac{8411}{16019} + \frac{3858}{26877} = 0.67 \leq 1.0$$

AS AN ADDED CHECK, THE SHEAR AND TENSION DISPLACEMENTS OF THE 1" ϕ HILTIS WILL BE COMPARED TO THE AVERAGED SHEAR AND TENSION ULTIMATE DISPLACEMENTS FROM REFERENCE [14], ΔS_{ULT} AND ΔT_{ULT} , RESPECTIVELY. THE TENSION DISPLACEMENT FROM ALL LOAD COMBINATIONS FROM BASE R2 II [17], ΔT , IS THE MAXIMUM TENSION DISPLACEMENT FROM ALL LOAD COMBINATIONS. THE SHEAR DISPLACEMENT FROM BASE R2 II [17], ΔS , IS THE SRSS COMBINATION OF THE MAXIMUM ANCHORAGE ΔX AND ΔY FOR BOTH BOLTS AND ALL LOAD COMBINATIONS.

$$\Delta S = 0.035 \text{ in} \quad \Delta S_{ULT} = 0.320 \text{ in}$$

$$\frac{\Delta S}{\Delta S_{ULT}} = 0.109$$

$$\Delta T = 0.220 \text{ in} \quad \Delta T_{ULT} = 0.543 \text{ in}$$

$$\frac{\Delta T}{\Delta T_{ULT}} = 0.405$$

THE EQUILIBRIUM TENSION DISPLACEMENT IS INDICATED ON THE LOAD DISPLACEMENT CURVE IN FIGURE 9. FOR MORE TYPICAL CPSES EMBEDMENT DEPTHS FOR 1" HILTIS (ie 8 TO 10 INCHES), THE EQUILIBRIUM TENSION DISPLACEMENT WOULD BE A FAR SMALLER PERCENTAGE OF THE ULTIMATE.

THERMAL LOAD EVALUATION				
REV	BY	DATE	CHECKED	DATE
2	AT	5/5/87	DWS	5/5/87
			JOB NO	0310-02
			CALC NO	11-27
			PAGE	20 OF 47

THE LINEAR STIFFNESS ASSUMED IN SHEAR IS APPROPRIATE SINCE THE APPLIED SHEAR LOAD REMAINS FAR BELOW THE ULTIMATE.

THE K_z AND K_{xx} ANCHORAGE STIFFNESSES ORIGINALLY ASSUMED IN THE SUPERPIPE ANALYSIS ARE VERIFIED IN ADDITIONAL LOAD CASES DOCUMENTED IN REFERENCE [17]. THE SAME PROCEDURE USED IN REFERENCE [16] TO DEVELOP ANCHORAGE STIFFNESSES WAS USED TO VERIFY THE ASSUMED STIFFNESS. THE F_z AND M_x LOAD COMPONENTS ARE APPLIED TO THE BASEPLATE II BASE ANGLE ATTACHMENT LOCATION AND APPLIED AS SEPARATE LOAD CASES (SEE FIGURE 8 FOR LOCAL COORDINATE ORIENTATION).

THE ROTATION STIFFNESS CAN BE DETERMINED BY REVIEWING THE DISPLACEMENTS OF THE NODES ADJACENT TO THE LOADING:

FOR LOAD CASE #6 [17], LOADING OF $M_x = 8.94$ KIP-IN

$$\Delta z_{11} = -.0009329'' \quad , \quad \Delta = .004803'' \\ \Delta z_{12} = .003870''$$

$$\angle = \sin^{-1} \frac{.004803''}{1.5''} = .003202 \text{ RAD}$$

$$K_{xx} = \frac{8.94 \text{ kip-in}}{.003202 \text{ RAD}} = 2792 \text{ KIP-IN/RAD}$$

THE TRANSLATION STIFFNESS FOR FULL-OUT LOADING CAN BE DETERMINED DIRECTLY BY REVIEWING THE DISPLACEMENT AT THE LOAD POINT:

FOR LOAD CASE #5 [17], LOADING OF $F_z = 5.36$ KIP

$$\Delta z_{11} = .2154''$$

$$K_z = \frac{5.36 \text{ KIP}}{.2154 \text{ IN}} = 25 \text{ KIP/IN}$$

					FINAL LOAD EVALUATION		
					JOB NO	CALC NO	PAGE
REV	BY	DATE	CHECKED	DATE	IMPELL CORPORATION		21 OF 47
-	-	DWS	5/5/87				

FOR THE BRACING MEMBER ATTACHMENT REACTIONS,
THE VERIFIED ANCHORAGE STIFFNESS ARE COMPARABLE
TO THE ASSUMED ANCHORAGE STIFFNESS BUT WITH
THE PULL-OUT STIFFNESS, K_z , BEING SOMEWHAT SOFTER
THAN THAT WAS ASSUMED.

	VERIFIED	ASSUMED
K_z	25 KIP/IN	40 KIP/IN
K_{xy}	2792 KIP-IN/RAD	2800 -F-IN/RAD

FOR THE CANTILEVER ATTACHMENT REACTIONS THE
VERIFIED ANCHORAGE STIFFNESS ARE COMPARABLE TO THOSE
ASSUMED.

	VERIFIED	ASSUMED
K_{xy}	2792 KIP-IN/RAD	-300 KIP-IN/RAD

FOR THE CANTILEVER ATTACHMENT, THE F_z COMPONENT
CAUSES COMPRESSION IN THE BOLTS AND THEREFORE
THE MODELLING OF A RIGID STIFFNESS IN THIS
DIRECTION IS APPROPRIATE.

REV	BY	DATE	CHECKED	DATE	IMPELL CORPORATION	JOB NO 0210-021	PAGE 22 OF 47
2	+PA	5/5/87	DWS	5/6/87		CALC NO M-27	

b) 1" RICHMOND INSERT

A SIMILAR SUPERPIPE ANALYSIS WAS PERFORMED WITH RICHMOND INSERTS ASSUMED AT THE ANCHORAGES. THE K_Z AND K_{XX} STIFFNESS VALUES USED FOR THIS ANALYSIS WERE CORRESPONDINGLY INCREASED DUE TO THE HIGHER STIFFNESS OF THIS BOLT TYPE.

SANTILEVER ANCHORAGE

$$K_Z = \text{RIGID}$$

$$K_{XX} = 8500 \text{ KIP-IN/RAD}$$

BRACE ANCHORAGE

$$K_Z = 300 \text{ KIP/IN.}$$

$$K_{XX} = 8500 \text{ KIP-IN/RAD}$$

THESE STIFFNESS VALUES WILL AGAIN BE CONFIRMED PERFORMING A BASELINE II ANALYSIS USING THE FIGURE B CONFIGURATION AND BOLT STIFFNESS VALUES CORRESPONDING TO RICHMOND INSERTS.

THE CRITICAL REACTIONS FROM THE SUPERPIPE ANALYSIS (DOCUMENTED IN REFERENCE [22]) WERE AGAIN FOUND AT THE BRACE MEMBER ATTACHMENT ANCHORAGE.

					THERMAL LOAD EVALUATION			
REV	BY	DATE	CHECKED	DATE	IMPELL	JOB NO C210-C41 CALC NO .A1-27	PAGE 23 OF 47	
2	HAT	5/5/87	DWS	5/5/87				

TO ANALYZE THE FIGURE 3 MODEL IN BASE^R II, A NON-LINEAR TENSION STIFFNESS WAS INPUT FOR THE 1" RICHARDSON BOLTS. THE LOAD DISPLACEMENT CURVE FOR TENSION WAS TAKEN FROM REFERENCE [19] AND IS SHOWN IN FIGURE 10. THE CURVE CHOSEN FROM REFERENCE [182] WAS ONE THAT SHOWED A TYPICAL REPRESENTATION OF THE BEHAVIOR OF THE 1" RICHARDSON NUTLESS NUTS IN TENSION. A CONSTANT BOLT SHEAR STIFFNESS OF 485 KIP/IN TAKEN FROM REFERENCE [32] WAS USED.

THE FOLLOWING REACTIONS TAKEN FROM THE REFERENCE [22] SURFACE ANALYSIS, WERE APPLIED TO THE BASE^R II ATTACHMENT LOCATION:

$$\begin{array}{ll} F_x = 7120 \text{ lb} & M_x = 14300 \text{ in-in} \\ F_y = 1350 \text{ lb} & M_1 = 2630 \text{ in-in} \\ F_z = 7050 \text{ lb} & M_2 = 14300 \text{ in-in} \end{array}$$

AS BEFORE, DIFFERENT COMBINATIONS OF THE ABOVE LOADS WERE PUT INTO BASE^R II TO MAXIMIZE THE LOADING ON THE BOLTS. THE RESULTING MAXIMUM BOLT LOADS WERE [182]:

$$\begin{aligned} T_{\max} &= 20135 \text{ lb} \\ S_{\max x} &= 3586 \text{ lb} \\ S_{\max y} &= 3566 \text{ lb} \\ S_{\max} &= \left[S_{\max x}^2 + S_{\max y}^2 \right]^{1/2} = 5057 \text{ lb} \end{aligned}$$

THE BOLTS WERE THEN QUALIFIED USING THE FOLLOWING INTERACTION EQUATION FROM REFERENCE [13] AND

					THERMAL LOAD EVALUATION		
REV	BY	DATE	CHECKED	DATE	JOB NO	0210-02	PAGE
2	FRA	5/15/87 DWS	5/15/87		CALC NO	11-27	OF
					IMPELL		+7

AVERAGE ULTIMATE LOADS FROM REFERENCE [19]:

$$\left(\frac{T_{MAX}}{T_{ULT}} \right)^{4/3} + \left(\frac{S_{MAX}}{S_{ULT}} \right)^{4/3} \leq 1 \quad T_{ULT} = 42600 \text{ lb} \quad [19] \\ S_{ULT} = 45200 \text{ lb} \quad [19]$$

$$\left(\frac{20135}{42600} \right)^{4/3} + \left(\frac{5057}{45200} \right)^{4/3} = 0.42 \leq 1$$

IN ADDITION, THE BOLTS MUST BE QUALIFIED USING THE FOLLOWING INTERACTION EQUATION FROM REFERENCE [13]:

$$\left(\frac{T_{MAX}}{T_{BOLT}} \right)^2 + \left(\frac{S_{MAX}}{S_{BOLT}} \right)^2 \leq 1$$

WHERE T_{BOLT} AND S_{BOLT} ARE THE ULTIMATE TENSION AND SHEAR CAPACITIES OF THE BOLT CONSERVATIVELY CHOSEN TO BE MADE OF A307.

$$T_{BOLT} = 36350 \text{ lb} \quad [20]$$

THE SHEAR VALUE, S_{BOLT} , IS CONSERVATIVELY TAKEN AS THE ALLOWABLE SHEAR LOAD ON A 1" Ø A307 BOLT IN SINGLE SHEAR. NOTE, THIS IS A DESIGN ALLOWABLE AS OPPOSED TO AN ULTIMATE CAPACITY.

$$S_{BOLT} = 7850 \text{ lb} \quad [4]$$

$$\left(\frac{20135}{36350} \right)^2 + \left(\frac{5057}{7850} \right)^2 = 0.72 \leq 1.0$$

THERMAL LOAD EVALUATION					JOB NO CALC NO	PAGE OF
REV	BY	DATE	CHECKED	DATE		
2	RA	5/5/87	DWS	5/5/87	0210-C-1 M-27	25 OF -7



AS AN ADDED CHECK THE MAXIMUM SHEAR AND TENSION DISPLACEMENTS OF THE 1" Ø RICHMOND INSERTS WILL BE COMPARED TO AVERAGE SHEAR AND TENSION ULTIMATE DISPLACEMENTS FROM REFERENCES [19]. THE PROCEDURE TO OBTAIN THE SHEAR AND TENSION DISPLACEMENTS FROM TABLE I IS THE SAME PROCEDURE DESCRIBED IN SECTION 4.3e.

$$\Delta S = 0.010$$

$$\Delta S_{ULT} = 0.294 \text{ in}$$

$$\frac{\Delta S}{\Delta S_{ULT}} = 0.034$$

$$\Delta T = 0.01868$$

$$\Delta T_{ULT} = 0.163 \text{ in}$$

$$\frac{\Delta T}{\Delta T_{ULT}} = 0.115$$

THE EQUILIBRIUM TENSION DISPLACEMENT IS INDICATED ON THE LOAD DISPLACEMENT CURVE IN FIGURE 10. FIGURE 10 IS A TYPICAL CURVE WITH AN ULTIMATE DISPLACEMENT OF 0.146". EVEN COMPARING ΔT , 0.01868", TO THE MINIMUM ΔT_{ULT} , 0.134", FROM REFERENCE [19] SHOWS THAT IF THE MINIMUM ΔT_{ULT} IS USED FOR THE CURVE, THE EQUILIBRIUM TENSION DISPLACEMENT REMAINS FAR BELOW THE MINIMUM ΔT_{ULT} .

THE LINEAR STIFFNESS ASSUMED IN SHEAR IS SHOWN TO BE APPROPRIATE SINCE THE APPLIED SHEAR LOAD REMAINS FAR BELOW THE ULTIMATE.

THERMAL LIAI EVALUATION				
REV	BY	DATE	CHECKED	DATE
2	-41	5/5/87	DWS	5/5/87

	JOB NO 3318-521 CALC NO 11-27	PAGE - 5 OF 7
--	----------------------------------	---------------

THE K_z AND K_{xx} ANCHORAGE STIFFNESS ORIGINALLY ASSUMED IN THE SUPERFIFE ANALYSIS ARE PER FEC. ADDITIONAL LOAD CASES DOCUMENTED IN REFERENCE [18]. THE F_z AND M_{xx} LOAD COMPONENTS ARE APPLIED TO THE BASEPLATE BASEANGLE ATTACHMENT AND APPLIED AS SEPERATE LOAD CASES (SEE FIGURE 8 FOR LOCAL COORDINATE ORIENTATION). THE PROCEDURE TO OBTAIN THE STIFFNESSES IS THE SAME PROCEDURE AS DESCRIBED IN SECTION 4.2a.

ROTATIONAL STIFFNESS, K_{xx} :

FOR LOAD CASE # 6 [18], LOADING OF $M_x = 14.3$ KIP-IN

$$\begin{aligned}\Delta z_1 &= - .001898'' \\ \Delta z_2 &= .0006247''\end{aligned} \quad \left. \begin{array}{l} \Delta = .002523'' \\ \end{array} \right\}$$

$$L = \sin^{-1} \frac{.002523''}{1.5''} = .001682 \text{ RAD}$$

$$K_{xx} = \frac{14.3 \text{ KIP-IN}}{.001682 \text{ RAD}} = 8502 \text{ KIP-IN/RAD}$$

TRANSLATIONAL STIFFNESS, K_z :

FOR LOAD CASE # 5 [18], LOADING OF $F_z = 7.05$ KIP

$$\Delta z_1 = .02360''$$

$$K_z = \frac{1.05 \text{ KIP}}{.02360 \text{ IN}} = 299 \text{ KIP/IN}$$

					THERMAL LOAD EVALUATION		
					JOB NO	OILC 0-1	PAGE
REV	BY	DATE	CHECKED	DATE	CALC NO	M-27	27 OF 47
=	RH	5/4/87	DWS	5/5/87	IMPELL	4	

FOR THE BRACING MEMBER ATTACHMENT REACTIONS,
THE VERIFIED ANCHORAGE STIFFNESSES ARE
COMPARABLE WITH THOSE ASSUMED.

	VERIFIED	ASSUMED
K_z	299 KIP/IN	300 KIP/IN
K_{xx}	8502 KIP-IN/RAD	8500 KIP-IN/RAD

FOR THE CANTILEVER ATTACHMENT REACTIONS, THE
VERIFIED ANCHORAGE STIFFNESS COMPARABLE WITH
THOSE ASSUMED.

	VERIFIED	ASSUMED
K_{xy}	8502 KIP-IN/RAD	8500 KIP-IN/RAD

FOR THE CANTILEVER ATTACHMENT, THE F_z
COMPONENT CAUSES COMPRESSION IN THE BOLTS
AND THEREFORE THE MODELLING OF A RIGID STIFFNESS
IN THIS DIRECTION IS APPROPRIATE.

THERMAL LOAD CASE 1					THERMAL LOAD CASE 2	
REV	BY	DATE	CHECKED	DATE	JOB NO	PAGE
2	-f	7/7 DWS	5/5/87		0210-02	23 OF 29

IMPELL CORPORATION

4.4 "Worst Case" Support for Shear Alone

In the previous sections, the beam of cantilever was intended to represent a 'worst case' condition for combined shear and tensile bolt elongation. For bolt shear alone, a "worst case" condition is one which leads to a maximum force demand.

The direct clamping of trays to concrete is rarely employed, particularly in the Reactor Building. Due to the high axial compressive force mobilized by the stiff support, any available system slack will be mobilized by slippage. The equilibrium displacement at the support point will also be significantly reduced by the tray axial flexibility.

The bolt shear displacement is estimated by again conservatively assuming a 4c' tray run and neglecting tray tray flexibility. Tray slack will be assumed mobilized by slippage at the high axial loads.

$$\Delta_{\text{bolt}} = \Delta_{\text{TOTAL}} - \Delta_{\text{SLACK}}$$

$$\Delta_{\text{bolt}} = 0.60 - 0.35 = 0.25 \text{ in.}$$

*Ultimate shear, 1" HHTI = 0.320 in > 0.25 in.

*Ultimate shear, 1" Richardson = 0.294 in > 0.25 in.

Therefore both bolts have adequate shear displacement capacity to accommodate the "worst case" condition.

*The average test value presented is based on an "initial spalling" of concrete rather than a loss of structural capacity to resist load. A significantly greater margin against failure therefore actually exists.

					THERMAL LOAD EVALUATION		
					JOB NO	0210-041	PAGE
REV	BY	DATE	CHECKED	DATE	CALC NO	29	OF
2	DWS	5/5/87	ZPH	5/5/87	M-27	47	



3.0 CONCLUSIONS

The preceding sections have presented an evaluation of thermal load effects on cable tray systems. The results show that cable tray systems satisfy the IRR/FSAR criteria for the exclusion of accident thermal load from design requirements - the loads are resonant and self-limiting in nature and all materials and connections have been shown to be sufficiently ductile to ensure failure will not occur. For cases where ductility was questioned (i.e., steel-to-concrete anchorages), a numerical evaluation was performed for a "worst case" configuration. THE ANCHORAGE EVALUATION HAS SHOWN THAT:

1. FOR NORMAL OPERATING CONDITIONS THE CALCULATED THERMAL EXPANSION WAS SHOWN TO BE INSIGNIFICANT. THE MAXIMUM ACCIDENT THERMAL EXPANSION WHICH COULD CONSIDERABLY OCCUR ALONG WITH A SEISMIC EVENT WILL NOT EXCEED THE MINIMUM EXPECTED SLACK IN THE SYSTEM. THEREFORE THESE LOAD COMBINATIONS NEED NOT BE CONSIDERED.
2. FOR A SUPPORT INTENDED TO DEMONSTRATE "WORST CASE" COMBINED SHEAR AND TENSION BOLT DEFORMATIONS, THE MAXIMUM THERMAL EXPANSION WHICH MAY OCCUR DURING AN ACCIDENT EVENT WAS SHOWN TO BE LIMITED TO VALUES WHICH WOULD NOT CAUSE STRUCTURAL FAILURE. THIS WAS SHOWN TO BE TRUE EVEN FOR A LONGITUDINAL CABLE TRAY SUPPORT WITH AN UPPER BOUND STIFFNESS AND A "WORST CASE" ARRANGEMENT OF BOLTS AT THE BASE ANGLE ANCHORAGE. THE VALIDITY OF THIS CONCLUSION WAS NOT DEPENDENT ON MOBILIZING SYSTEM SLACK.

Thermal load evaluation				
REV	BY	DATE	CHECKED	DATE
2	HAA	5/5/87	DWS	5/5/87
1	ZRL	1/23/87	AH	2/24/87



JOB NO. 100-11
CALC NO. M-27

PAGE 30 OF 47

THE SHEAR AND TENSILE FORCES USED TO QUALIFY THE ANCHOR BOLTS FOR THE ACCIDENT THERMAL LOAD CASE WERE OVERESTIMATED FOR THE FOLLOWING REASONS:

- THE THERMAL DISPLACEMENT WAS BASED ON A 40 FOOT STRAIGHT RUN OF CABLE TRAY. INSPECTION OF THE REACTOR BUILDING SPAN LENGTH DRAWINGS SHOWS THIS LENGTH IS UNREALISTIC DUE TO THE CLOSELY SPACED CABLE TRAY BENDS IN THIS BUILDING.
- IN SPITE OF THE DOCUMENTED SLACK WHICH EXISTS IN THE CABLE TRAY SYSTEMS, IT WAS ASSUMED THAT THE THERMAL DISPLACEMENT OF THE SUPPORT WOULD BE THE SAME AS THE THERMAL DISPLACEMENT OF THE TRAY.
- THE THERMAL DISPLACEMENT WAS APPLIED TO A "WORST CASE" SUPPORT IN A LOCATION WHICH MINIMIZED THE FLEXURAL DEFORMATION OF THE SUPPORT AND MAXIMIZED REACTION FORCE AND MOMENT AT THE ANCHORAGE.
- ALTHOUGH THE AXIAL FLEXIBILITY OF THE TRAY WOULD REDUCE THE EQUILIBRIUM DISPLACEMENT AT THE SUPPORT POINT, THE ENTIRE THERMAL DISPLACEMENT WAS APPLIED TO THE CLAMP.

					THERMAL LOAD EVALUATION		
REV	BY	DATE	CHECKED	DATE	IMPELL	JOB NO	PAGE
2	HAA	5/5/87	DWD	5/5/87	IMPELL CORPORATION	2210-041 CALC NO	31 OF 47 M-27

- IN PERFORMING SEPARATE SUPERPIPE ANALYSES FOR ANCHORAGES WITH BOTH HILTI KWIK BOLTS AND RICHMOND INSERTS, FINITE STIFFNESS VALUES WERE ASSUMED FOR THE LOCAL KY AND KK ANCHORAGE DIRECTIONS. THESE ASSUMED STIFFNESSES WERE LATER CONFIRMED BY ANALYZING THE ANCHORAGE FOR APPLIED LOADS IN THESE TWO DIRECTIONS WITH THE NON-LINEAR PROGRAM BASED II. ANCHORAGE STIFFNESS VALUES FOR THE REMAINING DEGREES OF FREEDOM WERE ASSUMED RIGID.
- A CRITICAL ANCHORAGE CONFIGURATION WAS ASSUMED IN THE BASED II QUALIFICATION. USING THE MEMBER ANCHORAGE REACTIONS CALCULATED BY SUPERPIPE, THE BOLT DISPLACEMENTS AND SHEAR/TENSILE LOADS WERE SHOWN TO BE FAR BELOW ULTIMATE VALUES. THE EQUILIBRIUM LOCATIONS ARE INDICATED IN FIGURES 9 AND 10 FOR THE BOLT TENSION DIRECTIONS. DUE TO THE LARGE AMOUNT OF DEFORMATIONAL CAPACITY REMAINING IN THE BOLTS, THERMAL DISPLACEMENTS SIGNIFICANTLY LARGER THAN THOSE CALCULATED COULD BE ACCOMMODATED WITHOUT FAILURE.

					THERMAL LOAD EVALUATION		
REV	BY	DATE	CHECKED	DATE	JOB NO C210-071	PAGE	
2	MTH	5/5/87	DWS	5/5/87	CALC NO	M 27	32 OF 47



3. FOR A SUPPORT INTENDED TO DEMONSTRATE A "WORST CASE" CONDITION FOR BOLT SLACK, THE MAXIMUM DISPLACEMENT WAS ONCE MORE SHOWN TO BE LIMITED TO VALUES WHICH WOULD NOT CAUSE FAILURE. FOR THIS CASE THE AVAILABLE SLACK WAS ASSUMED MOBILIZED BY THE HIGH AXIAL TRAY LOADS.

IT HAS BEEN THEREFORE RECEIVED SHOWN THAT THE CPSES CABLE TRAY SYSTEMS SATISFY THE SPP/FSAR CRITERIA FOR THE EXCLUSION OF THERMAL LOADS FROM DESIGN CRITERIA.

THERMAL LOAD EVALUATION				
REV	PY	DATE	CHECKED	DATE
2	TRA	5/15/87	DWS	5/15/87
IMPELL  CORPORATION			JOB NO 0210-041 CALC NO	PAGE 33 OF 47
M-27				

6.0 REFERENCES

- [1] COMANCHE PEAK STEAM ELECTRIC STATION, FINAL SAFETY ANALYSIS REPORT (AMENDMENT 55; JULY 19, 1985)
- [2] STATIC TESTS OF CABLE TRAYS AND FITTINGS FOR CPSES BY CC&L REPORT # A-719-86, JUNE, 1986
- [3] CPSES UNIT I FIELD VERIFICATION METHOD, TNE-FUM-CS-001, MARCH 20, 1986
- [4] AMERICAN INSTITUTE OF STEEL CONSTRUCTION (AISC), 7th EDITION
- [5] AMERICAN SOCIETY FOR METALS, METALS HANDBOOK NINETH EDITION, VOLUME 1; PROPERTIES AND SELECTION: IRONS AND STEELS, AMERICAN SOCIETY FOR METALS, 1978
- [6] IMPELL PROJECT INSTRUCTIONS PI-02 "DYNAMIC ANALYSIS OF CABLE TRAY SYSTEMS" REV. 5
- [7] STATIC STIFFNESS AND FREQUENCY DETERMINATION TEST RESULTS FOR TYPICAL CPSES CABLE TRAY HANGER SUPPORTS, ANCO ENGINEERS INC., SCT. 1986, PRELIMINARY RESULTS
- [8] FRANK P. INCROPERA AND DAVID P. DEWITT, FUNDAMENTALS OF HEAT TRANSFER, JOHN WILEY & SONS, NEW YORK, 1981

					Thermal Load Evaluation		
REV	BY	DATE	CHECKED	DATE	JOB NO	0210-241	PAGE
1	RA	2/5/87	RML	2/6/87	CALC NO	M - 27	27 OF 47
					IMPELL		

[9] "STATISTICAL ANALYSES OF BOLT HOLE/EDGE DISTANCES IN CTHS", EBASCO STUDY VOLUME I, Book 22.

[10] "General Instructions for Cable Tray Hanger Analysis for Comanche Peak Steam Electrical Station No. 1 and 2", Rev. R2, December 20 1985, by Ebasco Services Inc.

[11] Raymond J. Rourk and Warren C. Young, Formulas for Stress and Strain, 5th Edition, McGraw-Hill, New York 1975

[12] Theodore Baumeister, Eugene A. Avallone and Theodore Baumeister III, Merk's Standard Handbook for Mechanical Engineers, McGraw-Hill, New York, 1978

[13] Impell Project Instructions PI-07,
"Design Verification of Base Plates, Base Angles and Embedment Plates" Rev. 3

[4] Abbott A Hanks File No. 142139-S1, Report No. 87B4, dated January, 1974.

[15] Transmittal, V. Svetlichny (Richmond) to J. Ramnuta (Impell) Bulletin # to test reports on EC Type Inserts, dated 9/17/86

Thermal Load Evaluation				
REV	BY	DATE	CHECKED	DATE
2	DWS	5/5/87	BPH	5/5/87
1	HAT	-5/37	KTM	2/6/87
IMPELL CORPORATION		JOB NO 0210-321 CALC NO	M-27	PAGE 25 OF 47

[16] IMPELL CALCULATION M-04: "BASE ANGLE STIFFNESSES", REV. 1

[17] BASER II OUTPUT 87/05/02 . 16.00.23
HILTI

[18] BASER II OUTPUT 87/05/02 . 15.59.16
RICHMOND

[19] TEST REPORT : "SHEAR AND TENSION LOADING OF RICHMOND INSERTS 1½-INCH TYPE EC-6W 1-INCH TYPE EC-2W" APRIL 19, 1984

[20] ASTM SPECIFICATION A 307-78.

[21] SUPER PIPE RUN 87/05/02 . 15.49.14 HILTI

[22] SUPERPIPE RUN 87/05/02 . 16.30.37 RICHMOND

[23] NOT USED

[24] C.E.L. REPORT # A-717-86 : "TEST REPORT FOR MONOTONIC AND CYCLIC TESTS FOR TRAY CLAMPS FOR CPSEZ", JUNE 27, 1986 ; APPENDIX C-4.

[25] IMPELL SUPERPIPE OUTPUT 87/05/05 . 14.33.53

[26] IMPELL SUPERPIPE OUTPUT 87/05/05 . 13.42.15

[27] SUPERPIPE V.21A 10/16/86 , IMPELL CORPORATION STANDARD PROGRAM

[28] BASEPLATE II , V 2.6 JULY 86, COMPUTER PROGRAM

THERMAL LOAD EVALUATION					
REV	BY	DATE	CHECKED	DATE	
2	HAT	5/4/87	DWS	5/5/87	 IMPELL CORPORATION

JOB NO 0210-C41
CALC NO
M-27

PAGE 36 OF 47


7.0 FIGURES

					Thermal Lead Evaluation
1	R.K.	2/17/87	TRT	2/17/87	
REV	BY	DATE	CHECKED	DATE	
 IMPELL <small>CORPORATION</small>					JOB NO 0210-041 CALC NO M-27
					PAGE 37 OF -7


TOPOGRAPHIC MAPS
INSTRUMENTATION: THERMISTOR
WIRE

Figure 1

FROM SWIFT AND ASSOCIATES
UNITS 1 and 2
COMMENCE PEAK SEIS



DESIGN
 GEORGE E. ELECTRIC
 Job No. 0210-041
 Date 12/27
 M-27
 215.87
 12/27/73



FOMANCE PEAKS
 FROM SAFETY ANALYSIS REPORT
 UNITS 1 and 2

STRUCTURAL WAT. THERMISTOR
 CIRCUIT - D100

Figure 2

COMANCHE PEAK SES
FINAL SAFETY ANALYSIS REPORT

UNITS 1 and 2

CONTAINMENT VAPOR
TEMPERATURE TRAJECTORY
0.908 FT² SPLIT 31B AT 10% FLOW
ONE 100% SPRAT




Figure 3

COMANCHE PEAK S.E.S.
FINAL SAFETY ANALYSIS REPORT
UNITS 1 and 2

CONTAINMENT INTERNAL
TEMPERATURE
TRANSIENT IN SPLIT SITE
MANUFACTURE 1-1-1




Figure 4




FIGURE 5

THERMAL LOAD EVALUATION				
REV	BY	DATE	CHECKED	DATE
2	HAT	5/5/87	DWS	5/5/87
IMPELL CORPORATION			JOB NO 0210-041	PAGE 42 OF 47
CALC NO M-27				

00003

1903.22 TUGCO
SAMPLE NO. A-4C-02






FIGURE 6

PG. -3

47

000078

A-4C-02




NOTE:
THE PLATE MAY
BE BENT TO FIT
THE CURVATURE OF
TRAY.

3/16" WASHER PLATE
DETAIL

TYPE 'B' HEAVY DUTY CLAMP

FIGURE 7

AZ




ANCHORAGE CONFIGURATION USED
TO QUALIFY ANCHOR BOLTS.

FIGURE 8

THERMAL LOAD EVALUATION				
REV	BY	DATE	CHECKED	DATE
2	JRT	5/5/87	DWS	5/5/87
IMPELL			JOB NO 0210-041	PAGE 15 OF 27
CORPORATION			CALC NO	M-27


FIGURE 9 1" HILTI Kwik BOLT
TENSILE LOAD DISPLACEMENT CURVE
REFERENCE [14]

4 1/2" EMBEDMENT



REV	BY	DATE	CHECKED	DATE	IMPELL CORPORATION	JOB NO 0210-241	PAGE 1 OF 7
2	TRA	5/5/87 DWS	5/5/87			CALC NO M-27	

FIGURE 10 1" RICHMOND INERT
TENSILE LOAD DISPLACEMENT
REFERENCE [19]



REV	BY	DATE	CHECKED	DATE
R-A	S/S/87	DWS	S/S/87	

IMPELL
CORPORATION

JOB NO 0210-041

CALC NO

M-27

PAGE
47
OF
47