



Idaho National Engineering Laboratory

June 17, 1987

50-344

Mr. M. Carrington, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

TRANSMITTAL OF FINAL REPORT, "CONFORMANCE TO GENERIC LETTER 83-28,
ITEM 2.2.2--VENDOR INTERFACE PROGRAMS FOR ALL OTHER SAFETY-RELATED
COMPONENTS: TROJAN," EGG-NTA-7663, JUNE 1987 (FIN D6001) - EWR-146-87

Ref: NRC Form 189, "Evaluation of Conformance to Generic Letter 83-28 For
ORs (Project 2)" (D6001)

Dear Mr. Carrington:

Transmitted herewith is the above subject report.

The report documents INEL's evaluation of the licensee actions in response to NRC Generic Letter 83-28, Item 2.2.2--Vendor Interface Programs for All Other Safety-Related Components. Based on the licensee submittals, we conclude that the plant conforms to the generic letter on this item except for a vendor interface with vendors other than the NSSS vendor. The licensee should establish a program for regular periodic contact with these vendors.

Very truly yours,


E. W. Roberts, Manager
NRC Headquarters Support

ACU:gp

Enclosure:
As Stated

cc: G. L. Jones, DOE-ID
D. Lasher, SICB (2)
J. O. Zane, EG&G Idaho, Inc. (w/o Encl.)

B707170014 B70617
PDR ADOCK 05000344
P PDR



11428 Rockville Pike

Suite 410

Rockville, MD 20852

Hool Add: T. Chan Ltr Encl
1/1