

DS09
L. Shottkin



WASHINGTON PUBLIC POWER

DOCKETED USNRC
RULES & PROCEDURES BR
RR:ADM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

87 JUL 14 A9:40

April 8, 1987
52 FR 11385
(7)

July 9, 1987

Rules and Procedures Branch
Division of Rules and Records
Office of Administration
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Sir:

Subject: REVIEW OF DRAFT REGULATORY GUIDE
"BEST-ESTIMATE CALCULATIONS OF EMERGENCY CORE
COOLING SYSTEM PERFORMANCE" (TASK RS 701-4)

The Supply System has reviewed the subject draft Regulatory Guide and finds that, in general, it represents a step forward toward a more reasonable approach to regulation. We encourage the continued use of Best Estimate Computational Models, however, without the availability of NUREG-1230, "Compendium of ECCS Research for Realistic LOCA Analysis", (to be published), and a sufficient review time, it is difficult to assess the impact or reasonableness of this Regulatory Guide. We would urge you to delay issuance of this Regulatory Guide until NUREG-1230 is available and reviewed.

Our detailed comments are noted on the attachment. Thank you for this opportunity to participate in the NRC's standards development process. Should you have any questions regarding these comments, please feel free to contact me.

Very truly yours,

G. C. Sorensen, Manager
Regulatory Programs

cc: D Williams/BPA 399

8707220101 870709
PDR REGGD
01. XXX C PDR

ATTACHMENT I

- Page A-3, Section 1.3.1 - In the first sentence, the words are "... range 1,500-1,900°F . . ." whereas in the last sentence of this paragraph the words are "... greater than 1,900°F and less than 1,500°F . . ." It should be "... greater than 1,500°F and less than 1,900°F . . ."
- Page B-5, Section 1.2.2 - In the first full paragraph, it is stated "In ECCS performance calculations, the break should be assumed to occur instantaneously." Finite break opening time should be allowed for ECCS performance as it is for other portions of LOCA analyses. Appropriate evaluation of uncertainties in break opening time would then be included in the overall model uncertainty evaluations.