

OCT 08 1987

Duke Power Company
ATTN: Mr. H. B. Tucker, Vice President
Nuclear Production Department
422 South Church Street
Charlotte, North Carolina 28242

Gentlemen:

SUBJECT: DOCKET NOS. 50-369 AND 50-370

This acknowledges the receipt of your letter of August 18, 1987, which transmitted Revision 30 to the McGuire Physical Security Plan.

Our review of the changes has found most of them to be consistent with the provisions of 10 CFR 50.54(p). Accordingly, they are acceptable for inclusion into the plan. However, as indicated in the enclosure, one change requires further clarification and one change is not consistent with the provisions of 10 CFR 50.54(p). On September 25, 1987, Ms. C. Perny of this office discussed these concerns with Mr. R. Cross of your staff.

Please revert to the commitments in your previously approved plan or, if desired modify your plan to accommodate the enclosed comments and resubmit corrected plan changes as necessary to maintain plan continuity. Should you want to pursue the change deemed inconsistent, you must submit a request to the Commission's Office of Nuclear Reactor Regulation under the provisions of 10 CFR 50.90 for amendment to your license.

The enclosure to your letter is being withheld from public disclosure because it contains Safeguards Information and must be protected in accordance with the provisions of 10 CFR Part 73.21.

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

William E. Cline, Chief
Nuclear Materials Safety and
Safeguards Branch
Division of Radiation Safety
and Safeguards

Enclosure:
Inconsistent Changes

cc w/encl: (See page 2)

8710130281 871008
PDR ADOCK 05000369
F PDR

RGol
~~RGol~~
1/1

OCT 08 1937

(cc w/encl cont'd)
Duke Power Company
ATTN: Mr. A. V. Carr, Esq.
P.O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Duke Power Company
ATTN: Mr. R. L. Gill
Nuclear Production Department
P.O. Box 33189
Charlotte, North Carolina 28242

Mr. C. D. Markham
Power Systems Division
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell and Reynolds
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Mr. L. L. Williams
Operating Plants Projects Regional Manager
Westinghouse Electric Corporation - R&D 701
P.O. Box 2728
Pittsburgh, Pennsylvania 15230

Mr. Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
P. O. Box 12200
Raleigh, North Carolina 27605

Saluda River Electric Cooperative, Inc.
P. O. Box 929
Laurens, SC 29360

bcc w/encl: (See page 3)

OCT 08 1987

bcc w/encl:
Document Control Desk (RG01), 42-P
Director, Division of Reactor
Inspection and Safeguards, NRR
EWS-305A
Region II Licensing File,
(50-369) (21VA), TAB 2
Resident Inspector
A. Tillman
State of North Carolina

RII
CPerry
10/1/87

RII
DMcGuire
10/7/87

RII
WClone
10/7/87

RII
TPeebles
10/7/87
10/8/87

ENCLOSURE

Revision 30 to the McGuire Physical Security Plan

Change Inconsistent with the Provisions of 10 CFR 50.54(p)

<u>Page</u>	<u>Section</u>	<u>Comment</u>
4.5-1 4	4.5.1 Glossary of Terms	<p>Tractors were deleted from the description of typical designated vehicles. Tractors were added to the examples in the in the Glossary of Terms as means of transport which do not qualify as vehicles.</p> <p>10 CFR 73.55(d)(4) requires licensees to exercise positive control over all designated vehicles to assure that they are used only by authorized persons and for authorized purposes. Special purpose vehicles such as tractors cannot be excluded from vehicle controls unless the licensee can demonstrate that the vehicle is of such light weight and construction that it could not be used as a means of causing radiological sabotage. The categories of vehicles which were previously listed as examples of exceptions to the vehicle controls were jitneys, trams, and carts.</p> <p>ACTION: Reinstate tractors as a vehicle type which will be controlled or provide an analysis which would support a statement that tractors are of insufficient weight and acceleration capability to be used as a means of causing radiological sabotage. Also, recognize that the term tractor refers to both farming/pulling machinery and to trucks having a cab and no body which are used for pulling large vehicles such as trailers or vans.</p>

Change Requiring Editorial Clarification

Figure MSP-11	<p>The changes described in the synopsis were not made to the copies of MSP-11 transmitted to this office.</p> <p>Provide revised copies MSP-11.</p>
---------------	--