

078.

FEB 24 1989

Docket No. 50-302
License No. DPR-72

Florida Power Corporation
Mr. W. S. Wilgus
Vice President Nuclear Operations
ATTN: Manager, Nuclear Licensing
P. O. Box 219
Crystal River, FL 32629

Gentlemen:

SUBJECT: DISCRETIONARY ENFORCEMENT TO ALLOW CONTINUED OPERATION WITH REACTOR
COOLANT PUMP POWER MONITOR CHANNELS TECHNICAL SPECIFICATION
SURVEILLANCE NOT PERFORMED

This letter acknowledges your letter dated February 14, 1989, requesting discretionary enforcement associated with the performance of the surveillance required by Technical Specification 4.3.1.1.1, Reactor Coolant Pump Power Monitor Surveillance. This request is limited to the time period prior to the next plant shutdown, presently scheduled to begin no later than February 28, 1989.

We have reviewed your request which included discussions with your staff during the week of February 13, 1989, and the request was subsequently granted in a telephone conversation with Region II staff on February 16, 1989.

Should you have any questions concerning this letter, please contact us.

Sincerely,

Original signed by
J. Philip Stohr (for)

Malcolm L. Ernst
Acting Regional Administrator

8903070150 890224
PDR ADDCK 05000302
P PNU

cc: P. F. McKee, Director, Nuclear
Plant Operations
E. C. Simpson, Director, Nuclear
Site Support
State of Florida

bcc: NRC Resident Inspector
DRS Technical Assistant
Document Control Desk

RII
RCr1enjak
02/27/89

RII
BWilson
02/23/89

LR
2/24/89

gk
G. JENKINS
2/24/89

Gibson
2/24/89
JE01