

Georgia Power Company  
Post Office Box 282  
Waynesboro, Georgia 30830  
Telephone 404 554-9961  
404 724-8114

Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202  
Telephone 205 870-6011



**Vogtle Project**

October 15, 1987

United States Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

File: X7BC35  
Log: GN-1405

Reference: Letter Number GN-1382, dated July 13, 1987

NRC DOCUMENT NUMBERS 50-424 AND 50-425  
OPERATING LICENSE NPF-68  
CONSTRUCTION PERMIT NUMBER CPPR-109  
VOGTLE ELECTRIC GENERATING PLANT UNITS 1 AND 2  
DIESEL FUEL OIL STORAGE TANKS COATING

Gentlemen:

In the referenced letter, Georgia Power Company discussed the pop test performed on the diesel generator to check the spray pattern from the fuel injectors. As part of this test, all injectors are disassembled, cleaned, inspected, and damaged or worn parts replaced. During this test Georgia Power Company will analyze the content of any significant deposits, to the extent practical, and will pay particular attention to any zinc that may be present. These instructions will be added to the Diesel Generator Maintenance Procedure.

Should you have any questions, please inquire.

Sincerely,

J. A. Bailey  
Project Licensing Manager

JAB/wk1

xc: NRC Regional Administrator  
NRC Resident Inspector  
J. P. O'Reilly  
R. E. Conway  
P. D. Rice  
L. T. Gucwa  
R. A. Thomas  
J. E. Joiner, Esquire  
M. A. Miller (2)  
G. Bockhold, Jr.  
R. Goddard, Esquire  
D. Feig  
R. W. McManus  
Vogtle Project File

8710230173 871015  
PDR ADOCK 05000424  
P PDR

Boo1  
1/0