



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 12 1987

MEMORANDUM FOR:

~~R. Wessman~~, Acting Project Director
Project Directorate I-3
Division of Reactor Projects - I/II

FROM:

M. W. Hodges, Chief
Reactor Systems Branch
Division of Engineering
& Systems Technology

SUBJECT:

SER FOR TECHNICAL SPECIFICATION CHANGES
FOR STANDBY LIQUID CONTROL SYSTEM

Plant Name:	Pilgrim Nuclear Power Station
Docket No:	50-293
TAC No:	59127
Project Directorate:	Project Directorate I-3
Project Manager:	R. Wessman
Review Branch:	SRXB
Review Status:	Complete

Enclosure 1 is the Reactor Systems Branch SER on Boston Edison Company's request to modify the Technical Specifications for Pilgrim Nuclear Power Station. The licensee's proposal will make the Standby Liquid Control System Technical Specifications consistent with the requirements of ATWS Rule, 10 CFR 50.62.C.4, for that system. This is acceptable to us.

Enclosure 2 is our SALP input.

M. W. Hodges

M. W. Hodges, Chief
Reactor Systems Branch
Division of Engineering
& Systems Technology

Enclosures:
As stated

cc w/enclosures:
S. Varga
B. Boger
A. Thadani
R. Wessman
H. Li
SRXB Members

Contact: G. Thomas, RSB, x27588

8707300325XAP

E/24