



Log # TXX-6610
File # 10110
907.6
Ref: 10CFR50.55(e)

William G. Council
Executive Vice President

July 29, 1987

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
BOP SAFETY RELATED INSTRUMENT SET POINTS
SDAR: CP-86-81 (INTERIM REPORT)

Gentlemen:

On November 7, 1986, we verbally notified your Mr. T. Westerman of a potentially reportable item involving the calculations for BOP safety-related instrument setpoints indicating that omissions of required data or use of incorrect information occurred in performing the calculations required in Reg. Guide 1.105, Rev. 1. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e). Our latest interim report logged was TXX-6271 dated February 6, 1987.

The engineering evaluation of this issue has been completed and the initial results indicate that this issue is not reportable pursuant to 10CFR50.55(e). We are in the process of final verification of those results and anticipate completion by August 21, 1987. We will submit our next report by September 18, 1987.

Very truly yours,

W. G. Council

W. G. Council

By: *G. S. Keeley*
G. S. Keeley
Manager, Nuclear Licensing

RDD/mlh

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8708030086 870729
PDR ADOCK 05000445
S PDR

IF27
1/0