

Docket Nos.: 50-424
and 50-425

JUL 30 1987

Mr. James P. O'Reilly
Senior Vice President - Nuclear Operations
Georgia Power Company
P.O. Box 4545
Atlanta, Georgia 30302

Dear Mr. O'Reilly:

Subject: Staff Acceptance of Stainless Steel Ties for Use in Vertical
Cable Trays for Vogtle Units 1 and 2 (TAC 63584)

By letter dated May 27, 1987, Georgia Power Company submitted its long-term proposal for support of cable in vertical cable trays, i.e., through the use of stainless steel cable ties. The staff has completed its review of this submittal and concludes that the use of stainless steel ties to support cables in vertical cable trays is acceptable.

The staff's evaluation is enclosed.

Sincerely,

151

Melanie A. Miller, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II

Enclosure: As stated

cc: See next page

DISTRIBUTION:

Docket File

NRC PDR

Local PDR

PDII-3 Reading

BJYoungblood Reading

SVarga/GLainas

MDuncan

OGC-Bethesda

EJordan

JPartlow

ACRS(10)

MMiller

NRomney

PDII-3/DRPI/II

MMiller/rad

07/2/87

PDII-3/DRPI/II

MDuncan

07/30/87

PDII-3/DRPI/II

BJYoungblood

07/30/87

8708050059 870730
PDR ADDOCK 05000424
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 30 1987

Docket Nos.: 50-424
and 50-425

Mr. James P. O'Reilly
Senior Vice President - Nuclear Operations
Georgia Power Company
P.O. Box 4545
Atlanta, Georgia 30302

Dear Mr. O'Reilly:

Subject: Staff Acceptance of Stainless Steel Ties for Use in Vertical
Cable Trays for Vogtle Units 1 and 2 (TAC 63584)

By letter dated May 27, 1987, Georgia Power Company submitted its long-term proposal for support of cable in vertical cable trays, i.e., through the use of stainless steel cable ties. The staff has completed its review of this submittal and concludes that the use of stainless steel ties to support cables in vertical cable trays is acceptable.

The staff's evaluation is enclosed.

Sincerely,

A handwritten signature in cursive script, reading "Melanie A. Miller", is positioned above the typed name.

Melanie A. Miller, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II

Enclosure: As stated

cc: See next page

Mr. J. P. O'Reilly
Georgia Power Company

Vogtle Electric Generating Plant

cc:

Mr. L. T. Gucwa
Chief Nuclear Engineer
Georgia Power Company
P.O. Box 4545
Atlanta, Georgia 30302

Resident Inspector
Nuclear Regulatory Commission
P. O. Box 572
Waynesboro, Georgia 30830

Mr. Ruble A. Thomas
Vice President - Licensing
Vogtle Project
Georgia Power Company/
Southern Company Services, Inc.
P.O. Box 2625
Birmingham, Alabama 35202

Deppish Kirkland, III, Counsel
Office of the Consumers' Utility
Council
Suite 225
32 Peachtree Street, N.W.
Atlanta, Georgia 30303

Mr. Paul D. Rice
Vice President & Project General Manager
Georgia Power Company
Post Office Box 299A, Route 2
Waynesboro, Georgia 30830

James E. Joiner
Troutman, Sanders, Lockerman,
& Ashmore
Candler Building
127 Peachtree Street, N.E.
Atlanta, Georgia 30303

Mr. J. A. Bailey
Project Licensing Manager
Southern Company Services, Inc.
P.O. Box 2625
Birmingham, Alabama 35202

Danny Feig
1130 Alta Avenue
Atlanta, Georgia 30307

Ernest L. Blake, Jr.
Bruce W. Churchill, Esq.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington, D. C. 20037

Carol Stangler
Georgians Against Nuclear Energy
425 Euclid Terrace
Atlanta, Georgia 30307

Mr. G. Bockhold, Jr.
Vogtle Plant Manager
Georgia Power Company
Route 2, Box 299-A
Waynesboro, Georgia 30830

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Mr. R. E. Conway
Senior Vice President and Project Director
Georgia Power Company
Rt. 2, P. O. Box 299A
Waynesboro, Georgia 30830