

July 28, 1987

Docket No.: 50-344

Mr. David W. Cockfield  
Vice President, Nuclear  
Portland General Electric Company  
121 S.W. Salmon Street  
Portland, Oregon 97204

Dear Mr. Cockfield:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - LCA 150 - POWER  
LOCKOUT OF ACCUMULATOR ISOLATION VALVES (TAC NO. 64533)

DISTRIBUTION

Docket File

NRC & Local PDRs  
PD5 Plant File  
GMHolahan  
JLee  
TChan  
OGC-Bethesda  
EJordan/JPartlow  
ACRS (10)

By letter dated January 20, 1987 Portland General Electric Company requested a change to the Trojan Technical Specifications (LCA 150) regarding the disconnection of power from the accumulator isolation valves operator. The proposed change would replace the requirement to specifically disconnect power to these valves by removal of the breaker from the circuit, with a more general requirement that would allow the use of a lockout feature on the accumulator isolation valve control room switches.

We have reviewed your submittal and find that additional information is required before we can complete our review. We ask that you provide the requested information contained in Enclosure 1 within 60 days from receipt of this letter, or provide an alternative schedule for doing so within 15 days.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

Original signed by  
Terence L. Chan, Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure:  
As stated

cc: w/enclosure  
See next page

DRSP/PD5  
TChan:ts  
7/28/87

DRSP/D:RD5  
GWKrighton  
7/28/87

8708050200 870728  
PDR ADCK 05000344  
P PDR

Mr. David W. Cockfield  
Portland General Electric Company

Trojan Nuclear Plant

cc:  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Trojan Nuclear Plant  
Post Office Box 0  
Rainier, Oregon 97048

Michael J. Sykes, Chairman  
Board of County Commissioners  
Columbia County  
St. Helens, Oregon 97501

Mr. David Kish  
Oregon Department of Energy  
Labor and Industries Building  
Room 111  
Salem, Oregon 97310

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

REQUEST FOR ADDITIONAL INFORMATION  
TROJAN NUCLEAR PLANT  
PROPOSED TECHNICAL SPECIFICATION CHANGE REGARDING  
SURVEILLANCE REQUIREMENTS FOR POWER LOCKOUT OF THE  
ACCUMULATOR ISOLATION VALVES

By letter dated January 20, 1987 you requested a change to the Trojan Technical Specifications regarding the disconnection of power from the accumulator isolation valves operator. You proposed to delete the requirement to specifically disconnect power to these valves by removal of the breaker from the circuit and to replace it with a more general requirement that would allow the use of a lockout feature on the accumulator isolation valve control room switches. We have reviewed your request and find that we require additional information before we can complete our review.

1. Provide an electrical schematic and description of the lockout feature on the accumulator isolation valve control room switches referred to in your January 20, 1987 letter.
2. Provide a description of the procedure you intend to use to accomplish the proposed surveillance requirement (4.5.1.C) to verify that power to the isolation valves operator is disconnected. This is the procedure that would involve the use of the lockout feature on the accumulator isolation valve control room switches.