



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 113
License No. DPR-59

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Power Authority of the State of New York (the licensee) dated March 16, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:

8711040244 871022
PDR ADDCK 05000333
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 113, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Acting Director
Project Directorate I-1
Division of Reactor Projects, I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 22, 1987



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ATTACHMENT TO LICENSE AMENDMENT NO. 113

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Revise Appendix A as follows:

<u>Remove Pages</u>	<u>Insert Pages</u>
ii	ii
vii	vii
136	136
137	137
138	138
146	146
147	147
148	148
163	163

TABLE OF CONTENTS (cont'd)

		<u>Page</u>
F. Minimum Emergency Core Cooling System Availability	F.	122
G. Maintenance of Filled Discharge Pipe	G.	122
H. Average Planar Linear Heat Generation Rate (APLHGR)	H.	123
I. Linear Heat Generation Rate (LHGR)	I.	124
J. Thermal Hydraulic Stability	J.	124a
<u>LIMITING CONDITIONS FOR OPERATION</u>	<u>SURVEILLANCE REQUIREMENTS</u>	
3.6 Reactor Coolant System	4.6	136
A. Pressurization and Thermal Limits	A.	136
B. Deleted		
C. Coolant Chemistry	C.	139
D. Coolant Leakage	D.	141
E. Safety and Safety/Relief Valves	E.	142a
F. Structural Integrity	F.	144
G. Jet Pumps	G.	144
H. DELETED		
I. Shock Suppressors (Snubbers)	I.	145b
3.7 Containment Systems	4.7	165
A. Primary Containment	A.	165
B. Standby Gas Treatment System	B.	181
C. Secondary Containment	C.	184
D. Primary Containment Isolation Valves	D.	185
3.8 Miscellaneous Radioactive Material Sources	4.8	214
3.9 Auxiliary Electrical Systems	4.9	215
A. Normal and Reserve AC Power Systems	A.	215
B. Emergency AC Power System	B.	216
C. Diesel Fuel	C.	218
D. Diesel-Generator Operability	D.	220
E. Station Batteries	E.	221
F. LPCI MOV Independent Power Supplies	F.	222a
G. Reactor Protection System Electrical Protection Assemblies	G.	222c
3.10 Core Alterations	4.10	227
A. Refueling Interlocks	A.	227
B. Core Monitoring	B.	230
C. Spent Fuel Storage Pool Water Level	C.	231
D. Control Rod and Control Rod Drive Maintenance	D.	231
3.11 Additional Safety Related Plant Capabilities	4.11	237
A. Main Control Room Ventilation	A.	237
B. Crescent Area Ventilation	B.	239
C. Battery Room Ventilation	C.	239

LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.1-1	Manual Flow Control	47a
3.1-2	Operating Limit MCPR versus	47b
4.1-1	Graphic Aid in the Selection of an Adequate Interval Between Tests	48
4.2-1	Test Interval vs. Probability of System Unavailability	87
3.4-1	Sodium Pentaborate Solution of System Volume-Concentration Requirements	110
3.4-2	Saturation Temperature of Sodium Pentaborate Solution	111
3.5-1	Thermal Power and Core Flow Limits of Specifications 3.5.J.1 and 3.5.J.2	134
3.5-6	(Deleted)	135d
3.5-7	(Deleted)	135e
3.5-8	(Deleted)	135f
3.5-9	MAPLHGR Versus Planar Average Exposure Reload 4, P8DRB284L	135g
3.5-10	MAPLHGR Versus Planar Average Exposure Reloads 4 & 5, P8DRB299	135h
3.5-11	MAPLHGR Versus Planar Average Exposure Reload 6, BP8DRB299	135i
3.6-1	Reactor Vessel Pressure-Temperature Limits	163
4.6-1	Chloride Stress Corrosion Test Results at 500°F	164
6.1-1	Management Organization Chart	258
6.2-1	Plant Staff Organization	260

Amendment No. ~~14~~, ~~22~~, ~~43~~, ~~64~~, ~~72~~, ~~74~~, ~~88~~, ~~98~~, 113

3.6 LIMITING CONDITIONS FOR OPERATION3.6 REACTOR COOLANT SYSTEMApplicability:

Applies to the operating status of the Reactor Coolant System.

Objective:

To assure the integrity and safe operation of the Reactor Coolant System.

Specification:A. Pressurization and Thermal Limits1. Reactor Vessel Head Stud Tensioning

The reactor vessel head bolting studs shall not be under tension unless the temperatures of the reactor vessel flange and the reactor head flange are at least 90°F.

2. In-Service Hydrostatic and Leak Tests

During in-service hydrostatic or leak testing the Reactor Coolant System pressure and temperature shall be on or to the right of curve A shown in Figure 3.6-1 and the maximum temperature change during any one hour period shall be:

Amendment No. 1/4, 113

4.6 SURVEILLANCE REQUIREMENTS4.6 REACTOR COOLANT SYSTEMApplicability:

Applies to the periodic examination and testing requirements for the Reactor Coolant System.

Objective:

To determine the condition of the Reactor Coolant System and the operation of the safety devices related to it.

Specification:A. Pressurization and Thermal Limits1. Reactor Vessel Head Stud Tensioning

When in the cold condition, the reactor vessel head flange and the reactor vessel flange temperatures shall be recorded:

- a. Every 12 hours when the reactor vessel head flange is $\leq 120^{\circ}\text{F}$ and the studs are tensioned.
- b. Every 30 minutes when the reactor vessel head flange is $\leq 100^{\circ}\text{F}$ and the studs are tensioned.
- c. Within 30 minutes prior to and every 30 minutes during tensioning of reactor vessel head bolting studs.

2. In-Service Hydrostatic and Leak Tests

During hydrostatic and leak testing the Reactor Coolant System pressure and temperature shall be recorded every 30 minutes until two consecutive temperature readings are within 5°F of each other.

3.6 (cont'd)

- a. $\leq 20^\circ\text{F}$ when to the left of curve C.
- b. $\leq 100^\circ\text{F}$ when on or to the right of curve C.

3. Non-Nuclear Heatup and Cooldown

During heatup by non-nuclear means (mechanical), cooldown following nuclear shutdown and low power physics tests the Reactor Coolant System pressure and temperature shall be on or to the right of the curve B shown in Figure 3.6-1 and the maximum temperature change during any one hour shall be $\leq 100^\circ\text{F}$.

4. Core Critical Operation

During all modes of operation with a critical core (except for low power physics tests) the reactor Coolant System pressure and temperature shall be at or to the right of the curve C shown in Figure 3.6-1 and the maximum temperature change during any one hour shall be $\leq 100^\circ\text{F}$.

5. With any of the limits of 3.6.A.1 through 3.6.A.4 above exceeded, either

- a. restore the temperature and/or pressure to within the limits within 30 minutes, perform an engineering evaluation to determine the effects of the out-of-limit condition on the structural integrity of the reactor coolant system, and determine that the reactor coolant system remains acceptable for continued operations; or

4.6 (cont'd)

3. Non-Nuclear Heatup and Cooldown

During heatup by non-nuclear means, cooldown following nuclear shutdown and low power physics tests, the reactor coolant system pressure and temperature shall be recorded every 30 minutes until two consecutive temperature readings are within 5°F of each other.

4. Core Critical Operation

During all modes of operation with a critical core (except for low power physics tests) the reactor Coolant System pressure and temperature shall be recorded within 30 minutes prior to withdrawal of control rods to bring the reactor critical and every 30 minutes during heatup until two consecutive temperature readings are within 5°F of each other.

- b. be in at least HOT SHUTDOWN within 12 hours and in COLD SHUTDOWN within the following 24 hours.

6. Idle Recirculation Loop Startup

When Reactor Coolant System temperature is $>140^{\circ}\text{F}$ an idle recirculation loop shall not be started unless:

- a. The temperature differential between the reactor coolant system and the reactor vessel bottom head drain line is $\leq 145^{\circ}\text{F}$, and
- b. When both loops are idle, the temperature difference between the reactor coolant system and the idle loop to be started is $\leq 50^{\circ}\text{F}$, or
- c. When only one loop is idle, the temperature difference between the idle loop and the operating loop is $\leq 50^{\circ}\text{F}$.

B. Deleted

6. Idle Recirculation Loop Startup

Within 30 minutes prior to startup of an idle loop:

- a. The differential temperature between the reactor coolant system and the reactor vessel bottom head drain line shall be recorded, and
- b. When both loops are idle, the differential temperature between the reactor coolant system and the idle loop to be started shall be recorded, or
- c. When only one loop is idle, the temperature differential between the idle loop and the operating loop shall be recorded.

7. Reactor Vessel Flux Monitoring

The reactor vessel Flux Monitoring Surveillance Program complies with the intent of the May, 1993 revision to 10 CFR 50, Appendices G and H. The next flux monitoring surveillance capsule shall be removed after 15 effective full power years (EFPy's) and the test procedures and reporting requirements shall meet the requirements of ASTM E 185-82.

B. Deleted

3.6 and 4.6 BASES

A. Pressurization and Thermal Limits

The reactor vessel design specification requires that the reactor vessel be designed for a maximum heatup and cooldown rate of the contained fluid (water) of 100°F/hr averaged over a period of 1 hour. This rate has been chosen based on past experience with operating power plants. The associated time periods for heatup and cooldown cycles when the 100°F/hr rate is applied provide for efficient, but safe, plant operation.

The reactor vessel manufacturer has designed the vessel to the above temperature criterion. In the course of completing the design, the manufacturer performed detailed stress analysis. This analysis includes more severe thermal conditions than those which would be encountered during normal heating and cooling operations.

Specific analyses were made based on a heating and cooling rate of 100°F/hr applied continuously over a temperature range of 100°F to 546°F.

Calculated stresses were within 1965 ASME Boiler and Pressure Vessel Code, Section III, with 1966 addenda stress intensity and fatigue limits. The normal heating and cooling rate of 100°F/hr was also evaluated to assure protection against brittle fracture of the vessel shell remote from discontinuities. The rate meets the requirements of Appendix G to the Summer 1972 Edition of 1971 ASME III, throughout plant life, and is, therefore, satisfactory.

The limiting coolant temperature differential between the upper and lower regions of the reactor vessel, prior to recirculation pump operation, assures that the vessel bottom head

region will not be warmed at an excessive rate due to rapid sweep-out of cold coolant in the vessel lower head region by recirculation pump operation (cold coolant can accumulate as a result of control rod drive inleakage and/or low recirculation flow rate during startup or hot standby). The limit on idle recirculation loop startup avoids high thermal stress effects in the pumps and piping, while also minimizing thermal stresses on the vessel nozzles.

The nil-ductility transition (NDT) temperature RTNDT is defined as the temperature below which ferritic steel breaks in a brittle rather than ductile manner. Reactor vessel flux monitoring samples are installed to conform with the 1972 draft revision of ASTM E 185. Surveillance program test results have established the magnitude of changes in the NDT temperature as a function of the integrated neutron exposure for BWR vessels. The design life of the reactor vessel is 40 years, and the maximum fast neutron exposure at 40 years was originally calculated to be 7.0×10^{17} n/cm². Based on the surveillance program test results, the EOL fluence is now estimated to be 1.7×10^{18} n/cm².

Fast neutron irradiation affects the fracture toughness of the reactor vessel material. In order to assure that non-ductile failure does not occur, two types of information are needed:

- a) a relationship between the change in RTNDT and the accumulated fast neutron fluence, and,
- b) a relationship between the neutron fluence at the point of peak flux in the reactor pressure vessel shell and the effective full power years.

3.6 and 4.6 BASES (cont'd)

The expected neutron fluence at the reactor vessel wall can be determined at any point during plant life based on the linear relationship between the reactor thermal power output and the corresponding number of neutrons produced. Accordingly, neutron flux wires were removed from the reactor vessel with the surveillance specimens to establish the correlation at the capsule location by experimental methods. The flux distribution at the vessel wall and 1/4 thickness (1/4T) depth was analytically determined as a function of core height and azimuth to establish the peak flux location in the vessel and the lead factor of the surveillance specimens.

A method of relating shift in RTNDT to accumulated fast neutron (> 1 MeV) fluence is contained in Regulatory Guide 1.99. Experimental results of the evaluation of the irradiated surveillance specimens taken from the reactor pressure vessel in April, 1985, show a shift in RTNDT greater than predicted by Regulatory Guide 1.99. Therefore, the surveillance results were used with the methods of Regulatory Guide 1.99 to establish the RTNDT shift. The shift for 16 EFPY was added to the unirradiated reactor pressure vessel shell beltline curve.

Operating limits for the reactor vessel pressure and temperature during normal heatup and cooldown, and during in-service hydrostatic and leak testing were established using 10 CFR 50 Appendix G, May, 1983 and Appendix G of the Summer 1984 Addenda to Section III of the ASME Boiler and Pressure Vessel Code. These operating limits assure that the vessel could safely accommodate a postulated surface flaw having a depth of 0.24 inch at the flange-to-vessel

junction, and one-quarter of the material thickness at all other reactor vessel locations and discontinuity regions. For the purpose of setting these operating limits, the reference temperature, RTNDT, of the vessel material was estimated from impact test data taken in accordance with the requirements of the Code to which the vessel was designed and manufactured (1985 Edition including Winter 1966 addenda). The RTNDT values for the reactor vessel flange region and for the reactor vessel shell beltline region are 30°F, based on fabrication test reports. The RTNDT for the remainder of the vessel is 40°F.

The first surveillance capsule containing test specimens was withdrawn in April, 1985 after 6 EFPY. The test specimens removed were tested according to ASTM E 185-82 and the results are in GE report MDE-49-0386. The curves of Figure 3.6-1, A through C, reflect findings in the report related to copper-phosphorus content of the reactor vessel shell beltline, flux wire testing fluence distribution analysis, and Charpy V-Notch specimen testing. The next surveillance capsule will be removed after 15 EFPY of operation and the results of the examination used as a basis for revision of Figure 3.6-1 curves A, B and C for operation of the plant after 16 EFPYs.

Figure 3.6-1 curve A establishes the minimum temperature for hydrostatic and leak testing required by the ASME Boiler and Pressure Vessel Code, Section XI. Test pressures for in-service hydrostatic and leak testing are a function of the testing temperature and the component material. Accordingly, the maximum hydrostatic test pressure will be 1.1 times the operating pressure or about 1105 psig.

3.6 and 4.6 BASES (cont'd)

Figure 3.6-1, curve B, provides limitations for plant heatup and cooldown when the reactor is not critical or during low power physics tests. The thermal limitation is based on maximum heatup and cooldown rates of 100°F/hr in any one-hour period.

Figure 3.6-1, curve C, establishes operating limits when core is critical. These limits include a margin of 40°F as required by 10 CFR 50 Appendix G.

The requirements for cold boltup of the reactor vessel closure are based on NDT temperature plus a 60°F factor of safety. This factor is based on the requirements of the ASME Code to which the vessel was built. For Figure 3.6-1, curves A, B and C, 60°F margins are only added to the low temperature portion of the curve where non-ductile failure is a concern. The closure flanges have an NDT temperature not greater than 30°F and are not subject to any appreciable neutron radiation exposure. Therefore, the minimum temperature of the flanges when the studs are in tension is 30°F plus 60°F, or 90°F.

B. Deleted

C. Coolant Chemistry

A radioactivity concentration limit of 20 ~~4~~ Ci/ml total iodine can be reached if the gaseous effluents are near the limit as set forth in Radiological Effluent Technical Specification 2.3.A if there is a failure or a prolonged shutdown of the cleanup demineralizer.

In the event of a steam line rupture outside the drywell, with this coolant activity level, the resultant radiological dose at the site boundary would be 33 rem to the thyroid, under adverse meteorological conditions assuming no more than 3.14 Ci/gm of dose equivalent I-131. The reactor water sample will be used to assure that the limit of Specification 3.6.C is not exceeded. The total radioactive iodine activity would not be expected to change rapidly over a period of 96 hr. In addition, the trend of the stack offgas release rate, which is continuously monitored, is a good indicator of the trend of the iodine activity in the reactor coolant. Also during reactor startups and large power changes which could affect iodine levels, samples of reactor coolant shall be analyzed to insure iodine concentrations are below allowable levels. Analysis is required whenever the I-131 concentration is within a factor of 100 of its allowable equilibrium value. The necessity for continued sampling following power and offgas transients will be reviewed within 2 years of initial plant startup.

The surveillance requirements 4.6.C.1 may be satisfied by a continuous monitoring system capable of determining the total iodine concentration in the coolant on a real time basis, and annunciating at appropriate concentration levels such that sampling for isotopic analysis can be initiated. The design details of such a system must be submitted for evaluation and accepted by the Commission prior to its implementation and incorporation in these Technical Specifications.




FIGURE 3.6-1
 REACTOR VESSEL PRESSURE - TEMPERATURE LIMITS