



Namco Controls
7567 Tyler Boulevard
Mentor, Ohio 44060
(216) 946-9900
Telex 24-1566

October 29, 1987

United States
Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Ellis W. Merschoff, Chief
Vendor Inspection Branch

Subject: Docket #99900378/87-01

Gentlemen:

This is in response to your letter of October 1, 1987.

Enclosed is a copy of a memorandum dated October 21, 1987 from David Jackson, III, Chief Engineer, Newton Products, on this subject. This memo indicates corrective action being taken, which we trust will be satisfactory to the Commission.

Thank you for your cooperation in this matter.

Very truly yours,

N. E. Swanson
President

NES:ami
Enc.

cc: B. E. Kovarik
E. L. Laskowski
D. Jackson, III
B. Pettrey

8711060297 871029
PDR GA999 EMVNAMCO
99900378 PDR

11
I E.09

DATE: 10-21-87

TO: E. Laskowski VP ENG.
FROM: D.Jackson III CH. ENG.
SUBJECT: RESPONSE TO THE NRC 1987 AUDIT (99900378/87-01)


In accordance with our N.S.P. requirement I am forwarding my Engineering Department response to the two NRC audit findings.

FINDINGS

The first finding was failure to hold the yearly indoctrination seminar. This seminar will be held on October 26, 1987. To prevent recurrence this item will be reviewed on our yearly audit checklist.

The second finding was for having one calibration tag improperly marked with the same date for the date calibrated as for next due date for calibration. The calibration file card was then reviewed by the auditor and was found to be correct. The calibration tag was then corrected that same day. No other occurrences were noted. It is our opinion that this was an anomaly, and no further action is required.

Both the above findings are considered closed by my Engineering Department.



David Jackson III
Chief Engineer-Newton Products

pc: NUC FILE
B.Kovarik G.M.
J.Bendokaitis N.P.C.
B. Pettrey Q.A.