

OPERATING DATA REPORT

Report Number: 160

DOCKET NO.: 50-482
 UNIT NAME: Wolf Creek Generating Station
 DATE: July 2, 1998
 COMPLETED BY: K. A. Harris
 TELEPHONE: 316-364-8831 X4566

REPORT MONTH: June, 1998

1.	Design Electrical Rating (MWe - Net):	1170
2.	Maximum Dependable Capacity (MWe - Net):	1163

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	720.0	4,343.0	93,438.1
4.	Number of Hours Generator On-Line:	720.0	4,343.0	92,458.0
5.	Unit Reserve Shutdown Hours:	0.0	0.0	339.8
6.	Net Electrical Energy Generated (MWH)	850,134	5,170,290	103,242,464

Wolf Creek Generating Station
 Monthly Operating Report
 June, 1998
 Page 1 of 2

9807160273 980710
 PDR ADOCK 05000482
 R PDR

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO.: 50-482
 UNIT NAME: Wolf Creek Generating Station
 DATE: July 2, 1998
 COMPLETED BY: K. A. Harris
 TELEPHONE: 316-364-8831 X4566

No	Date	Type E: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

SUMMARY: The unit operated at or near 100% power, Mode 1, from June 1 through June 30, 1998.

- 1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUATION
 5. OTHER