



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

DOCKET NO. 50-339

NORTH ANNA POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 81
License No. NPF-7

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company, et al., (the licensee) dated July 30, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-7 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 81, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Lester S. Rubenstein, Director
Project Directorate II-2
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 6, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 81

TO FACILITY OPERATING LICENSE NO. NPF-7

DOCKET NO. 50-339

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page as indicated. The revised page is identified by amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

Remove Page

3/4 7-12

Insert Page

3/4 7-12

PLANT SYSTEMS

STEAM TURBINE ASSEMBLY

LIMITING CONDITION FOR OPERATION

3.7.1.6 The structural integrity of the steam turbine assembly shall be maintained.

APPLICABILITY: MODES 1 and 2

ACTION: With the structural integrity of the steam turbine assembly not conforming to the above requirement restore the structural integrity of the steam turbine prior to placing it in service.

SURVEILLANCE REQUIREMENTS

4.7.1.6 The structural integrity of the steam turbine assembly shall be demonstrated;

- a. At least once per 40 months, during shutdown, by a visual and surface inspection of the steam turbine assembly at all accessible locations, and
- b. At least once per 10 years, during shutdown, by disassembly of the turbine and performing a visual, surface and volumetric inspection of all normally inaccessible parts.