



Log # TXX-6982
File # 10110
907.6
Ref. # 10CFR50.55(e)

William G. Council
Executive Vice President

November 18, 1987

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
BOP SAFETY-RELATED INSTRUMENT SETPOINTS
SDAR: CP-86-81 (INTERIM REPORT)

Gentlemen:

On November 7, 1986, we verbally notified your Mr. T. Westerman of a potentially reportable item involving the calculations for BOP safety-related instrument setpoints, indicating that omissions of required data or use of incorrect information occurred in performing the calculations required per Regulatory Guide 1.105, Rev. 2. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e). Our latest interim report was logged TXX-6758, dated September 18, 1987.

We are continuing our evaluation of this issue and will submit our next report no later than February 18, 1988.

Very truly yours,

W. G. Council

W. G. Council

By: *J. S. Marshall*

J. S. Marshall
Supervisor,
Generic Licensing

RDD/grr

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8711240026 871118
PDR ADDCK 05000445
S PDR

*IE27
/0*