



Point Beach Nuclear Plant  
6610 Nuclear Rd., Two Rivers, WI 54241

(920) 755-2321

NPL 98-0608

July 17, 1998

10 CFR 50.73

Document Control Desk  
U.S. NUCLEAR REGULATORY COMMISSION  
Mail Station P1-137  
Washington, DC 20555

Ladies/Gentlemen:

DOCKET 50-266  
SUPPLEMENTAL LICENSEE EVENT REPORT 1998-015-01  
CONTAINMENT FAN COOLER TEST RESULTS OUTSIDE  
ACCEPTANCE CRITERIA  
POINT BEACH NUCLEAR PLANT, UNIT 1

Enclosed is supplemental Licensee Event Report 1998-015-01 for Point Beach Nuclear Plant, Unit 1. The original LER was provided on May 20, 1998, in accordance with 10 CFR 50.73(a)(2)(ii), an "event or condition that resulted... in the nuclear power plant being in a condition that was outside the design basis of the plant." That report described the discovery, while reviewing the calculations for the Unit 1 "D" Containment Fan Cooler heat removal capacity testing, that application of the calculated testing uncertainty to the nominal test results resulted in the failure of the fan cooler to meet the heat removal acceptance criteria. This supplement to LER 266/1998-015-00 provides additional information concerning the corrective actions taken to restore the operability of the Unit 1 containment fan coolers. The additional information is provided in a supplemental section added to the end of the report. All changes or additions to the original report have been identified with margin bars.

No new commitments were added in this supplement. Commitments within the original report are indicated in italics.

Please contact us if you require additional information.

Sincerely,

A handwritten signature in black ink, appearing to read 'Vito A. Kaminskas'.

Vito A. Kaminskas  
Manager,  
Regulatory Services & Licensing

Enclosure

cc: NRC Resident Inspector  
NRC Regional Administrator  
NRC Project Manager

INPO Support Services  
PSCW

9807270374 980717  
PDR ADOCK 05000266  
S PDR