ENCLOSURE 1

NOTICE OF VIOLATION

Public Service Electric and Gas Company Hope Creek Generating Station

Docket No: 50-354 License No: NPF-57

During an NRC inspection conducted between May 17, 1998, through June 27, 1998, violations of NRC requirements were identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," NUREG-1600, Revision 1, the violations are listed below:

A. Technical Specification 6.8.1 requires, in part, that written procedures shall be established, implemented, and maintained for applicable activities recommended in Appendix A of NRC Regulatory Guide 1.33, Revision 2, February 1978.

Appendix A of NRC Regulatory Guide 1.33, Revision 2, February 1978 (Section 10) recommends that chemical control procedures be written to prescribe the nature and frequency of sampling and analyses.

Hope Creek chemistry procedure HC.CH-AP.ZZ-0014(Q), Hope Creek Generating Station Diesel Fuel Oil Testing Program, Revision 2, Section 5.1, requires that all diesel fuel oil deliveries (via tank truck) will be sampled and analyzed for particulates, and results reported by written notification within 14 days of sample receipt to the Hope Creek System Manager and the Fuel Oil Program Manager.

Contrary to the above, as of October 1997, chemistry technicians did not sample and analyze diesel fuel oil deliveries for particulates, and did not report results by written notification within 14 days of sample receipt to the Hope Creek System Manager and the Fuel Oil Program Manager.

This is a Severity Level IV violation (Supplement I).

B. 10 CFR Part 50, Appendix B, Criterion III (Design Control), requires, in part, that measures shall be established to assure that applicable regulatory requirements and the design bases are correctly translated into specifications, drawings, procedures, and instructions. The design control measures shall provide for verifying or checking the adequacy of design, such as by the performance of design reviews, by the use of alternate or simplified calculational methods, or by the performance of a suitable testing program.

Contrary to the above, during the RFO7 refueling outage (Fall - Winter 1997), design change package (DCP) 4EC-3638 incorrectly changed the design basis of the reactor core isolation cooling (RCIC) system by removing a timing sequence feature for the RCIC turbine steam line stop valve (F045). In addition, a design review of DCP 4EC-3638 and post-modification testing for DCP 4EC-3638 failed to identify the design error.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Public Service Electric and Gas Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region I, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation or severity level, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Your response may reference or include previous docketed correspondence, if the correspondence adequately addresses the required response. If an adequate reply is not received within the time specified in this Notice, an order or a Demand for Information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

If you contest this enforcement action, you should also provide a copy of your response to the Director, Office of Enforcement, United States Nuclear Regulatory Commission, Washington, DC 20555-0001.

Because your response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information so that it can be placed in the PDR without redaction. If personal privacy or proprietary information is necessary to provide an acceptable response, then please provide a bracketed copy of your response that identifies the information that should be protected and a redacted copy of your response that deletes such information. If you request withholding of such material, you <u>must</u> specifically identify the portions of your response that you seek to have withheld and provide in detail the bases for your claim of withholding (e.g., explain why the disclosure of information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.790(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21.

Dated at King of Prussia, Pennsylvania this 21st day of July 1998 Distribution w/encls: Region I Docket Room (with concurrences) Nuclear Safety Information Center (NSIC) NRC Resident Inspector PUBLIC

- H. Miller, RA/W. Axelson, DRA
- D. Screnci, PAO (1)
- J. Linville, DRP
- S. Barber, DRP
- L. Harrison, DRP
- C. O'Daniell, DRP

Distribution w/encls: (Via E-Mail)

- B. McCabe, OEDO
- R. Ennis, Project Manager, NRR
- R. Capra, PDI-2, NRR

Inspection Program Branch, NRR (IPAS)

- R. Correia, NRR
- D. Talbot, NRR

DOCDESK

DOCUMENT NAME: G:\BRANCH3\1-HC\IR9806.HC

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP	RI/DRP			
NAME	Pindale/meo	Linville			
DATE	07/21/98	07/2//98/	07/ /98	07/ /98	07/ /98

OFFICIAL RECORD COPY