



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ P. O. Box 15830, Sacramento CA 95852-1830, (916) 452-3211
AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

GCA 87-749

NOV 24 1987

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Docket No. 50-312
Rancho Seco Nuclear Generating Station
License No. DPR-54
LICENSEE EVENT REPORT 87-031, REVISION 1: TECHNICAL SPECIFICATION REQUIRED
VISUAL INSPECTIONS NOT DONE ON THE HYDROGEN PURGE SYSTEM

Dear Sirs:

In the previous submittal of LER 87-031, the Sacramento Municipal Utility District committed to supplementing the LER. This revision states that Technical Specification Proposed Amendment No. 158 will provide controls for the Hydrogen Recombiner System. In addition, Surveillance Procedures SP.45A and SP.45B will replace procedure SP.201.08.

Please contact me if you have any questions. Members of your staff with questions requiring additional information or clarification may contact Mr. Paul Lavelly at (916) 452-3211, extension 4674.

Sincerely,

G. Carl Andognini
Chief Executive Officer,
Nuclear

Attachment

cc w/atch:

G. Kalman, NRC, Bethesda (2)
A. D'Angelo, NRC, Rancho Seco
J. B. Martin (2)
INPO

8712010406 871124
PDR ADDCK 05000312
S PDR

IE22
1/1