



**PECO NUCLEAR**

A Unit of PECO Energy

**Michael P. Gallagher, P.E.**  
Plant Manager  
Limerick Generating Station

PECO Energy Company  
Limerick Generating Station  
PO Box 2300  
Sanatoga, PA 19464-0920  
610 718 2000

10CFR50.73

July 22, 1998  
Docket No. 50-353  
License No. NPF-85

U.S. Nuclear Regulatory Commission  
Attn.: Document Control Desk  
Washington, DC 20555

SUBJECT: Licensee Event Report  
Limerick Generating Station - Unit 2

This LER reports a condition prohibited by Technical Specifications (TS) in that the Main Condenser Offgas Pre-Treatment Radioactivity Monitor skid was inoperable and the applicable TS Action had not been met. This event resulted from an incorrect procedure.

Reference: Docket No. 50-353  
Report Number: 2-98-003  
Revision Number: 00  
Event Date: June 22, 1998  
Report Date: July 22, 1998  
Facility: Limerick Generating Station  
P.O. Box 2300, Sanatoga, PA 19464

This LER is being submitted pursuant to the requirements of 10CFR50.73(a)(2)(i)(B).

Very truly yours,

DMS

cc: H. J. Miller, Administrator Region I, USNRC  
A. L. Burritt, USNRC Senior Resident Inspector, LGS

9807280348 980722  
PDR ADOCK 05000353  
S PDR