



EG&G ENERGY MEASUREMENTS GROUP

San Ramon Operations

2801 OLD CROW CANYON ROAD, SAN RAMON, CA • TEL (415) 837-5381 • MAIL BOX 204, SAN RAMON, CA 94583

In reply please refer to: WOW: 84-06

5 December 1983

Mr. Dennis Kirsh
U. S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Subject: INSPECTION STATUS REPORT
Reference: Memo; D. Kirsh to W. Wade dated 30 November 1983

This report provides the information requested in the reference memo. Attachment 1 tabulates the information by category with the exception of concrete expansion - anchor bolt data which is not available. Anchor bolts were inspected against the appropriate Foley or Pullman specifications (QCP9, QCPE9, and ESD 223) when they were used for the installation.

Aside from population data, the information was derived from records maintained for the inspections conducted under FIN B-8552. The inspections were conducted between July and November 1983 and some are incomplete. As a consequence, a description of the discrepancy and an assessment of the significance is provided only for completed inspections.

Attachment 2 illustrates the information stored in the data file for this project. The computer was asked to list all completed inspection items having a discrepancy for which a quality assurance (QA) report and/or a citation has been initiated. Incomplete inspection items for which QA reports have been initiated were also added since these reports provide the descriptive information needed to assess significance.

If further explanation or additional information is required please contact me at my office in San Ramon.

W. O. WADE
MECHANICAL ENGINEERING DEPARTMENT

WOW:cog 8712020285 871123
PDR FOIA
GARDEB4-21 PDR

Distribution:

LLNL
G. Cummings
M. Eli
R. Bogdanowicz

EG&G/SRO
R. Pong
A. Debeling
C. Morton

NRC
T. Bishop
P. Narbut
P. Morrill

M-12

ATTACHMENT I

SUMMARY of DIABLO CANYON INSPECTION * of '82 MODIFICATIONS FROM ^{the}INDEPENDENT DESIGN VERIFICATION PROGRAM

DEC. 5, 1983

CATEGORY	NUMBER OF ITEMS INSPECTED	NUMBER OF DISCREPANC. (INSPECTION COMPLETED)	NUMBER OF DISCREPANC. (INSPECTION INCOMPLETE)	NUMBER OF NON-DISCREP. (INSPECTION COMPLETED)	NUMBER OF MODIFIED SAFETY - RELATED ITEMS IN POPULATION	NUMBER OF SAFETY - RELATED ITEMS IN POPULATION	DISCREPANCY	SIGNIFICANT
ELECTRICAL RACEWAY SUPPORT	124	16	17	91	2200	26,601	• E0019 - ANCHOR BOLT ALIGNMENT	N
							• E0020 - AS-BUILT LOCAT. DIMENSION	N
							• E0022 - CITATION - THRU-BOLT	Y
							• E0026 - LOOSE ANCHOR NUT	N
							• E0027 - LOOSE SPRING NUTS	N
							• E0028 - LOOSE SPRING NUTS	N
							• E0032 - LOOSE SPRING NUT	N
							• E0033 - LOOSE ANCHOR NUT	N
							• E0039 - LOOSE CONDUIT CLAMP	N
							• E0043 - WRONG SIZE CHANNEL IRON	N
							• E0044 - THREAD ENGAG. AS-BUILT DIMENSIONS	N

* INSPECTION TEAM FROM LAWRENCE LIVERMORE NATIONAL LABORATORY.

SUMMARY of DIABLO CANYON INSPECTION *

DEC. 5, 1983

of '82 MODIFICATIONS FROM ^{the} INDEPENDENT DESIGN VERIFICATION PROGRAM

CATEGORY	NUMBER OF ITEMS INSPECTED	NUMBER OF DISCREPANC. (INSPECTION COMPLETED)	NUMBER OF DISCREPANC. (INSPECTION INCOMPLETE)	NUMBER OF NON-DISCREP. (INSPECTION COMPLETED)	NUMBER OF MODIFIED SAFETY-RELATED ITEMS IN POPULATION	NUMBER OF SAFETY-RELATED ITEMS IN POPULATION	DISCREPANCY	SIGNIFICANT
ELECTRICAL ACEWAY SUPPORTS (cont'd)							• E0075 - LOOSE SPRING NUT.	N
							• E0077 - LOOSE SPRING NUTS.	N
							• E0078 - LOOSE SPRING NUT.	N
							• E100Z - MISSING UNISTRUT BOLTS.	N
							• E1014 - USED WRONG FASTENERS.	N
ANCHOR BOLTS								

DEC. 5, 1983

SUMMARY of DIABLO CANYON INSPECTION *
of '82 MODIFICATIONS FROM ^{the} INDEPENDENT DESIGN VERIFICATION PROGRAM

ATEGORY	NUMBER OF ITEMS INSPECTED	NUMBER OF DISCREPANC. (INSPECTION COMPLETED)	NUMBER OF DISCREPANC. (INSPECTION INCOMPLETE)	NUMBER OF NON-DISCREP. (INSPECTION COMPLETED)	NUMBER OF MODIFIED SAFETY-RELATED ITEMS IN POPULATION	NUMBER OF SAFETY-RELATED ITEMS IN POPULATION	DISCREPANCY	SIGNIFICANT
MAJOR BOLTS	-	-	-	-	-	-	M0261 - IMPROPER WELD.	N
MAJOR RESERVANTS	11	0	3	8	22	332	-	
MAJOR BOLTS	-	-	-	-	-	-	-	
MAJOR SUPPORTS	14	3	1	10	604	1124	M0330 - WELD LOCATION.	N
							M0331 - PROTECTIVE PAINT.	N
							M0344 - THREAD ENGAGEMENT	N
MAJOR BOLTS	-	-	-	-	-	-	-	

SUMMARY of DIABLO CANYON INSPECTION *

DEC. 5, 1983

of '82 MODIFICATIONS FROM ^{the} INDEPENDENT DESIGN VERIFICATION PROGRAM

CATEGORY	NUMBER OF ITEMS INSPECTED	NUMBER OF DISCREPANCY (INSPECTION COMPLETED)	NUMBER OF DISCREPANCY (INSPECTION INCOMPLETE)	NUMBER OF NON-DISCREP. (INSPECTION COMPLETED)	NUMBER OF MODIFIED SAFETY-RELATED ITEMS IN POPULATION	NUMBER OF SAFETY-RELATED ITEMS IN POPULATION	DISCREPANCY	REMARKS
PIPE SUPPORTS	280	11	6	263	4969	7114	<p>M0023 - AS BUILT ORIENTATION. N</p> <p>M0025 - LOOSE ANCHOR. N</p> <p>M0029 - TURN BUCKLE LOCKNUTS MISSING. Y</p> <p>M0047 - NO U-BOLT LOCKNUTS. N</p> <p>M0085 - WELD PASS SEPARATION - ANCHOR BOLT ALIGNMENT. N</p> <p>M0087 - MISSING WELD. N</p> <p>M0088 - UNDER SIZE WELD. N</p> <p>M0138 - STRUT ALIGNMENT. N</p> <p>M0163 - MISPLACED WELD. N</p> <p>M0200 - STRUT ALIGNMENT. N</p>	

SUMMARY of DIABLO CANYON INSPECTION * of '82 MODIFICATIONS FROM ^{the} INDEPENDENT DESIGN VERIFICATION PROGRAM

DEC. 5, 1983

CATEGORY	NUMBER OF ITEMS INSPECTED	NUMBER OF DISCREPANC. (INSPECTION COMPLETED)	NUMBER OF DISCREPANC. (INSPECTION INCOMPLETE)	NUMBER OF NON-DISCREP. (INSPECTION COMPLETED)	NUMBER OF MODIFIED SAFETY-RELATED ITEMS IN POPULATION	NUMBER OF SAFETY-RELATED ITEMS IN POPULATION	DISCREPANCY	SIGNIFICANT
STRUCTURAL MEMBERS	58	6	4	48	2130	—	S0003 - WALL FIGHT GAP - SPALLED CONCRETE AT ANCHORS. S0046 - ANCHOR BOLT ALIGNMENT. S0049 - INSUFF. WELD LENGTH. S0061 - WELD REINFORCEMENT. S0062 - WELD REINFORCEMENT S0063 - LACK OF FUSION, SLAG INCLUSION, STITCHED WELD SPACING, BASE METAL DAMAGE.	N N N N N N Y
ANCHOR BOLTS	—	—	—	—	—	—	—	—

* INSPECTION TEAM FROM LAWRENCE LIVERMORE NATIONAL LABORATORY.

ATTACHMENT II

LOG NUM	LOC	U N I T	ITEM	PART NUMBER	START DATE	COMPLETE DATE	CRIT	CONTACTS	AFF	STATUS	STATUS DATE	INSF	MAN HRS
E0019 AUX BLDG		1	RACEWAY SUPPORT	14/CSR-127-3480	7/13/83	10/19/83	QCP 3 QCP 5A QCP 9 QCP E9	MONTEROLA CAMPBELL MORRISON	BE FO P6	PHYSICAL MVR-E2625 ACCEPTED	9/23/83 9/23/83 10/19/83	MWE	8.0 7.0
E0020 AUX BLDG		1	RACEWAY SUPPORT	10/CSR1274328	7/13/83	10/31/83	QCP 3 QCP 5A QCP 9 QCP E9	MONTEROLA CAMPBELL MORRISON	BE FO P6	RECORDS MVR-E2625 ACC-W/O-QA	9/23/83 9/23/83 10/31/83	MWE	8.0 5.0
E0022 AUX BLDG		1	RACEWAY SUPPORT	12/H-115-6-105	7/13/83	8/29/83	QCP 3 QCP 5A QCP 9 QCP E9	MONTEROLA CAMPBELL HERNANDEZ	BE FO NR	CITATION MVR-E2618 ACCEPTED	8/20/83 8/20/83 8/29/83	MWE	2.0 5.0
E0026 AUX BLDG		1	RACEWAY SUPPORT	K-154-1-112	8/05/83	10/15/83	QCP 3 QCP 5A QCP 9 QCP E9	MONTEROLA CAMPBELL MORRISON	BE FO P6	PHYSICAL MVR-E2653 ACC-W/O-QA	9/15/83 9/15/83 10/15/83	MWE	5.0 8.0
E0027 AUX BLDG		1	RACEWAY SUPPORT	9/K-140-4-140	8/05/83	10/15/83	QCP 3 QCP 5A QCP 9 QCP E9	MONTEROLA CAMPBELL MORRISON	BE FO P6	PHYSICAL MVR-E2653 ACC-W/O-QA	9/15/83 9/15/83 10/15/83	MWE	5.0 7.0
E0028 AUX BLDG		1	RACEWAY SUPPORT	9/K-140-4-136	8/05/83	10/15/83	QCP 3 QCP 5A QCP 9 QCP E9	MONTEROLA CAMPBELL MORRISON	BE FO P6	PHYSICAL MVR-E2653 ACC-W/O-QA	9/15/83 9/15/83 10/15/83	MWE	5.0 8.0
E0032 CONTAINMENT		1	RACEWAY SUPPORT	246-140-8-E3008	10/15/83		QCP 3 QCP 5A QCP 9 QCP E9	MORRISON CAMPBELL	P6 FO	PHYSICAL MVR-E-2698 ACC-W/O-QA	10/20/83 10/20/83 10/15/83	MWE	5.0 8.0
E0033 CONTAINMENT		1	RACEWAY SUPPORT	10/F-140-5-965	10/15/83		QCP 3 QCP 5A QCP 9 QCP E9	MORRISON CAMPBELL	P6 FO	PHYSICAL MVR-E-2699 ACC-W/O-QA	10/20/83 10/20/83 10/31/83	MWE	3.0 2.0
E0039 PENETRAT BLDG		1	RACEWAY SUPPORT	146EW1151313	10/18/83	10/31/83	QCP 3 QCP 5A QCP 9 QCP E9	MORRISON CAMPBELL	P6 FO	PHYSICAL MVR-E-2703 ACC-W/O-QA	10/20/83 10/20/83 10/31/83	MWE	7.0 6.0
E0043 TURBINE BLDG		1	RACEWAY SUPPORT	11/C-104-B-10	10/19/83	11/17/83	QCP 3 QCP 5A QCP 9 QCP E9	MORRISON CAMPBELL	P6 FO	PHYSICAL RECORDS	10/19/83 10/19/83	RMB MWE	7.0 6.0

Item ID	Description	Location	Date	Time	Person	Activity	Notes	Time
E0044	TURBINE BLDG	1 RACEWAY SUPPORT 15/A-119-3-44	10/19/83	11/15/83	QCP 3 QCP 5A QCP 9 QCP E9	MORRISON CAMPBELL	P6 FD	MVR E-2705 10/31/83 ACC-W/O-QA 11/17/83 RMB 1.0
								DIMENSION 10/19/83 RMB 7.0 RECORDS 10/19/83 MWE 6.0 MVR E-2704 10/31/83 MVR E-2706 10/31/83 ACC-W/O-QA 11/15/83 RMB 1.0
E0075	TURBINE BLDG	1 RACEWAY SUPPORT 45/A-119-5-48	10/26/83	11/01/83	QCP 3 QCP 9 QCP E9	MORRISON HELLO	P6 FD	RECORDS 10/26/83 RMB 1.0 PHYSICAL 10/26/83 MVR-E-2711 10/26/83 ACC-W/O-QA 11/01/83 RMB 1.0
E0077	TURBINE BLDG	1 RACEWAY SUPPORT 50/A-107-7-88	10/27/83	11/02/83	QCP 3 QCP 5A QCP 9 QCP E9	MORRISON HELLO	P6 FD	RECORDS 10/27/83 RMB 1.0 PHYSICAL 10/27/83 MVR-E-2713 10/27/83 ACC-W/O-QA 11/02/83 RMB 1.0
E0078	TURBINE BLDG	1 RACEWAY SUPPORT 50/A-119-2-15	10/27/83	11/02/83	QCP 3 QCP 5A QCP 9 QCP E9	MORRISON HELLO	P6 FD	RECORDS 10/27/83 RMB 1.0 PHYSICAL 10/27/83 MVR-E-2714 10/27/83 ACC-W/O-QA 11/02/83 RMB 1.0
E1002	AUX BLDG	1 RACEWAY SUPPORT CSR-127-4-56	11/08/83	11/17/83	QCP E9	CAMPBELL	FD	MVR-E-2729 11/17/83 RP 3.0
E1014	CONTAINMENT	1 RACEWAY SUPPORT H-85-1-42	11/08/83	11/17/83	QCP E9	MORRISON CAMPBELL	P6 FD	MVR-E-2729 11/17/83 RP 3.0
M0023	CONTAINMENT	1 PIPE HANGER 12-196SL	7/07/83	10/12/83	ESD 223	TINKLE GAUDIUSO	P6 P6	RECORDS 9/02/83 MWE 8.0 MVR-M-4542 9/02/83 MWE 6.0 ACCEPTED 10/12/83
*M0025 (see next page)								
M0029	N/A	1 PIPE HANGER 46-9V	7/11/83	7/11/83	ESD 223	HOWELL TINKLE	BE P6	CITATION 7/11/83 AGD 1.0 RP 1.0
M0047	N/A	1 PIPE HANGER 22-396SL	7/13/83	7/13/83	ESD 223	TINKLE HOWELL	P6 BE	DR-5184 7/13/83 AGD 2.0 RP 1.0
M0085	AUX BLDG	1 PIPE HANGER 555-172R	7/19/83	9/02/83	ESD 223	TINKLE GIACOLONI GAUDIUSO	P6 BE P6	PHYSICAL 8/20/83 WELD 8/20/83 MWE 5.0 MVR-M4511 8/20/83 MWE 1.0 ACCEPTED 9/02/83
M0087	CONTAINMENT	1 PIPE HANGER 57N-38R	7/20/83	9/02/83	ESD 223	GAUDIUSO TINKLE HOWELL	P6 P6 BE	WELD 8/20/83 MWE 5.0 RECORDS 8/20/83 MVR-M4511 8/20/83 ACCEPTED 9/02/83 MWE 1.0
M0088	CONTAINMENT	1 PIPE HANGER 57N-28V	7/20/83	9/02/83	ESD 223	TINKLE GIACOLONI GAUDIUSO	P6 BE P6	WELD 8/20/83 MWE 5.0 MVR-M4511 8/20/83 ACCEPTED 9/02/83 MWE 1.0
*M0138 (see next page)								
M0160		1 PIPE HANGER 73-39R	8/09/83	9/15/83	ESD 223	TINKLE GADICO DOLE	P6 P6 P6	MVR M-4533 9/15/83 RGS 1.0 CHM 1.0
M0200		1 PIPE HANGER 92-103R	8/17/83	9/15/83	ESD 223	TINKLE GADICO DOLE	P6 P6 P6	DR 5144 9/15/83 EWR 1.0 CHM 3.0
M0261	N/A	1 PIPE HANGER 22-547SL	8/24/83	8/24/83	ESD 223	TINKLE LORTIE	P6 BE	MVR 4542 8/24/83 AGD 1.0
M0330		1 HVAC SUPPORT SKC-HV570	8/11/83	9/20/83	QCP 40	BERESTEDT O'CONNOR	FD P6	IR8827-71 9/20/83 RGS 1.0 CHM 3.0

M0331	1 HVAC SUPPORT	SKC-HV568	8/11/83	9/20/83	QCP 40	BERGSTEDT D'CONNOR	FO PG	IR8827-71	9/20/83	R6S CHM	1.0 3.0	
M0344	1 HVAC SUPPORT	SKC-HV367	8/11/83		QCP 40	NOVACK CARLSON BERGSTEDT	FO FO FO	IR8827-73	9/20/83	R6S CHM	1.0 2.0	
S0003	CONTAINMENT	1 ANNULUS	6181-C1-13-610	7/14/83	QCP 3 QCP 5A QCP C7 QCP 9	KOHLER KITCHEN BERG	BE PG FO	PHYSICAL QA NCR5422272	9/15/83 9/15/83 9/15/83	MWE	5.0	
S0046	N/A	1 SWITCH GEAR	6422-T1-13-871	8/25/83	8/31/83	QCP 3	PALARMO	PG	NCR	8/31/83	AGD	1.0
S0049	N/A	1 SWITCH GEAR	6422-T1-13-874	8/25/83	8/31/83	QCP 3	PALARMO	PG	NCR 5422-255	8/31/83 8/31/83	AGD	1.0
S0061	FUEL HANDLING	1 FUEL HANDLING	6180-F1-13-026-016	9/22/83	10/20/83	QCP 3 QCP 5A QCP C7	KOHLER TINGLEY CANNING MUNRO	BE FO FO BE	WELD NCR-8833 ACC-W/O-QA	10/14/83 10/14/83 10/20/83	MWE	3.0 2.0
S0062	FUEL HANDLING	1 FUEL HANDLINE	6180-F1-13-026-116	9/22/83	10/20/83	QCP 3 QCP 5A QCP C7	KOHLER TINGLEY CANNING MUNRO	BE FO FO BE	WELD NCR-8833 ACC-W/O-QA	10/14/83 10/20/83	MWE	3.0 2.0
S0063	TURBINE BLDG	1 TURBINE BLDG	6424-T1-13-794	11/01/83	QCP 3 QCP 5A QCP C7 QCP 9	KOHLER HARRISON BERG MARTINSON KIRSCH	BE BE FO FO NR	WELD NCR 5422-332 NCR 5422-333 NCR 5422-341 NCR 5422-351 CITATION	11/01/83 11/03/83 11/03/83 11/03/83 11/03/83 11/03/83 11/10/83 11/10/83 11/18/83	MWE RMB MWE MWE MWE MWE MWE MWE	16.0 10.0 10.0	
M0025	AUX BLDG	1 PIPE HANGER	855-66R	7/07/83	9/15/83	ESD 223	TINKLE SMITH BAUDIUSO	PG BE PG	PHYSICAL	9/02/83	MWE MWE	
									MVR-4503 ACCEPTED	9/02/83 9/15/83		
M0138	TURBINE BLDG	1 PIPE HANGER	384-393R	8/02/83	9/15/83	ESD 223	TINKLE HOWELL	PG BE	PHYSICAL DR-5144 ACCEPTED	9/02/83 9/02/83 9/15/83	MWE MWE MWE	

RECEIVING OFFICE

1. Facility(ies) Involved:

(If more than 3, or if generic, write GENERIC)

(Name)

DIABLO CANYON
UNITS 1 AND 2

Docket Number (If applicable)

5	0	3	7	5
5	0	3	7	5

2. Functional Area(s) Involved:

(Check appropriate box(es))

X

operations
construction
safeguards
other (Specify) _____

onsite health and safety
offsite health and safety
emergency preparedness

3. Description:

(Limit to 100 characters)

A	L	L	E	R	F	E	L	I	E	S	M	C	K	S	A	R	E				
R	E	I	N	G	R	E	J	E	C	T	E	D	W	I	T	H	O	U	T	A	N
E	G	L	A	T	E	I	N	J	U	S	T	I	F	I	C	A	T	I	O	N	

4. Source of Allegation:

(Check appropriate box)

X

contractor employee
licensee employee
NRC employee
organization (Specify) _____
other (Specify) _____

security guard
news media
private citizen

5. Date Allegation Received:

MM	DD	YY
0	8	11
		82

6. Name of Individual Receiving Allegation:

(First two initials and last name)

T. W. BISHOP / P. J. MCKINLEY

7. Office:

R	S		
---	---	--	--

ACTION OFFICE

8. Action Office Contact:

(First two initials and last name)

D. F. KIRSCHE

9. FTS Telephone Number:

4	6	3	-	3	7	2	3
---	---	---	---	---	---	---	---

10. Status:

(Check one)

Open, if followup actions are pending or in progress
Closed, if followup actions are completed

11. Date Closed:

MM	DD	YY

12. Remarks:

(Limit to 50 characters)

12.1 Man-hours/Date

13. Allegation Number:

Office	Year	Number
R	V	-
8	3	-
A	-	0
0	0	2
0	2	0

THE HOWARD P. FOLEY COMPANY

NONCONFORMANCE REPORT

Day Shift

ORIGINAL

Page 1 of 1

NUMBER:

8802-861

DESCRIPTION:

WELDERS AND WELD PROCEDURES QUALIFIED TO WRONG
AWS CODE

ATTACHMENTS

Yes ☐ No ☒

DATE:

6-13-83

HOLD TAG # N/A
REMOVED

REF. HPF/IR NUMBER: N/A

BY _____ DATE _____

UNIT I ☒ UNIT II ☒ /LOCATIONCLASS I ☒ NON-CLASS I ☐INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☒ PROCEDURE ☒DOCUMENT TITLE AND NUMBER: Spec. 8802 6.1
QCP-5A AWS D1.1-82 Par. 1.2.2

DESCRIPTION OF NONCONFORMANCE: (Including Cause)

Specification 8802, Paragraph 6.1 states, H.P.F. is required to comply with the "Code for Arc & Gas Welding in Building Construction, published by AWS".

H.P.F. QCP-5A Revision 9 requires welder qualifications and production welding to be in compliance with AWS D1.1-82. D1.1-82, Paragraph 1.2.2 specifies a minimum base metal thickness of 1/8" and states that AWS D1.3 should apply to base metals less than 1/8". Contrary to this requirement, H.P.F.'s Welder and Procedure Qualification and Production Welding in the Electrical support work has been performed in accordance with AWS D1.1 instead of D1.3.

INITIATED BY

DATE

Q.C. SUPERVISOR REVIEW

DATE

DISPOSITION:

Revise QCP-5 and QCP-5A to call out D.1.1 - 75 for electrical welding Spec 8802, as per attached letter from PG&E (June 14, 1983).

Previous work was accomplished as per the attached procedures. Accept as is.
Procedure qualifications was performed and is acceptable.

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.G. & E. CO.

DATE

DISPOSITION ACCOMPLISHED

QCP 5 REVISED REF. PCN#5
QCP 5A REVISED REF. PCN#8

PREVIOUS WORK "ACCEPTED AS IS" PER ABOVE STATED DISPOSITION

VERIFIED BY

DATE

Q.C. SUPERVISOR

DATE

FOR INFORMATION ONLY

Close to File (date)

FOIA-84-21

N-1 1.

ORIGINAL

NONCONFORMANCE REPORT

FORM 2-871 Rev. 8/82

DESCRIPTION:

WELD, WELD ROD SIZE, TYPE, AND WPS

APPROVED

DATE:

Yes ☐ No ☐

HOLD TAG

REMOVED

BY

DATE

REF. HDP/IR NUMBER: 100

UNIT I ☒ UNIT II ☒ (LOCATION DOCUMENTATION FILE)CLASS I ☒ NON-CLASS I ☐INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☐ PROCEDURE ☒

DOCUMENT TITLE AND NUMBER: OCP-5A Rev. 9 Para. 13.2.1

DESCRIPTION OF NONCONFORMANCE: (Including Cause)

There are a number of Class I welds that the Weld Rod Type, Size and WPS are unverifiable per OCP-5A Para. 13.2.1.

INFORMATION ONLY

INITIATED BY

DATE

Q.C. SUPERVISOR REVIEW

DATE

H.P. POLEY DISPOSITION:

- 1) Visually inspect welds in question to existing visual acceptance criteria.
 - 2) Accept weld filler metal type As Is.
 - a) 6010 and 7018 are the only types issued to Electrician Holders.
 - b) Both 6010 and 7018 are acceptable for use on electrical supports.
- (DISPOSITION CONTINUED ON PAGE 2)

APPROVAL OF DISPOSITION

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.G. & E. DISPOSITION OR CONCURRENCE:

PG-KE
OK by
AS
N-2

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT - CONTINUATION SHEET

NO.	BR02-P71 Rev
PAGE	OF
DATE	6-1-85

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☐
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

H. P. FOLEY DISPOSITION: CONTINUED FROM PAGE 1:

- 3) Accept rod size As Is if visual inspection is acceptable.
a) Remove and replace weld if lack of fusion is noted.
- 4) Accept Ht." As Is - Only acceptable filler material is issued to the rod control station.
- 5) Revise QCP-5A to require the welder to enter size, heat No. and type of rod used on the applicable "Work Copy" documentation. QC to verify it's entry.
- 6) Record this NCR Number on affected SWS's, VIS's.

INFORMATION ONLY

APPROVAL OF DISPOSITION

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT

Page 1 of 6

NUMBER:

[8802-92A]

DESCRIPTION: QCP-5A - Quality Control Procedure
for AWS Welding D1.1.
The above referenced Procedure is not in accordance
with the referenced Code - AWS D1.1.

ATTACHMENTS

Yes ☐ No ☐

DATE:

[9-6-83]

HOLD TAG # N/A
REMOVED

REF. EPF/IR NUMBER: N/A

BY _____ DATE _____

UNIT I ☒ UNIT II ☒ /LOCATION Various

CLASS I ☒ NON-CLASS I ☒

INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☒ PROCEDURE ☒ CODE X

DOCUMENT TITLE AND NUMBER: (SEE LIST OF PROCEDURES AND CODES ON PAGE 2)

DESCRIPTION OF NONCONFORMANCE: (Including Cause)

The referenced inspection criteria, H.P. Foley Q.A. Manual, states in part:
"...special processes are performed in accordance with the requirements of
applicable design drawings, specifications, procedures, codes and standards
by qualified personnel."

In violation of this Q.A. Manual is the referenced Procedure (QCP-5A)
because it is not in accordance with the above referenced Code (AWS D1.1).
Also, please note:

(CONTINUED ON PAGE 2)

INITIATED BY

DATE

Q.C. SUPERVISOR REVIEW

DATE

H.P. FOLEY DISPOSITION:

VOID
[1/29/83]

[ERN] FOR [R. WILSON]

See attached memorandum.

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.G. & E. DISPOSITION OR CONCURRENCE:

INFORMATION ONLY

P.G. & E. Co.

DATE

DISPOSITION ACCOMPLISHED

VERIFIED BY

DATE

Q.C. SUPERVISOR

DATE

N-3 2

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT - CONTINUATION SHEET

NO. 2862-924
PAGE 2 OF 6
DATE 8-6-83

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☒
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

INSPECTION CRITERIA: (CONTINUED FROM PAGE 1)

QCP-5A - Quality Control Procedure for AWS Welding D1.1

AWS D1.1-82 Structural Welding Code - Steel

H.P. Foley Q.A. Manual, Section IX, Control of Special Processes

10 CFR 50 Appendix "B", Section IX, Control of Special Processes

DESCRIPTION OF NONCONFORMANCE: (Including Cause) (CONTINUED FROM PAGE 1)

1. The Procedure (QCP-5A), Paragraph #1 "Scope", states in part, "This Procedure outlines the basic requirements to cover...gas metal arc welding."
The Code (AWS D1.1), Paragraph 5.1.2, requires a welding procedure specification to be prepared for the applicable process. This has not been done.
NOTE #1: The welding procedure specifications are currently for Shielded Metal Arc Welding and Flux Cored Arc Welding (FCAW).
NOTE #2: FCAW is not noted in the Procedure's Scope.
2. The Procedure (QCP-5A), Paragraph 3.2.1, states in part, "....the Production Superintendent (is) to insure Production forces under his supervision are kept informed of and are working to the latest requirements specified in the Quality Procedure."
This has not been done. Welders are frequently found to be unaware of even the welding procedure specification that they are using. The welders are not formally trained in the procedure.
3. The Procedure (QCP-5A), Paragraph 6.1.2, requires that the base metals prepared by oxygen cutting--surface roughness values not to exceed 1000 mil or 2000 mil, as applicable.
An ANSI Surface Roughness Gauge is not in the H.P. Foley Tool Room, Calibration Lab, Field or the Q.C. Department Tool Locker.
NOTE #1: This requirement is taken from the Code (AWS D1.1) at Paragraph 3.2.2. Also, see Note 4 of that paragraph.
NOTE #2: Discovered in the Purchasing Office was an AWS C4-1-77 Oxy-fuel Gauge. However, these gauges are not applicable to this referenced Procedure or Code.
4. The Procedure (QCP-5A), Paragraph 7.6.1.1, references welding processes FCAW-GMAW and SMAW.
The Code (AWS D1.1), Paragraph 5.1.2, requires a welding procedure specification to be prepared for the applicable process. This has not been done for the GMAW process.
NOTE: See Item #1 of this NCR.
5. The Procedure (QCP-5A), Paragraph 8.8, states..."caulking of welds, unless specifically noted by Constructor, is prohibited."
The Code (AWS D1.1), Paragraph 3.9, states: "Caulking of welds shall not be permitted."
(CONTINUED ON PAGE 3)

INFORMATION ONLY

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT - CONTINUATION SHEET

NO. 8802-924

PAGE 3 OF 6

DATE 9-6-83

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☒
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

DESCRIPTION OF NONCONFORMANCE: (Including Cause) (CONTINUED FROM PAGE 2)

NOTE: The Code (AWS D1.1), Appendix 1, "Terms and Definitions", states "Caulking. Plastic deformation of weld and base metal surfaces by mechanical means to seal or obscure discontinuities."

6. The Procedure (QCP-5A), Paragraph 10.3.1, references AWS D1.1 Current Revision.

The Current Revision is not in the Q.C. Library, and to the Writer's knowledge, the Current Revision is not on site.

NOTE #1: Current is 1983.

NOTE #2: The Procedure (QCP-5A), Paragraph 2, references AWS D1.1-75. This year Code is not in the Q.C. Library.

NOTE #3: Some site personnel have in their possession an AWS D1.1-75 with the 1976 and 1977 Addenda. There is, to the Writer's knowledge, not one of the referenced Code (1975) on site.

7. The Procedure (QCP-5A), Paragraph 10.2.5, allows the straightening of distorted members by the use of localized heat (i.e., not to exceed 1100° F).

The Code (AWS D1.1), Table 4.2, Note 3, records the maximum temperature for Group "4" materials as 400° F. to 450° F., depending on the material thickness.

NOTE #1: Group "4" materials are intended primarily for use in dynamic loading (bridges, seismic requirements, etc.), Please reference ASTM 1983 - Designation: A514-83.

NOTE #2: The steels in Group "4" are tempered.

8. The Procedure (QCP-5A), references AWS D1.1 Current Revision. Same as Item #6 of this NCR and also same as Item #3.

NOTE: Procedure (QCP-5A), Paragraph 10.3.3, does not reference year of Code.

9. The Procedure (QCP-5A), Appendix "A", Paragraph 3.5.7, references minimum fillet weld size for FCAW as 1/8".

NOTE #1: The Code (AWS D1.1). Table 2.7 Note ** states, "Minimum size for bridge applications is 3/16".

NOTE #2: The Code (AWS D1.1), Paragraph 1.1.1, states the basic division of the Code for buildings (static loading) and for bridges (dynamic loading). It is believed, by the Writer, that the structural steel work on this Project is built with seismic (dynamic) engineering criteria, so therefore, all work detailed with 1/8" fillet welds is discrepant in accordance with the Code criteria.

NOTE #3: The Procedure (QCP-5A) does not reference minimum fillet weld sizes for the welding processes SMAW or GMAW as does the Code (AWS D1.1), @ Table 2.7.

NOTE #4: If it is noted in response to this NCR, for it is not in the Procedure, that the structural/electrical work is to the building (static loading) section of the Code, then numerous supports are in violation of the Code (AWS D1.1), Paragraph and Figure 8.8.5. Example S-310, REV. 23; S-339, REV. 27; and others. (CONTINUED ON PAGE 4)

INFORMATION ONLY

137-1432

OK

not used

←

←

←

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT - CONTINUATION SHEET

NO. 5802-929

PAGE 4 OF 6

DATE 9-6-83

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☒
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

DESCRIPTION OF NONCONFORMANCE: (Including Cause) (CONTINUED FROM PAGE 3)

NOTE #5: The Code (AWS D1.1-82) specifies the minimum fillet weld size and requires that this size be made in a single pass. This requirement is intended to insure sufficient heat input in order to reduce the possibility of cracking in either the heat affected zone or weld metal, especially in a restrained joint. The Procedure does not reference this (minimum fillet weld size) requirement.

10. The Procedure (QCP-5A), Appendix "A", Paragraph 8.2, states... "Only the responsible P.G. & E. Welding Engineer or Designee is permitted to set parameters beyond the ranges specified on the WPS."
The Code (AWS D1.1), Section 5, "Qualification", provides for the qualification of weld joints by their acceptance to Sections 2, 3, 4, as well as Section 8, 9, or 10, as applicable, or by their qualification per ref. Paragraph 5.2.
The Code does not allow the welding procedure specifications to be exceeded. If a greater range of the parameters is required, a new WPS is to be established. Reference Section 5.
11. The Procedure (QCP-5A), Appendix "B", Paragraph 6.2. This is the same as Item #10 of this NCR.
12. The Procedure (QCP-5A) Section "D" Stud Welding, Paragraph D3.2.5 states: "All studs shall be installed reasonably perpendicular to the surface to which they are attached."
The Code (AWS D1.1 Commentary), Paragraph 7.6, states in part: "Studs applied to a vertical surface may require modified arc shields and modified arc shields may also be required when welding to other than front surfaces. Since this and other special cases are not covered by the manufacturer's stud base qualification, the Contractor shall be responsible for the performance of these tests."
NOTE #1: The Procedure does not reference any additional requirement for vertical, overhead, etc., welding.
NOTE #2: The referenced Procedure Paragraph permits all position welding of automatically controlled time welded studs.
13. The Code (AWS D1.1) requires tests to be performed by the Contractor (H.P. Foley) for other than flat position welding of automatically controlled time welded studs. This has not been performed.
14. The Procedure (QCP-5A), Paragraph D3.2.6 states: "If the reduction in length of studs as they are welded becomes less than normal (i.e., the length of the stud is more than 1/16" greater than specified), welding shall be stopped immediately and not resumed until the cause has been corrected."
The Procedure (QCP-5A) also notes the references for welding as D1.1-82 and D1.1-75 (Electrical only) at Paragraph 2, "References." The referenced Procedure Paragraph D3.2.6 is taken from the AWS D1.1-75 Code.
The stud welding section of the Procedure should be based upon the requirements of D1.1-82, Section 7 and Appendix "K" per the reference section of the Procedure (QCP-5A).
(CONTINUED ON PAGE 5)

INFORMATION ONLY

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT - CONTINUATION SHEET

NO. B602-929
PAGE 5 OF 5
DATE 9-6-83

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☒
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

DESCRIPTION OF NONCONFORMANCE: (Including Cause) (CONTINUED FROM PAGE 4)

14. (Continued)

NOTE #1: AWS D1.1-82 is basically different from the D1.1-75 Edition for the qualification process and procedural requirements.

NOTE #2: The referenced Procedure Paragraph on stud reduction has been deleted since 1978 from the D1.1 Code and the stud length reduction is found in the Manufacturer's Qualification Test Data for each and every diameter stud, along with its weld time cycles (in 1/60 seconds) and welding current. Also, please reference AWS C5.4, Table 4 - Typical Length Reductions of Studs in Arc Welding; and Table 5 - Typical Welding Conditions for Stud Welding of Steel; and Paragraph 6 - Welding Procedure (Studs).

NOTE #3: AWS C5.4, Recommended Practices for Stud Welding, is referenced in the Code, AWS D1.1-75-83. Also, AWS C5.4 cross references itself with AWS D1.1.

15. The Procedure (QCP-5A) Weld Procedure Specifications are not in accordance with the code AWS D1.1. Reference QCP-5A, WPS 1, Position of Welding - ALL (Vertical Upwards).

It is the intent of the code (AWS D1.1) that code users detail the position of welding (i.e. Flat, Vertical, Overhead, Horizontal) in order that the amps & volts parameters are conducive to produce quality welds.

NOTE: This is typical throughout the weld procedure specifications.

16. The Procedure (QCP-5A) Weld Procedure Specifications are not in accordance with the code AWS D1.1-82. The Weld Procedure Specifications are not detailed.

NOTE #1: Instead of detailing out the groove preparation dimensions, the Procedure states, The groove preparation (i.e. Root opening "R", Roof face "F", Groove Angle "A") Engineering variables as noted in the code and then includes the "As Sealed" tolerances.

Note: This allows the welder to engineer his own joint configuration.

17. The Procedures (QCP-5A) Weld Procedure Specification WPS-81 and WPS-82 weld symbol is for a Flare Bevel Groove Weld. The referenced DCC 4362 (Found in Remarks block of WPS-82) paragraph "C" states in part; Dr. Moss Davis (AWS) agrees that Flared single level (SIC) Groove Welds (for superstrut) shall be considered Fillet Welds...

NOTE# 1: The H. P. Foley letter to AWS dated February 21, 1978 Figure B details it as a Fillet Weld, AWS confirms it as a Fillet Weld and the Procedure details as a Groove Weld.

NOTE# 2: The material thickness is not noted on the WPS's.

NOTE# 3: WPS-81 Remarks block references DCC 4361. This should be DCC 4362 as noted above also as noted in WPS 78, 79 and 80.

18. Reference the above Item 17 Note# 2 of this NCR. The Weld Procedure Specifications WPS-81 and WPS-82 material thickness is not noted. The Joint Design sketch for WPS 81 and 82 can be / could have been mistaken for Tube steel to Building steel application using E-60XX electrodes.

CONTINUED ON PAGE 6:

INFORMATION ONLY

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT - CONTINUATION SHEET

NO. 8802-924

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☐
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

PAGE 6 OF 6

DATE 8-6-83

DESCRIPTION OF NONCONFORMANCE: (Including Cause) CONTINUED FROM PAGE 5:

18. NOTE # 1: The incorrectly referenced DCC 4361 (WPS-81) and DCC 4362 (WPS-8) is not readily available to craft and inspection personnel for it is a P.G.&E. DOCUMENT.
NOTE# 2: The incorrect Weld symbol (for Superstrut) is correct for Tube steel.
19. Reference Item 18 of this NCR. This condition is also applicable for WPS-78, 79 and 80 prior to PCN# 12.
20. The Procedure QCP-5A, WPS-62 is not in accordance with the Code AWS D1.1. This Joint Configuration is not prequalified per AWS D1.1-82 or any other Code year. If this Joint has been qualified by H. P. Foley it is not noted, also which is not noted are the Joint details, such as material thickness, root opening, radius, etc., so it is not known what material this WPS is to be used on or, have been used on.
21. The Procedure QCP-5A, WPS-62 details a dashed horizontal line on the vertical item on the right side of the sketch. It is not known the intent of this dashed horizontal line. If the WPS is showing the effective throat of the weld then this is indeed a Non-conforming condition for it is excessive (Joint penetration) detailed on the WPS.
NOTE# 1: Actual Joint Detail performance tests are required per AWS D1.1-82. The Joint Detail and Welding Variables (i.e. Electrode size, Amps, Volts, Welding positions, Root opening, etc.) should be shown on the W.P.S.
NOTE# 2: This information is required to make accurate Engineering and Inspections.
NOTE# 3: The Procedure contains in it's written form 29 ea "may be", 3 ea "should be", 1 ea "if necessary", 1 ea "preferably", 2 ea "reasonably", 3 ea "as practical", 1 ea "where practical", 1 ea "when practical", 1 ea "where possible", 1 ea "as possible", 1 ea "when possible", 1 ea "Same general position", 1 ea "reasonable smooth and regular".

INFORMATION ONLY

TO: [Evan Viney]
FROM: [Rick Wilson, Quality Director]
REF: NCR 8802-924, Notes of discussion 9/27/83
DATE: September 29, 1983

The following is an evaluation of the referenced NCR and the response there to:

1. - Item 1 is not a violation of Code, but is an inconsistency between the scope and content of the procedure. Engineering will process a PCN. Item 1 has not resulted in a non-conformance.
2. Resubmit this item on a separate NCR.
3. All oxygen cut surfaces are dressed by grinding and do not exceed the 1000 uin requirement in paragraph 3.2.2 of the AWS Code. There is no need for a roughness gage. This item has not resulted in a non-conformance.
4. This item is not a code violation, it is much like Item 1. Engineering will process a PCN. There is no non-conforming condition.
5. No caulking of welds has been performed. Engineering will process a PCN to revise the procedure.
6. Q.A. has a 1975 AWS D1.1.
7. AWS temperatures are interpass and preheat for welding and do not deal with binding of shapes. There are no group 4 materials on-site.
8. This is not a non-conforming condition.
9. Engineering is requesting information from the Owner as to the design basis. It should be noted that H. P. Foley's responsibility is to erect in accordance with the design supplied by the Owner. EDR 1337-1432 response to Note 4. Resubmit Note 5 on a separate NCR.
10. This has not resulted in a non-conforming condition. Engineering is processing a PCN to revise the wording in the procedure.

INFORMATION ONLY

11. See Item 10.
12. No Class 1 automatic stud welding has been performed on the project since the 1942 Code has been in effect. Engineering is processing a PCN to remove automatic stud welding from the procedure.
13. See Item 12.
14. See Item 12.
15. There is no violation of the code. Electrode utilized by H. P. Foley is designated by the Code as "all position" and the range of amperage and voltage is as specified by the manufacture.
16. The WPS's in use by H. P. Foley utilize the full range of tolerances allowed in the Code. This in and of itself is not a non-conformance. The Owner has approved each WPS and H. P. Foley is erecting the material as specified by the design documents. H. P. Foley is addressing your concerns to the Owner via an EDR.
17. There is no non-conformance. Engineering is revising the WPS to eliminate conflicts in terminology.
18. See Item 17.
19. See Item 17.
20. Resubmit on separate NCR.
21. See Item 20.

So that there is consistency in the use of NCR's and IR's; this project uses the ANSI n45.2.10 definitions. Questions concerning design are processed through H. P. Foley Engineering on an Engineering Disposition Request (EDR), and questions concerning procedure should be processed through H. P. Foley Engineering or Quality Assurance on Procedure Change Requests.


RW:tt

cc NCR (E802-924)

INFORMATION ONLY

THE
OWARD P. FOLEY
COMPANY

10-4-83
8802-941



ELECTRICAL

THE HOWARD P. FOLEY COMPANY
PRODUCTION ENGINEERING DEPT.
ENGINEERING DISPOSITION REQUEST

Nº 9756

UNIT I

UNIT II

SEP 28 1983

To G. Glascock

Subject Detail versus Procedure

From Ray B. Emanuelson

050030

Problem Question has arisen concerning detail versus procedural requirements. Note 1

of the 050029 Drawing states that the detail prevails for conduit over the procedure.

Numerous situations arise when the support details conflict with the procedure.

Reference S-18-1, REV. 30A embedment criteria versus embedment criteria in

QCPE-9, Paragraph 4.7.6. Can it be assumed in all cases that the detail drawing

prevails over procedure in reference to the 050030 details also?

Signed

Ray B. Emanuelson

Date

9/26/83

Reply YES.

Signed

G. Glascock

Date

9/27/83

N-4

THE HOWARD P. FOLEY COMPANY

TRANSMITTAL

TO [CLYDE NEEDHAM]
ENGINEERING MANAGER

DATE 10/5/83
JOB NO. WY-576
SPEC. NO. 8802

WE HEREBY TRANSMIT - FOR YOUR APPROVAL

FOR YOUR INFORMATION

IN (NCR) 8802-938

- ☒ FOR YOUR RECOMMENDED DISPOSITION
☐ FOR CORRECTIVE ACTION
☐ FOR YOUR SIGNATURE

THANK YOU

[Signature]

DATE RECEIVED _____

RECEIVED BY _____

TURN ORIGINAL SIGNED AND DATED TO _____

ORIGINAL

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT

Page 1 of 1	NUMBER: 8802-938
ATTACHMENTS Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	DATE: 10-3-83
HOLD TAG # REMOVED	
BY	DATE

DESCRIPTION: LONGITUDINAL RESTRAINTS FOR
STATION BATTERY'S FILLET WELDS WERE MADE UTILIZING
MULTI-PASS WELD TECHNIQUE

REF. HPP/IR NUMBER: N/A

UNIT I ☒ UNIT II ☒ /LOCATION Battery Room

CLASS I ☒ NON-CLASS I ☐

INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☐ PROCEDURE ☒ CODE AWS D1.1-82

DOCUMENT TITLE AND NUMBER: SK-8-OWS Rev 0, QCP-5A Struct. Weld., AWS D1.1-82
WRF 5105 Struct. Weld

DESCRIPTION OF NONCONFORMANCE: (Including Cause) The Longitudinal Restraints for Station Battery's Fillet welds were made utilizing Multi-pass weld technique. The Code (AWS D1.1-82) specifies the minimum fillet weld size and requires that this size be made in a single pass. This requirement is intended to insure sufficient heat input in order to reduce the possibility of cracking in either the heat affected zone or weld metal, especially in a restrained joint.

2. The H.P.F. Drawing SK-8-OWS Rev 0 is different from the PG&E Drawing of the same number. The H. P. Foley does not have PG&E concurrence. The complete work package traveler was not seen in the field only, the H.P.F. Drawing.

INITIATED BY

DATE

Q.C. SUPERVISOR REVIEW

DATE

H.P. FOLEY DISPOSITION:

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.G. & E. DISPOSITION OR CONCURRENCE:

Added info - in different? It is a work copy, info can be added for clarity and ease of construction and no / G & E Concurrence is required. If Q & A has concurred that's all that is needed

INFORMATION ONLY

Recommended Disposition

THE HOWARD P. FOLEY COMPANY

TRANSMITTAL

TO CLYDE NEEDHAM

ENGINEERING MANAGER

DATE 10/5/83

JOB NO. WY-576

SPEC. NO. 8802

WE HEREBY TRANSMIT - FOR YOUR APPROVAL

FOR YOUR INFORMATION

TR/NCR 8802-942

- ☒ FOR YOUR RECOMMENDED DISPOSITION
☐ FOR CORRECTIVE ACTION
☐ FOR YOUR SIGNATURE

THANK YOU

Clay

DATE RECEIVED _____

RECEIVED BY _____

RETURN ORIGINAL SIGNED AND DATED TO _____

FORM H.P.F./T.

INFORMATION

N-6

6.

ORIGINAL

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT

Page 1 of 1	NUMBER: 8802-942
ATTACHMENTS Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	DATE: 10-4-83
HOLD TAG # N/A REMOVED	
BY	DATE

DESCRIPTION:
PROCEDURE VIOLATION - QCP-5A

REF. RPT/IR NUMBER: N/A

UNIT I ☒ UNIT II ☒ /LOCATIONCLASS I ☐ NON-CLASS I ☐INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☐ PROCEDURE ☒

DOCUMENT TITLE AND NUMBER: Q.C. PROCEDURE FOR AWS WELDING D1.1

DESCRIPTION OF NONCONFORMANCE: (Including Cause) The Procedure (QCP-5A), Paragraph 3.2.1, states in part, "...the Production Superintendent (is) to insure Production forces under his supervision are kept informed of and are working to the latest requirements specified in Quality Procedure." This has not been done. Welders are frequently found to be unaware of even the welding procedure specification that they are using. The welders are not formally trained in the procedure.

INITIATED BY

DATE

Q.C. SUPERVISOR REVIEW

DATE

H.P. FOLEY DISPOSITION:

P.C. & E. DISPOSITION OR CONCURRENCE:

INFORMATION ONLY
Recommended Disposition

THE HOWARD P FOLEY COMPANY

TRANSMITTAL

TO CLYDE NEEDHAM
ENGINEERING MANAGER

DATE 10/5/83

JOB NO. WY-576

SPEC. NO. 8802

WE HEREBY TRANSMIT - FOR YOUR APPROVAL

FOR YOUR INFORMATION

IRACH 8802-940

- ☒ FOR YOUR RECOMMENDED DISPOSITION
☐ FOR CORRECTIVE ACTION
☐ FOR YOUR SIGNATURE

Take a look at this and see what you can do to clarify it.

THANK YOU

[Signature]

DATE RECEIVED

RECEIVED BY

4 (IN ORIGINAL SIGNED AND DATED TO

FORM H.P.F. 101

N-7

INFORMATION ONLY 1.

THE HOWARD P. FOLEY COMPANY

NONCONFORMANCE REPORT

ORIGINAL

NUMBER:

8802-940

DESCRIPTION: THE PROCEDURE QCP-5A, WELDING
PROCEDURE SPECIFICATION (WPS) IS NOT QUALIFIED

ATTACHMENTS:

DATE:

Yes ☒ No ☐

10-4-83

HOLD TAG #
REMOVED

N/A

REF. HPF/IR NUMBER:

BY _____ DATE _____

UNIT I ☒ UNIT II ☒ /LOCATIONCLASS I ☒ NON-CLASS I ☐INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☐ PROCEDURE ☒

DOCUMENT TITLE AND NUMBER: Welding AWS DL1 QCP-5A

DESCRIPTION OF NONCONFORMANCE: (Including Cause) The Procedure QCP-5A, WPS-62 is not in accordance with the Code AWS DL1. This Joint Configuration is not prequalified per AWS DL1-82 or any other Code year. If this Joint has been qualified by H. P. Foley it is not noted, also which is not noted are the Joint Details, such as material thickness, root opening, radius, etc., so it is not known what material this WPS is to be used on or, have been used on.

INITIATED BY

DATE

QCP SUPERVISOR REVIEW

DATE

H.P. FOLEY DISPOSITION:

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.C. & E. DISPOSITION OR CONCURRENCE:

recommended Disposition
RECOMMENDATION ONLY

THE HOWARD P. FOLEY COMPANY

DIABLO CANYON JOE SITE


(PS) PROCEDURE SPECIFICATION NO.

WPS-22 WCP-5A

Material Specification _____ Group I and II per Table 4.1.1 AWS D1.1
 Welding Process _____ Shielded Metal Arc
 Manual or Machine _____ Manual
 Position of Welding _____ All (Vertical-Up)
 Filler Metal Specification _____ SFA A5.1
 Filler Metal Classification _____ E7018
 Flux _____ N/A
 Weld Metal Grade _____ 70,000 PSI
 Shielding Gas _____ N/A
 Single or Multiple Pass _____ Multiple Pass
 Single or Multiple Arc _____ Single
 Welding Current _____ Direct
 Polarity _____ Reverse
 Root Treatment _____ None
 Preheat and Interpass Temperature Up to and thru 3/4", none (*); over 3/4" and thru 1 1/2"
 50°F; over 1 1/2" and thru 2 1/4", 150°F; over 2 1/4", 225°F. *When base metal temperature is below
 12°F, base metal shall be preheated to and maintained at or above 70°F during welding.

NO. OF PASSES	ELECT SIZE	CURRENT	
		AMPS	VOLTS
Required	3/32	70-100	20-30
	1/8	110-150	20-30
	5/32	150-210	20-30

REMARKS:
 Maximum pass width 4 dia. of elec. being
 used; clean after each pass, no severe
 undercutting permitted on any intermediate



This procedure may vary due to fabrication sequence, fit-up, pass size, etc.
 within the "Limitation of Variables" given in the American Welding Society
 Structural Welding Code.

INFORMATION ONLY
 Recommended Disposition

THE HOWARD P. POLEY COMPANY
NONCONFORMANCE REPORT

Page 1 of 2

NUMBER:

8802-943

DESCRIPTION:

Class One Support Rework

ATTACHMENTS

Yes ☐ No ☐

DATE:

10-5-83

HOLD TAG #
REMOVED

N/A

REF. HPF/IR NUMBER: N/A

BY

DATE

UNIT I ☒ UNIT II ☒ /LOCATION Various

CLASS I ☒ NON-CLASS I ☐

INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☐ PROCEDURE ☒

DOCUMENT TITLE AND NUMBER:

Initiation of Work - QCP-17 REV. 1

DESCRIPTION OF NONCONFORMANCE: (Including Cause)

QCP-17, REV. 1, Paragraph 1d. (Scope) states: "Class One Electrical Raceway Support rework shall be handled in accordance with Appendix D." Appendix D, Paragraph D2.2 states that: "P.G. & E. will issue a 'work request' for any support rework (i.e. modifications, deletions, additions or complete replacement) and verification inspection." Contrary to this, "Conduit" Change Orders are being issued to cover "Support" work. These Conduit Change Orders do not reference any work request and do not fall within the scope of Appendix D.
(CONTINUED ON PAGE 2)

INITIATED BY

DATE

10-5-83

Q.C. SUPERVISOR REVIEW

DATE

H.P. POLEY DISPOSITION:

FIXED - ON 10-6-83

by [Pete]

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.G. & E. DISPOSITION OR CONCURRENCE:

INFORMATION ONLY

P.G. & E. Co.

DATE

DISPOSITION ACCOMPLISHED

N-8

VERIFIED BY

DATE

Q.C. SUPERVISOR

DATE

8

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT - CONTINUATION SHEET

NO.

8802-9437

PAGE 2 OF 2

DATE

10-5-83

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☒
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

DESCRIPTION OF NONCONFORMANCE: (Including Cause) (CONTINUED FROM PAGE 1)

This is in violation of QCP-3, REV. 6 "Processing and Control of Deviations and Nonconformances." Paragraph 3.2 of QCP-3 states: "The Production Superintendent or Designee assigned by the Project Manager shall be responsible for notifying Quality of deviations and nonconformances and accomplishing all work in accordance with the specifications, design drawings and procedures."

Per ANSI N45.2.10: "Quality Assurance Terms and Definitions": a nonconformance is "a deficiency in characteristic, documentation or procedure which renders the quality of an item unacceptable or indeterminate. Examples of nonconformance include: physical defects, test failures, incorrect or inadequate documentation, or deviation from prescribed processing, inspection or test procedures."

INFORMATION ONLY

CIVIL

No 1486

UNIT I

X

UNIT II

X

1983

THE HOWARD P. FOLEY COMPANY
PRODUCTION ENGINEERING DEPT.
ENGINEERING DISPOSITION REQUEST

To F.M. Russell

Subject Structural Welding Requirements

From D. Jones

Problem Per specification #8802 welding is to be performed in accordance with building section requirements of the AWS Welding Code for Structural Steel. However applicable section of the AWS Code is not referenced in other job specifications.

It is our understanding that all Structural Welding should conform with the additional requirements of section 8 - Buildings : Is this correct ?

Signed




Date

10/7/83

Reply WELDING SHALL BE PERFORMED TO THE REQUIREMENTS OF THE SECTION RELATING TO BUILDINGS AND THE GENERAL CODE SECTIONS. THE CODE REQUIREMENTS FOR BRIDGES DO NOT APPLY UNLESS SPECIFICALLY REFERENCED.

Signed FORREST RUSSELL



Date

October 7, 1983

Rick

To: Ivan Vinos

CHECK THIS OUT

DAVE

N-9

ORIGINAL

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT

DESCRIPTION: VARIOUS MINIMUM SIZED FILLET WELDS WERE MADE UTILIZING THE MULTI-PASS WELD TECHNIQUE		Page <u>1</u> of <u>1</u>	NUMBER: 8802-938 Rev <u>1</u>
		ATTACHMENTS Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	DATE: 10-7-83
		HOLD TAG # REMOVED	
REF. HPF/IR NUMBER: N/A		BY _____ DATE _____	
UNIT I <input checked="" type="checkbox"/> UNIT II <input checked="" type="checkbox"/> /LOCATION VARIOUS		CLASS I <input checked="" type="checkbox"/> NON-CLASS I <input type="checkbox"/>	
INSPECTION CRITERIA: DRAWING <input type="checkbox"/> SPECIFICATION <input type="checkbox"/> PROCEDURE <input checked="" type="checkbox"/> CODE AWS D1.1-82			
DOCUMENT TITLE AND NUMBER: QC Procedure for Structural Welding QCP-5A AWS D1.1			
DESCRIPTION OF NONCONFORMANCE: (Including Cause) There is a deficiency in the above referenced procedure which renders the quality of the items utilized in conjunction with the procedure as unacceptable. The above referenced code specifies the minimum fillet weld size and requires that this size be made in a single pass. The above reference procedure does not note this requirement and welds have been made in violation of this requirement.			
INITIATED BY <u>[Signature]</u>		Q.C. SUPERVISOR REVIEW <u>[Signature]</u>	
DATE 10-7-83		DATE 10-7-83	
H.P. FOLEY DISPOSITION:			
DISPOSITION BY _____		QUALITY REVIEW _____	
DATE _____		DATE _____	
P.G. & E. DISPOSITION OR CONCURRENCE:			
DISPOSITION ACCOMPLISHED		P.G. & E. Co. _____	
VERIFIED BY _____		O.C. SUPERVISOR _____	
DATE _____		DATE _____	

HPF/MCR 7-18-83

N-10

101

ORIGINAL

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT

Page 1 of 1

NUMBER:

8802-940 Rev 1

DESCRIPTION: ~~THE PROCEDURE QCP-5A~~, WELDING
PROCEDURE SPECIFICATION (WPS) IS NOT QUALIFIED

ATTACHMENTS

Yes ☒ No ☐

DATE:

10-7-83

HOLD TAG " N/A
REMOVED

REF. HPF/IR NUMBER: N/A

BY _____ DATE _____

UNIT I ☒ UNIT II ☒ /LOCATIONCLASS I ☒ NON-CLASS I ☐INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☐ PROCEDURE ☒

DOCUMENT TITLE AND NUMBER: Welding AWS D1.1 QCP-5A

DESCRIPTION OF NONCONFORMANCE: (Including Cause) There is a deficiency in the above
referenced Weld Procedure Specification (WPS) which renders the quality of all items
utilizing the above referenced W.P.S. as indeterminate.The above referenced WPS has inadequate documentation for its qualification for
its use.The weld joint details such as material thickness, root opening, radius, initial
pass electrode size, etc., are not noted. It is not known what material this W.P.S.
is to be used on, or has been used on.

INITIATED BY

DATE

Q.C. SUPERVISOR REVIEW

DATE

H.P. FOLEY DISPOSITION:

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.G. & E. DISPOSITION OR CONCURRENCE:

P.G. & E. Co.

DATE

DISPOSITION ACCOMPLISHED

VERIFIED BY

DATE

O.C. SUPERVISOR

DATE

HPF/NCR 7-18-83

N-11


11.

Material Specification _____
 Welding Process _____
 Filler Metal _____
 Shielding Gas _____
 Single or Multiple Pass _____
 Single or Multiple Arc _____
 Welding Current _____
 Polarity _____
 Root Treatment _____
 Preheat and Interpass Temperature _____
 50°F; over 1/4" and thru 3/4", 150°F; over 3/4" and thru 1 1/2", 225°F. When base metal temperature is below 40°F, base metal shall be preheated to and maintained at or above 70°F during welding.

INFORMATION ONLY

NO. OF PASSES	ELEC. SIZE	CURRENT	
		AMPS	VOLTS
As Required	3/32	70-100	20-30
	1/8	110-150	20-30
	5/32	150-210	20-30

REMARKS:
 Maximum pass width 4 dia. of elec. being used; clean after each pass, no severe undercutting permitted on any intermediate passes.



INFORMATION ONLY

THE HOWARD P FOLEY COMPANY

TRANSMITTAL

TO CLYDE NEEDHAM
ENGINEERING MANAGER

DATE 10/5/83

JOB NO. WY-576

SPEC. NO. 8802

WE HEREBY TRANSMIT - FOR YOUR APPROVAL

FOR YOUR INFORMATION

IR/NCR 8802-941

- ☐ FOR YOUR RECOMMENDED DISPOSITION
☐ FOR CORRECTIVE ACTION
☐ FOR YOUR SIGNATURE

THANK YOU

DATE RECEIVED

RECEIVED BY

TURN ORIGINAL SIGNED AND DATED TO

THE HOWARD P. FOLEY COMPANY

NONCONFORMANCE REPORT

ORIGINAL

1 of 1		NUMBER: 8802-941
ATTACHMENTS Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		DATE: 10-4-83
HOLD TAG # REMOVED		N/A
BY _____		DATE _____

DESCRIPTION:
THE PROCEDURE QCP-5A, WELDING PROCEDURE
SPECIFICATION (WPS) # 62 IS NOT DETAILED
CORRECTLY

REF. HPF/LR NUMBER: N/A

UNIT I ☒ UNIT II ☒ /LOCATIONCLASS I ☐ NON-CLASS I ☐INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☐ PROCEDURE ☒

DOCUMENT TITLE AND NUMBER: WELDING AWS D1.1 QCP-5A

DESCRIPTION OF NONCONFORMANCE: (Including Cause) The Procedure QCP-5A, WPS-62 details a dashed horizontal line on the vertical item on the right side of the sketch. It is not known the intent of this dashed horizontal line. If the WPS is showing the effective throat of the weld then this is indeed a Non-conforming condition for it is excessive (Joint penetration) detailed on the WPS. It is not known what material this WPS is to be used on, or has been used on.
CONTINUED ON PAGE 2:

INITIATED BY

DATE

E.P.C. SUPERVISOR REVIEW

DATE

E.P. FOLEY DISPOSITION:

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.C. & E. DISPOSITION OR CONCURRENCE:

INFORMATION ONLY

Recommended Disposition

THE HOWARD P. FOLEY COMPANY
ORIGINAL NONCONFORMANCE REPORT - CONTINUATION SHEET

NO.
8802-941
PAGE 2 OF 2
DATE 10-4-83

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☐
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

DESCRIPTION OF NONCONFORMANCE: (Including Cause) CONTINUED FROM PAGE 1:

NOTE# 1: Actual Joint Detail performance tests are required per AWS D1.1-82. The Joint Detail and Welding Variables (i.e. Electrode size, Amps, Volts, Welding positions, Root opening, etc.) should be shown on the W.P.S.

NOTE# 2: This information is required to make accurate Engineering and Inspections.

NOTE# 3: The Procedure contains in it's written form 29 ea "may be", 3 ea "should be", 1 ea "if necessary", 1 ea "preferably", 2 ea "reasonably", 3 ea "as practical", 1 ea "where practical", 1 ea "when practical", 1 ea "where possible", 1 ea "as possible", 1 ea "when possible", 1 ea "same general position", 1 ea "reasonably smooth and regular".

*What does this mean?
make it clear or leave it out.*

Recommended Disposition

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT

ORIGINAL

Page <u>1</u> of <u>1</u>	NUMBER: <u>8902-942 Rev 1</u>
ATTACHMENTS Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	DATE: <u>10-7-83</u>
HOLD TAG # REMOVED	
BY _____	DATE _____

DESCRIPTION: PROCEDURE VIOLATION - QCP-5A Paragraph 3.2.1	
REF. HPF/IR NUMBER: N/A	
UNIT I <input checked="" type="checkbox"/> UNIT II <input checked="" type="checkbox"/> /LOCATION	CLASS I <input type="checkbox"/> NON-CLASS I <input type="checkbox"/>

INSPECTION CRITERIA: DRAWING <input type="checkbox"/> SPECIFICATION <input type="checkbox"/> PROCEDURE <input checked="" type="checkbox"/>
DOCUMENT TITLE AND NUMBER: QCP-6 Para. 4.4; 4.5; 4.5.1; 4.5.2

DESCRIPTION OF NONCONFORMANCE: (Including Cause) The Procedure (QCP-5A), Paragraph 3.2.1, states in part, "...the Production Superintendent (is) to insure Production forces under his supervision are kept informed of and are working to the latest requirements specified in Quality Procedure." This has not been done. Welders are frequently found to be unaware of even the welding procedure specification that they are using. There is no documentation, or training records, for some welders being indoctrinated to QCP-5A.

<u>[Signature]</u> <u>10-7-83</u>	<u>[Signature]</u> <u>10-7-83</u>
INITIATED BY DATE	Q.C. SUPERVISOR REVIEW DATE

H.P. FOLEY DISPOSITION:

DISPOSITION BY _____	DATE _____	QUALITY REVIEW _____	DATE _____
----------------------	------------	----------------------	------------

P.G. & E. DISPOSITION OR CONCURRENCE:

INFORMATION ONLY

P.G. & E. Co. _____	DATE _____
---------------------	------------

DISPOSITION ACCOMPLISHED

VERIFIED BY _____	DATE _____	Q.C. SUPERVISOR _____	DATE _____
-------------------	------------	-----------------------	------------

1. PENCH 7-18-83

N-12

12.

To: [James J. Roselli] Quality Supervisor
From: [Edward G. Jones] D.C. Inspector II
REF: NCR [E802-924] VOIDING OF [9/27/83]
DATE: [SEPT 30, 1983]

Mr. [Roselli,]

I DO NOT AGREE WITH THE VOIDING OF
THE ATTACHED N.C.R. OR THE ATTACHED LETTER
FROM THE QUALITY DIRECTOR, [Mr. R. Wilson.]

Also, it is hereby noted that this voiding of
the above referenced NCR is not what was
discussed and agreed on at the above referenced
meeting, the contents of the letter is different
in some areas of the NCR than that what
was discussed.

I FIRMLY BELIEVE AN IN DEPTH REVIEW OF THE
ENTIRE H. P. FOLEY WELDING PROGRAM IS IN ORDER.

The attached letter references ANSI N45.2.10
DEFINITIONS - THE ONLY AVAILABLE ANSI N45.2.10 IS
10 YEARS OLD (1973) IS THIS ACCEPTABLE?

Please respond with directions pertaining to
NCR [E802-924] AND ITS VOIDING - THE ATTACHED LETTER
DATED [SEPT 27, 1983] IS DRAFTING AND REVIEW

AGAIN, OTHER NON-CONFORMING AREAS ARE IN THE PROGRAM.

[Signature]

C



THE HOWARD P. FOLEY COMPANY
PRODUCTION ENGINEERING DEPT.
ENGINEERING DISPOSITION REQUEST

№ 10066

To G. Glasgow Subject GLP 5A

From R. Knowles Welding.

Problem May we assume that unless otherwise specified vendor supplied material i. e. cabinets motors ect. is Group I per table 4.1.1 AWS D1.1.

R. Knudsen

Date 10/6/82

Reply YES.

A. J. Harschel

Date 10/6/83

ORIGINAL

NONCONFORMANCE REPORT

Page 1 of 1

8833XR-23

DESCRIPTION: C-6180 CONN CH
Weld 7A&7B to Ext.Col. 11² v¹ IN
Plate MK A005-1
Elv. 187'

YES ☐ NO ☐
ATTACHMENTS

Date:

2-7-83

HOLD TAG # 8833XR-14

REMOVED

BY *[Signature]*

DATE 4-7-83

REF. HPF/IR NUMBER 8833XR-14

UNIT I ☒ UNIT II ☐ / LOCATION FUEL HANDLING BLDG. EL.187' CLASS I ☒ NON-CLASS I ☐INSPECTION CRITERIA: DRAWING ☒ Rev 4 SPECIFICATION ☐ PROCEDURE ☒

DOCUMENT TITLE AND NUMBER: 6180-F1-13-005; QCP-5A

DESCRIPTION OF NONCONFORMANCE: (Including Cause)

The above preheated plate welds were accepted by Quality Control
(see attached HPF/WIS).

Upon cooling weld 7A cracked its full length, and weld 7B cracked 1/2 its
length. (Both 4" welds).

Plate (MK A005-1) plate is warped by 1/2" in 20" of length.

INITIATED BY

DATE

QUALITY MANAGER

DATE

PROJECT MANAGER

DATE

DISPOSITION INCLUDING MEANS TO PREVENT RECURRENCE:

Remove Plate A-005-1 and replace. Grind area of cracked welds flush and
liquid penetrant test to ensure that cracks did not propagate into base
metal.

Hold training meeting with Production supervision on distroction control.

DISPOSITION BY

DATE

PROJECT MANAGER

DATE

QUALITY MANAGER

DATE

PACIFIC GAS AND ELECTRIC CO.

DATE

DISPOSITION ACCOMPLISHED

PT Accomplished and found Acceptable on 3-3-83

Training meetings held 3-4-83.

STAFF

DATE

SUPERVISOR

DATE

QUALITY MANAGER

DATE

THE HOWARD P. FOLEY CO. ACCEPTANCE

PACIFIC GAS AND ELECTRIC CO. ACCEPTANCE

CLOSED To File 4/1/83

DIRECT MANAGER

DATE

SIGNATURE

DATE

UNIT I

UNIT II

1983

CIVIL

No

1486

THE HOWARD P. FOLEY COMPANY

PRODUCTION ENGINEERING DEPT.

ENGINEERING DISPOSITION REQUEST

To F.M. Russell

Subject Structural Welding Requirements

From D. Jones

Problem Per specification #8802 welding is to be performed in accordance.

with building section requirements of the AWS Welding Code for

Structural Steel. However applicable section of the AWS Code is not

referenced in other job specifications.

It is our understanding that all Structural Welding should conform with the additional requirements of section 8 - Buildings : Is this correct ?

Signed

Date

10/7/83

Reply WELDING SHALL BE PERFORMED TO THE REQUIREMENTS OF THE SECTION RELATING TO BUILDINGS AND THE GENERAL CODE SECTIONS. THE CODE REQUIREMENTS FOR BRIDGES DO NOT APPLY UNLESS SPECIFICALLY REFERENCED.

Signed

FORREST RUSSELL

Date

October 7, 1983

Rick

To: [Handwritten]

CHECK THIS OUT

DAVE

N-13

13

Original

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT

Page 1 of 2

NUMBER:
8802-871 Rev.2

DESCRIPTION:

WPS#, Weld Rod Size and Type Unverifiable

ATTACHMENTS

Yes ☐ No ☒

DATE:

10-13-83

HOLD TAG #
REMOVED

REF. HPF/IR NUMBER: N/A

BY _____ DATE _____

UNIT I ☒ UNIT II ☒ /LOCATION Documentation FilesCLASS I ☒ NON-CLASS I ☐INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☐ PROCEDURE ☒

DOCUMENT TITLE AND NUMBER: QCP-5A Rev.9, Para. 13.2.1

DESCRIPTION OF NONCONFORMANCE: (Including Cause)

There are a number of Class I Raceway Support Welds that the Weld Rod Type, Size, and WPS are unverifiable per QCP-5A, Para. 13.2.1.

INITIATED BY

DATE

Q.C. SUPERVISOR REVIEW

DATE

H.P. FOLEY DISPOSITION:

- 1) Welds shall be visually accepted prior to final sign-off of support.
 - a) Visual inspection confirms structural integrity of welds.
- 2) 6010 and 7018 are the only types issued to Electrician Welders.
- 3) Both 6010 and 7018 are acceptable for use on electrical supports.
(Continued on next page)

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.G. & E. DISPOSITION OR CONCURRENCE:

DISPOSITION ACCOMPLISHED

VERIFIED BY

DATE

Q.C. SUPERVISOR

DATE

H. ICR 7-18-83

Original

THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT - CONTINUATION SHEET

NO.	8802-871 Rev. 2
PAGE	2 OF 2
DATE	10-13-83

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☒
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

H.P. FOLEY DISPOSITION: (Continued)

- 4) Accept rod size "As Is" if visual inspection is acceptable.
 - a) Remove and replace weld if lack of fusion is noted.
- 5) Accept Ht.# "As Is" - Only acceptable filler material is issued to the Rod Control Station.
- 6) Revise QCP-5A to require the Electrical Welder to enter Size, Heat No., and Type of rod used on the applicable "Work Copy" documentation. Q.C. to verify it's entry.
- 7) Record this NCR Number on affected SIWS's or WIS's.
- 8) Accept missing WPS No. "As Is" based on Item #1), above.

ELECTRICAL

UNIT I



RK

UNIT II



VT

JS-3

LW-3

THE HOWARD P. FOLEY COMPANY
PRODUCTION ENGINEERING DEPT.
ENGINEERING DISPOSITION REQUEST

No. 9186

JAN 24 1983

To W. Coley/R. Dizon/R. Monterola Subject SR-E1238 DCI-EC-3604-4From R. Knowles

Problem On detail S-190 (CSR-127-4-52) the recommended "fix" can not be done. Do you have an alternate method?

On detail S-428 (CSR-127-6-343) the weld symbol shows we have to weld all the way around. Can we weld on three sides only?

Signed

R. Knowles

Date 1-21-83

Reply

① YES, use attached new "fix" (Page 1) as approved by OPEG. (S-190) CSR-127-4-52

② YES, 3 welds will be sufficient. See attached (Page 2) for CSR-127-6-343. (S-428)


Signed

R. Dizon

Date

1/24/83

Page 1



NEW FIX FOR SUPPORT NO. 6 SR-127-4-52

DETAIL S-190

Per DCI-EC-3604-~~4~~ and W.R. E-1238
 TO: ~~ED EPSTEIN~~ (OPEG)

1. We cannot modify support per detail S-190 as
 supplied by Engineering. Above sketch is suggested.
 Do you concur?


2. YES, Per ~~ED EPSTEIN~~ (1-21-53)

R.V. Monteleone
 1/21/53

PACIFIC GAS & ELECTRIC CO.	
APPROVED FOR CONSTRUCTION	
ENGINEERING DEPARTMENT	
BY ED EPSTEIN	DATE 1/21/53

Jan. 21, 1983

Page 2




(Proposed) ① Because of space limitation we can only weld 3 sides (bottom & 2 sides). Is this good enough?

TO: ~~ED~~ EPSTEIN (OPEG)

FOR Support No. CSR-127-6-343 Detail S-428

PER DCI-EC-3604-4 and W.R. E-123B

1. Welding 3 sides of the S-L brace is good enough. PER ~~ED~~ EPSTEIN (OPEG)



~~R.V. Montano~~ 1/21/83

TO [Rick Wilson]

In reference to NCR # [939] your disposition of a request for procedure change was unacceptable to Pete since several hundred supports were already installed without work requests. After NCR # [939] was voided, [Pete] clarified this nonconformance on NCR # [943]. It was not [Pete's] intent to not follow management's direction" by not writing a procedure change request. He merely felt that the definition of a nonconformance should be more clearly defined. [Pete Mesarop] has been a QC inspector for many years and is more quality oriented than any inspector you will find. It was quite a let down to everyone after coming back from your meeting to find out that you terminated one of your top professionals for trying to do his job. Don't you think it would have been more appropriate to call [Pete] into your office where you could at least explain your disposition rather than terminating him and intimidating the rest of the QC Inspectors.

Signed: [Michael D. Leggett]
Epic QC Inspector

To : Terry Roselli, Quality Supervisor
From : Ivan G. Jones, Q.C. Inspector II
REF NCR BB03-924 VOIDING OF #127183
DATE: SEPT 30, 1983 / gk

Mr. Roselli

I DO NOT AGREE WITH THE VOIDING OF
THE ATTACHED N.C.R. OR THE ATTACHED LETTER
FROM THE Quality Director, Mr. R. Wilson

Also, it is hereby noted that this voiding of
the above referenced NCR is not what was
discussed and agreed on at the above referenced
meeting, the contents of the letter is different
in some areas of the NCR than that what
was discussed.

I firmly believe an in depth review of the
entire H.P. Folly Welding Program is in order.

The attached letter references ANSI N45.2.10
DEFINITIONS - THE ONLY AVAILABLE ANSI N45.2.10 IS
10 YEARS OLD (1973) IS THIS ACCEPTABLE?

Please respond with directions pertaining to
NCR BB02-924 AND ITS VOIDING - THE ATTACHED LETTER
DATED SEPT 29, 1983 ITS EVALUATION AND RESPONSE.

Again, other non-conforming areas are in the procedure.

Sincerely,
Ivan G. Jones

To: Iven Vines } Q.C. Inspector II
From: Terry Roselli } Q.C. Supervisor
Ref: NCR 8802-924 } voiding

910-10-83

Mr. Vines }

Contained herein is my response to your letter dated 9-30-83. Your first concern dealt with the voiding of NCR 8802-924 and the letter that was sent to you by Mr. Rick Wilson giving direction to yourself about how to address each item of the above mentioned NCR. Mr. Wilson, as the Quality Director, has determined that this NCR should be voided and addressed item-by-item per his memorandum, and is within ^{procedural} his rights to do so per QCP-3.

The second concern dealt with a meeting that was held with yourself, Terry Roselli, Dave Jones and Rick Wilson. The discussion dealt with ^{engineering} ~~managements~~ and Q.C. and Q.C. managements comments on NCR 8802-924. I agree that the memo does not reflect all agreements that were made. I suggest that we adhere to the direction of the memorandum that is attached to the NCR and follow up with a letter to Rick Wilson itemizing those areas that are still of concern.

The third concern dealt with your feeling that an in-depth review of the entire H.P. Foley welding program is in order. This concern should be addressed to Rick Wilson and engineering via a letter also.

The fourth concern dealt with ~~with~~ the 1973 edition of ANSI N45.2.10. I have checked with Quality Assurance Supervisor [Jim Thompson] and the 1973 edition of ANSI N45.2.10 is what he has in his reference library. As such, the 1973 edition is acceptable for H.P. Foley on this site.

In closing I wish to state that the overall responsibility for Quality lies with Management and their implementation and control of the Quality program. You have presented some of your concerns, in ~~NAF 802-927~~ and Management has made their decision and consequently are now ~~is~~ responsible for that decision. It is your responsibility as an Inspector to make management aware of conditions that management must address. You, as an Inspector, cannot be held accountable for decisions made by Management. If you feel that items of concern were not addressed appropriately, I will help in bringing these concerns of yours to the Quality Director.

Sincerely

[J. R. Rull]

Original

THE HOWARD P. FOLEY COMPANY

NONCONFORMANCE REPORT

Page 1 of 2

NUMBER:

(8802-871 Rev.2)

DESCRIPTION:

WPS#, Weld Rod Size and Type Unverifiable

ATTACHMENTS

Yes ☐ No ☒

DATE:

(10-13-83)

HOLD TAG #
REMOVED

REF. HPF/IR NUMBER: N/A

BY _____ DATE _____

UNIT I ☒ UNIT II ☒ /LOCATION Documentation FilesCLASS I ☒ NON-CLASS I ☐INSPECTION CRITERIA: DRAWING ☐ SPECIFICATION ☐ PROCEDURE ☒

DOCUMENT TITLE AND NUMBER: QCP-5A Rev.9, Para. 13.2.1

DESCRIPTION OF NONCONFORMANCE: (Including Cause)

There are a number of Class I Raceway Support Welds that the Weld Rod Type, Size, and WPS are unverifiable per QCP-5A, Para. 13.2.1.

INITIATED BY

DATE

P.G. SUPERVISOR REVIEW

DATE

H.P. FOLEY DISPOSITION:

- 1) Welds shall be visually accepted prior to final sign-off of support.
 - a) Visual inspection confirms structural integrity of welds.
- 2) 6010 and 7018 are the only types issued to Electrician Welders.
- 3) Both 6010 and 7018 are acceptable for use on electrical supports.

(Continued on next page)

DISPOSITION BY

DATE

QUALITY REVIEW

DATE

P.G. & E. DISPOSITION OR CONCURRENCE:

P.G. & E. Co.

DATE

DISPOSITION ACCOMPLISHED

VERIFIED BY

DATE

P.G. SUPERVISOR

DATE

WORK COPY

N-14 14

original
THE HOWARD P. FOLEY COMPANY
NONCONFORMANCE REPORT - CONTINUATION SHEET

NO.
8802-871 Rev.2

CONTINUATION OF: DESCRIPTION OF NONCONFORMANCE ☒
PROPOSED DISPOSITION ☐
DISPOSITION ACCOMPLISHED ☐

PAGE 2 OF 2

DATE 10-13-83

H.P. FOLEY DISPOSITION: (Continued)

- 4) Accept rod size "As Is" if visual inspection is acceptable.
 - a) Remove and replace weld if lack of fusion is noted.
- 5) Accept Ht.# "As Is" - Only acceptable filler material is issued to the Rod Control Station.
- 6) Revise QCP-5A to require the Electrical Welder to enter Size, Heat No., and Type of rod used on the applicable "Work Copy" documentation. Q.C. to verify it's entry.
- 7) Record this NCR Number on affected SIWS's or WIS's.
- 8) Accept missing WPS No. "As Is" based on Item #1), above.

WORK COPY

QCE: