

NOV 25 1987

Docket No. 50-344

Portland General Electric Company  
121 S. W. Salmon Street  
Portland, Oregon 97204

Attention: Mr. David W. Cockfield  
Vice President, Nuclear

SUBJECT: NRC INSPECTION OF THE TROJAN NUCLEAR PLANT

This refers to the unannounced routine inspection conducted by Mr. C. Ramsey of this office on September 21 through 25, 1987, of activities authorized by NRC license No. NPF-1 and to the discussion of our findings held with members of your staff at the conclusion of the inspection.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Based on the results of this inspection, it appears that certain of your activities were not conducted in full compliance with NRC requirements, as set forth in the Notice of Violation, enclosed herewith as Appendix A. Your response to this Notice is to be submitted in accordance with the provisions of 10 CFR 2.201.

Furthermore, although the efforts you are taking to achieve compliance with the requirements of Appendix R to 10 CFR 50 are recognized by the NRC, a number of other issues raised in this report regarding implementation of your fire protection program are considered to be significant. We wish to re-emphasize to you the importance that the NRC places on effective implementation of the routine fire protection program. You are requested to include in your response your position regarding the following additional issues discussed in the report:

1. Fire pump testing in accordance with governing code design criteria (paragraph 3.B(2)).
2. Use of the offsite Fire Department to provide a backup water supply to the Service Water System (paragraph 4B).

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC Public Document Room.

The response directed by this letter and the accompanying Notice is not subject to the clearance procedure of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

8712100257 871125  
PDR ADDOCK 05000344  
Q PDR

11  
IEOI

NOV 25 1987

-2-

Should you have any questions concerning this inspection, we will be glad to discuss them with you.

Sincerely,

*Original Signed*  
Robert J. Pate, Chief  
Reactor Safety Branch

Enclosures:

- A. Notice of Violation
- B. Inspection Report No. 50-344/87-34

cc w/enclosures:

- C. Olmstead, PGE
- J. W. Durham, PGE
- W. Dixon, DOE

bcc w/enclosures:

- RSB/Document Control Desk (RIDS) (IE01)
- D. Persinko, NRR
- Project Inspector
- Resident Inspector
- G. Cook
- B. Faulkenberry
- J. Martin
- Docket File

bcc w/o enclosure B:

- LFMB
- M. Smith

Region V

REQUEST COPY	REQUEST COPY	REQUEST COPY	REQUEST COPY
<input checked="" type="checkbox"/> YES / NO	<input checked="" type="checkbox"/> YES / NO	YES / <input checked="" type="checkbox"/> NO	<input checked="" type="checkbox"/> YES / NO
			SEND TO PDR
			<input checked="" type="checkbox"/> YES / NO

  

<i>CR</i> CRamsey/norma 11/24/87	<i>RPate/for</i> SRichards 11/24/87	<i>K</i> AJohnson 11/25/87	RPate <i>RP</i> 11/24/87
--	---	----------------------------------	-----------------------------