



Point Beach Nuclear Plant  
6610 Nuclear Rd., Two Rivers, WI 54241

(920) 755-2321

NPL 98-0647

10 CFR 50.73

July 31, 1998

Document Control Desk  
U.S. NUCLEAR REGULATORY COMMISSION  
Mail Station P1-137  
Washington, DC 20555

Ladies/Gentlemen:

DOCKET 50-266  
LICENSEE EVENT REPORT 1998-021-00  
MISSSED SURVEILLANCES REQUIRED BY THE ASME SECTION XI  
INSERVICE TEST PROGRAM  
POINT BEACH NUCLEAR PLANT, UNIT 1

Enclosed is Licensee Event Report 1998-021-00 for Point Beach Nuclear Plant, Unit 1. This report is provided in accordance with 10 CFR 50.73(a)(2)(i)(B), an "operation prohibited by the plant's Technical Specifications." This report describes the discovery that ASME Section XI inservice stroke tests were not performed on four valves within the required time frame.

New commitments in this report are indicated in italics.

Please contact us if you require additional information.

Sincerely,

A handwritten signature in cursive script, appearing to read 'Vito A. Kaminskas'.

Vito A. Kaminskas  
Manager,  
Regulatory Services & Licensing

JG/dms

Enclosure

cc: NRC Resident Inspector  
NRC Regional Administrator  
PSCW  
INPO Support Services

9808110076 980731  
PDR ADOCK 05000266  
S PDR

IE221