



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

WISCONSIN ELECTRIC POWER COMPANY

DOCKET NO. 50-266

POINT BEACH NUCLEAR PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 109
License No. DPR-24

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Wisconsin Electric Power Company (the licensee) dated August 26, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8712150133 871203
PDR ADOCK 05000266
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

WISCONSIN ELECTRIC POWER COMPANY

DOCKET NO. 50-301

POINT BEACH NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 112
License No. DPR-27

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Wisconsin Electric Power Company (the licensee) dated August 26, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-24 is hereby amended to read as follows:

E. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 109, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective immediately upon issuance. The Technical Specifications are to be implemented within 20 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David L. Wigginton, Acting Director
Project Directorate III-3
Division of Reactor Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 3, 1987


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-27 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 112, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective immediately upon issuance. The Technical Specifications are to be implemented within 20 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David L. Wigginton, Acting Director
Project Directorate III-3
Division of Reactor Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 3, 1987

ATTACHMENT TO LICENSE AMENDMENT NOS. 109 AND 112
TO FACILITY OPERATING LICENSE NOS. DPR-24 AND DPR-27
DOCKET NOS. 50-266 AND 50-301

Revise the Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

Appendix A

REMOVE

page 15.4.11-2

INSERT

page 15.4.11-2

Appendix B

page 16.1-1
page 16.1-3

page 16.1-1
page 16.1-3

- c. Halogenated hydrocarbon testing of the charcoal adsorber bank shall be performed after each complete or partial replacement of charcoal adsorbers or after any structural maintenance of the adsorber housing. Halogenated hydrocarbon testing shall be at design velocity $\pm 20\%$.
- d. Laboratory sample analysis of in-place charcoal adsorbent shall be performed at least once per year for standby service or after every 720 hours of system operation and, as a minimum, shall be conducted at velocities within 20% of design, 1.75 mg/m^3 inlet iodide concentration, 95% relative humidity and 30°C (86°F).
- e. Fans shall be tested at least once per year or after 720 hours of operation since the previous test, and following fan maintenance or repair.

Basis

The control room emergency filtration system is designed to filter the control room atmosphere and makeup air to the control room during control room isolation conditions. The control room emergency filtration is normally isolated and not in operation and testing more frequently than that specified is not required to insure operability or performance. If the efficiencies of HEPA and charcoal adsorbers are as specified, the resulting control room doses during accident conditions will be less than allowable levels in Criterion 19 of Appendix A to 10 CFR 50.

16. NONRADIOLOGICAL TECHNICAL SPECIFICATIONS

16.1 Definitions

The definitions for terms used in these Nonradiological Technical Specifications for Units 1 and 2 are stated below.

WPDES Permit

The WPDES permit is the Wisconsin Pollutant Discharge Elimination System Permit No. WI-0000957 issued by the State of Wisconsin Department of Natural Resources for the Wisconsin Electric Power Company, Point Beach Nuclear Plant, and as subsequently amended.

16.5 Reporting Requirements

Specification

1. As part of the Semiannual Monitoring Report, described in Section 15.7.8.4.A of Appendix A, the following shall be reported:
 - a. All scheduled and unscheduled chemical discharge to the condenser cooling water.
 - b. A description of circulating water system operation for each unit which includes ambient temperature, intake temperature, discharge temperature, and circulating water system flow.