



Commonwealth Edison
960 North Route 47
Morris, Illinois 60450

May 22, 1985

50-373

50-374

John B. Hickman
Reactor Safety Engineer
United States Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: ERDS TEST AT LA SALLE NUCLEAR POWER STATION

Dear John:

As per our agreement regarding the transmission of station computer parameter data for the ERDS Test scheduled for July, 1985 the attached lists identifies those computer points.

In addition, the specifications for parameter data transmissions are as follows:

- 1) Frequency - once per minute
- 2) Baud rate - 1200 via telephone line
- 3) Format - ASCII language Asynchronous, 8-Bit,
no parity with one stop Bit
- 4) The transmission will consist of a Leader (16 characters) and all of the analog values (20 characters each, and the Follower (5 characters)

a. The 16 character Leaders consist of:

- 1 Unique beginning character
- 2 Station identification characters.
LS for La Salle Nuclear Power Station
- 1 Reactor Number character, 1 or 2 or 3
- 1 Decimal Point character
- 6 Date character. YEAR, MONTH, DAY (YYMMDD)
- 1 Decimal Point character
- 4 Time characters. 24 hour clock (HHMM)

Example for a 16 character leader for
La Salle 2 on May 19, 1985 at 1425 (2:25 p.m.)

✓ L S 2 . 8 5 0 5 1 9 . 1 4 2 5

b. All of the 20 character analog values will consist of:

- 6 Sensor Data Base point identifications Alpha Numeric characters (Left Justified)
- 10 Analog value characters (+ . 1 2 3 4 E ± 0 0)
- 4 Status word characters in HEX format

May 22, 1985

ERDS TEST AT LA SALLE NUCLEAR POWER STATION

Page 2 of 3

Example for 20 character analog value for computer point C014 SPDS-Reactor Pressure having a value of +1500 psig that is in High Alarm.

C 0 1 4 0 0 + . 1 5 0 0 E + 0 4 0 0 0 4

- c. The Follower will consist of:
4 HEX character check sum
1 Unique ending character

Example for a 5 character Follower:

3 F A 6 \

- 5) The software program uses an X-ON and X-OFF format.
- 6) Plant parameter data from the PRIME, are the most current at the moment of transmission, except for the scenario data.
- 7) To initiate the test personnel at La Salle will contact the NRC Operations Center Office in Maryland and establish a telephone link. Data transmission will be as follows:
 - a. Real plant parameter data will be initially transmitted for a short period of time to be able to assure both CECO and NRC programs are operational.
 - b. La Salle July, 1985 GSEP Scenario parameter data will then be transmitted for the duration of the exercise.
 - c. Real plant parameter data will follow the Scenario data for a short period of time to indicate the return to a normal condition. This will terminate the ERDS Test.
- 8) As originally discussed, 15 minute averaged meteorological data was requested. For real plant parameters this is possible, however, the Scenario program can not handle 15 minute averages, instead it has the one minute values. Thus, the one minute averages will be used in the scenario.

May 22, 1985

ERDS TEST AT LA SALLE NUCLEAR POWER STATION

Page 2 of 3

If you have any problems, concerns or questions, please contact me as soon as possible at Mazon EOF, Dresden extension 753. CECO computer personnel have started software development and if there are any changes I need to inform them so that our target data of the test is achieved.

Prepared By:

Larry W. Duchek
Larry W. Duchek
Emergency Planning
Supervisor

Approved By:

John C. Golden
John C. Golden
Supervisor
Emergency Planning

LWD:wjm

CC: D.L. Farrar
N.E. Wandke
L.D. Butterfield
J.C. Golden
B.B. Stephenson
L.D. Thompson
G.J. Diederich
C. Gains
P. Tebbe
T.G. Blackmon

EOF-#85-5-151
1222A

LA SALLE BWR PARAMETERS

REACTOR COOLANT SYSTEMS

<u>COMPUTER POINT</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
C014 ✓	SPDS-Reactor Pressure	PSIG
C013 ✓	SPDS-Reactor Level	INCHES
C188 ✓	FW LOOP Branch A	M#/H
C189 ✓	FW LOOP Branch B	M#/H
C019 ✓	SPDS-Reactor Power	%
A840	Total Rx FW FLOW	M#/H
C000	TOTAL FEEDWATER FLOW	M#/H

SAFETY INJECTION SYSTEMS

A806 ✓	HPCS PMP Discharge Flow	GPM
A808 ✓	LPCS PUMP DISCH Flow	GPM
A800	RHR PUMP 2A DISCH Flow	GPM
A801	RHR PUMP 2B DISCH Flow	GPM
A802	RHR PUMP 2C DISCH Flow	GPM

CONTAINMENT SYSTEMS

C015 ✓	SPDS - DW PRESS	PSIG
C016 ✓	SPDS - DW TEMP	DEGF
A810	DW H2 Concentration	%
A837	DW H2 Concentration	%
C018 ✓	SPDS-SUPP TEMP	DEGF
C017 ✓	SPDS-SUPP LVL	FEET

RADIATION MONITORING SYSTEMS

C102 ✓	SPDS-Containment Rad	KR/HR
C218 ✓	SPDS-OFF-GAS Radiation	R/HR
A827	STN VNT STACK GAS-HIGH RNG	uCi/CC
A825 ✓	STN VNT STACK GAS-LOW RNG	uCi/CC
A826	STN VNT STACK GAS-MID RNG	uCi/CC
A836 ✓	STN VNT STACK FLOW	KCFM
A830	SGTS EFF GAS HIGH	uCi/CC
A834	SGTS EFF GAS LOW	uCi/CC
A833	SGTS EFF GAS MID	uCi/CC
A832	SGTS EFF IODINE	KC/M
A831	SGTS EFF PARTICULATE	KC/M
A813 ✓	SGTS TRAIN INLET FLOW	CFM

Attachment - Ltr. EOF#85-5-151

1222A/wjm

LA SALLE BWR PARAMETERS

RADIATION MONITORING SYSTEMS (cont'd)

A946	RHR SERV WTR Loop A	RAD	KC/SEC
A922	RHR SERV WTR Loop B	RAD	KC/SEC
D952	MAIN STEAM RAD DIV A1		
D953	MAIN STEAM RAD DIV A2		
D992	MAIN STEAM RAD DIV B1		
D993	MAIN STEAM RAD DIV B2		
A815 ✓	Rx Bldg HCU MOD NO ARM		MR/HR
A816 ✓	Rx Bldg HCU MOD SO ARM		MR/HR
A817	Rx Bldg HPCS PUMP ARM		MR/HR
A822 ✓	Rx Bldg RCIC TURB ARM		MR/HR
A821 ✓	Rx Bldg RHR H-XCH NW ARM		MR/HR
A820 ✓	Rx Bldg RHR H-XCH SE ARM		MR/HR
A819	Rx Bldg Standby Gas ARM		MR/HR
A921	Service Water Effluent RAD		KC/SEC

METEOROLOGICAL SYSTEMS

P010 ✓	15-Min AVG 200 ft WS	M/SEC
P011	15-Min AVG 33 ft WS	M/SEC
P009	15-Min AVG 375 ft WS	M/SEC
P004 ✓	15-Min AVG 200 ft WD	DEGREES
P005	15-Min AVG 33 ft WD	DEGREES
P003	15-Min AVG 375 ft WS	DEGREES
P013 ✓	15-Min AVG Delta Temp 33/200	DEGF/ft
P012	15-Min AVG Delta Temp 33/375	DEGF/ft
C066	MIN AVG 375 FT WIND DIR	DEG
C067	MIN AVG 200 FT WIND DIR	DEG
C068	MIN AVG 33 FT WIND DIR	DEG
C069	MIN AVG 375 FT WIND VEL	M/sec
C070	MIN AVG 200 FT WIND VEL	M/sec
C071	MIN AVG 33 FT WIND VEL	M/sec
A851	DIFF TEMP AT 33 FT/375	DEGF/FT
A855	DIFF TEMP AT 33 FT/200	DEGF/FT

Attachment - Ltr. EOP#85-5-151

1222A/wjm

5/20

LaSalle

when completed

TABLE 2
BWR PARAMETER LIST

Primary Coolant
System

- Reactor pressure
- Reactor vessel level
- Feedwater flow
- Neutron flux - startup range

Safety Injection

- RCIC flow
- HPCI/HPCS flow
- Core spray flow
- LPCI flow
- Condensate storage tank level

Containment

- Drywell pressure
- Drywell temperatures
- Hydrogen and oxygen concentration
- Drywell sump levels
- Suppression pool temperature
- Suppression pool level

Radiation Monitoring
System

- Reactor coolant radioactivity level
- Primary containment radiation level
- Condenser off-gas radiation level
- Effluent radiation monitor
- Process radiation levels

Meteorological

- Wind speed
- Wind direction
- Atmospheric stability

BWR PARAMETER

Reactor Coolant System

Reactor Pressure. (LaSalle) GE

A906 - Rx Pressure NR — PSIG
A907 - Rx Pressure WR — PSIG
A934 - Rx Pressure WR — PSIG
C014 - SPDS-Rx Press — PSIG
C147 - SPDS-Rx Press Rate Change — PSI/M

Reactor Vessel level. (LaSalle.)

A905 Rx WTR LVL FUEL ZONE — INCHES
A933 Rx WTR LVL FUEL ZONE — INCHES
A902 Rx WTR LVL NR — INCHES
A839 Rx WTR LVL WR — IN
A903 Rx WTR LVL WR LVL 2 — IN
A904 Rx WTR LVL WR LVL 2 — IN
A932 " " " " " " — IN
A948 " " " " " " — IN
C013 SPDS Rx Level — INCHES
C146 SPDS Rx Level Rate Change — IN/M

Feedwater Flow (LaSalle.)

B728 Feedpump A Discharge Flow M³/H
B729 Feedpump B Discharge Flow M³/H
C188 FW LOOP BRANCH A M³/H
C189 FW LOOP BRANCH B M³/H.

Neutron flux Startup Range (LaSalle)

F480 } SRM CH A LOG COUNT RATE C/SEC
F477 } SRM CH A PERIOD ~~SEC~~ SEC
F481 } " CH B " "
F478 } " CH B " "
F482 } " CH C " "
F479 } " CH C " "

Safety Injection

RCIC Flow (LaSalle)

This information is not available thru the computer at LaSalle County Station.

HPCI Flow (LaSalle) "HPCS"

A806 HPCS PMP DISCHARGE Flow - GPM.

Core Spray Flow (LaSalle)

(This information is not available thru the computer at LaSalle County Station.)

A808 - LPCS PUMP DISCH Flow - GPM

LPCI Flow (LaSalle)

A800 - RHR PUMP 2A DISCH Flow - GPM

A801 RHR PUMP 2B DISCH Flow - GPM

A802 RHR PUMP 2C DISCH Flow - GPM

F473 Rx Hand Spray flow - GPM

Condensate Storage Tank Level (LaSalle)

This information is not available thru the computer at LaSalle County Station.

Containment

Drywell Pressure

L118 Drywell Pressure PSIG

A910 Drywell Pressure NR PSIG

A936 Drywell Pressure NR PSIG

C015 SPDS - DW PRESS PSIG

C148 SPDS - DW PRESS RATE CHANGE PSI/M

Drywell Temperature

A924 DW AIR TEMP DEG F

A925 " " " "

A949 " " " "

A950 " " " "

C016 SPDS DW TEMP DEG F

C149 SPDS DW TEMP RATE CHANGE DEG F/M

Hydrogen + Oxygen Concentration

A810 DW H2 Concentration %

A837 " " " %

Oxygen Concentration in DW is not available thru the Computer at LaSalle Station.

Drywell Sump Level

This information is not available thru the computer at
LeSalle County Station.

Suppression Pool Temperature

L122	SUPP POOL WATER TEMP	NW	DEG F
L123	"	SE	DEG F
A912	Supp. Pool Water Temp		DEG F
then	"	"	"
A918	"	"	"
A938	"	"	"
then	"	"	"
A944	"	"	"
C018	SPDS SUPP TEMP		"
C151	SPDS SUPP TEMP RATE CHANGE		DEG/M

14 points

Suppression Pool Level

A937	SUPP POOL WTR LVL	FEET
L124	SUPP POOL WTR LVL	IN.
A911	SUPP POOL LVL	FEET
C017	SPDS - SUPP LVL	FEET
C150	SPDS - SUPP LVL RATE CHANGE	FEET

Radiation Monitoring Systems

Reactor Coolant Radioactivity level

This information is not available thru the computer at
LeSalle County Station

Primary Containment Radiation level.

AB14	DW Gross Gamma Rad	KR/HR
AB36	"	KR/HR
C102	SPDS - Containment Rad	KR/HR

Condenser Off-Gas Radiation levels

C218	SPDS - Off Gas Radiation	R/HR
A919	Off-Gas RAD	R/HR
A945	Off Gas RAD	R/HR

Effluent Radiation Monitor

A827	STU. UNT	STACK GAS - High Range	uCi/cc
A825	"	" " " " " Lo "	uCi/cc
A826	"	" " " " " Mid "	uCi/cc
A838	STU UNT	STACK FLOW	uCi/cc
C217	- SPDS -	GAS EFFLUENT RAD.	uCi/sec.
A830	SGTS	EFF GAS HIGH	uCi/cc
A834	"	" " " " " Low	uCi/cc
A833	"	" " " " " Mid	uCi/cc
A832	SGTS	EFF IODINE	Kc/M
A831	"	" " PARTICULATE	Kc/M
A813	SGTS	TRAIN INLET FLOW	CFM

Process Radiation levels

A823	} ARM	MP/HR
A818		
A946	RHR SERV. WTR LOOP RAD	Kc/sec
A922	" " " " " RAD	"
A815 - A816 - A817	} ARM.	MP/HR
A822 - A821 - A820 A819		
D952/D953/D992/D993	Main Steam Rad Div A1, A2 B1, B2	

Meteorological

Wind Speed

A850	WS at 200 ft	M.P.H.
A852	WS at 33 ft	"
A844	WS at 375 ft	"
C070	MIN AVG 200 WIND VEL.	M/S
C071	" " 33 " "	M/S
C069	" " 375 " "	M/S.
P010	15 MIN AVG 200 FT WS	M/sec
P011	" " " 33 " "	M/sec
P009	" " " 375 " "	M/sec

WIND

DIRECTION

P004	15-MIN AVG 200 FT WD	Degrees.
P005	" " 33 WD	"
P003	" " 375 WD	"
A848	WD at 200 ft	"
A853	WD at 33	"
A847	WD at 375	"
C067	WD at 200	"
C068	WD at 33	"
C069	WD at 375	"

atmosphere stability

A BSS	-	Delta Temp.	33/200	DEGF/F
ABSI	-	Delta Temp.	33/375	DEGF/F
P013		15-min Avg. Delta Temp.	33/200	Deg. F/ft
P012		" " " "	33/375	Deg F/ft.
P007		15-MIN STD. DEU	WD. 200	Degrees
P008		" " " "	33	Degrees
P006		" " " "	375	Degrees.

4/24/85

Send data once / minute

For test - dial up access

For test :

- 1) set up line
- 2) send live plant data
- 3) break
- 4) send scenario data
- 5) break
- 6) send live data

Larry Duckert (212) 294-3285

Mel Gehrs - (Larry Thompson's Boss ?)

~~Patty~~ Patty Tebby

Capture in File Bell 212 / 1200 Baud ?
Yes

Do we need flow control or can we
continuously capture Need flow control

Propose to send ASCII characters OK

Will call @ 4:30

X-ON X-OFF → OK

Non-bit parity ?


4/10

Com Ed Mtg

Larry Duckert
Terry Blackmon

- 1) Review Parameter List.
- 2) Line up ADP expert and trip
to Com Ed or telecon.

Talk to Larry on Monday



OPS CTR
 ★ Dial up; ask
 for our parameters.

Quad Cities Aug. 26-28

need to get Bill NPA bill
 before Quad Cities

- Can you be
- U. S. ... Center
- Trans ... expense.

ROUTING AND TRANSMITTAL SLIP		ACTION	
1 TO (Name, office symbol or location)		INITIALS	CIRCULATE
Ken Perkins		DATE	COORDINATION
		INITIALS	FILE
2 John Hickman Action		DATE	INFORMATION
3		INITIALS	NOTE AND RETURN
		DATE	PER CON - VERBATION
4		INITIALS	SEE ME
		DATE	SIGNATURE
REMARKS			
Cordell Reed of CE has agreed to ERDS testing. Contacts are Norm Wandke, Asst VP Nuclear Service and Del Butterfield Tech Service, John Golden E.P. I know the first two - <u>Lets meet before or after April 3-4</u> Do NOT use this form as a RECORD of approvals, concurrences, disapprovals, clearances, and similar actions.			
FROM (Name, office symbol or location)		DATE	
Ed Jordan		PHONE	

OPTIONAL FORM 41
AUGUST 1967
GSA FPMR (41CFR) 101-11.206

GPO 640-10-61418-1 419-016 5041-101