

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)

BIG ROCK POINT PLANT

DOCKET NUMBER (2)

0 5 0 0 0 1 5 5 1 OF 0 3

PAGE (3)

TITLE (4)

Technical Specification Violation - Limit for CRD Withdraw Time

EVENT DATE (5)

LER NUMBER (6)

REPORT DATE (7)

OTHER FACILITIES INVOLVED (8)

| MONTH | DAY | YEAR | YEAR | SEQUENTIAL NUMBER | REVISION NUMBER | MONTH | DAY | YEAR | FACILITY NAMES | DOCKET NUMBER(S) | | | | | | | | | | |
|-------|-----|------|------|-------------------|-----------------|-------|-----|------|----------------|------------------|---|---|---|---|---|---|---|---|-----|-----------|
| 1 | 1 | 2 | 2 | 8 | 7 | 8 | 7 | 0 | 1 | 3 | 0 | 0 | 1 | 2 | 2 | 2 | 8 | 7 | N/A | 0 5 0 0 0 |

OPERATING MODE (9)

N

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5. (Check one or more of the following) (11)

20.402(b)

20.405(a)

50.73(a)(2)(iv)

73.71(b)

POWER LEVEL (10)

0.00

20.405(a)(1)(i)

50.36(a)(1)

50.73(a)(2)(v)

73.71(a)

20.405(a)(1)(ii)

50.36(a)(2)

50.73(a)(2)(vi)

OTHER (Specify in Abstract below and in Text, NRC Form 300A)

20.405(a)(1)(iii)

50.73(a)(2)(i)

50.73(a)(2)(vii)(A)

20.405(a)(1)(iv)

50.73(a)(2)(ii)

50.73(a)(2)(vii)(B)

20.405(a)(1)(v)

50.73(a)(2)(iii)

50.73(a)(2)(viii)

LICENSEE CONTACT FOR THIS LER (12)

NAME

CRAbel or RJAlexander

TELEPHONE NUMBER

AREA CODE

6 1 6 5 4 7 - 6 5 3 7

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

| CAUSE | SYSTEM | COMPONENT | MANUFACTURER | REPORTABLE TO NRC | CAUSE | SYSTEM | COMPONENT | MANUFACTURER | REPORTABLE TO NRC |
|-------|--------|-----------|--------------|-------------------|-------|--------|-----------|--------------|-------------------|
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If you, complete EXPECTED SUBMISSION DATE)

X NO

EXPECTED SUBMISSION DATE (15)

MONTH DAY YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During a reactor startup on November 22, 1987 (1047 hours) three (3) control rod drives were observed to have "double" notched during withdrawal. Startup was immediately terminated and all control rods inserted to allow investigation of the problem.

On November 22, 1987 (1743 hours) during performance of Control Rod Drive Timing tests, two (2) control rod drives were found to have withdraw times of 21.7 and 22.6 seconds. These values exceeded the Big Rock Point Technical Specification 5.2.2(a)(iv) minimum withdraw time of 23 seconds.

Further investigation concluded that the CRD timing is affected by recirculating pump valve position and flowrate. All thirty-two (32) control rod drives were timed and reset to acceptable values with the recirculating pumps at full flow.

At 0105 hours on November 23, 1987, reactor startup commenced.

8712290113 871222
PDR ADOCK 05000155
S PDR

FE 22
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

| | | | | | | | |
|---|--|----------------|-------------------|-----------------|----------|-----|--|
| FACILITY NAME (1) Big Rock Point Plant | DOCKET NUMBER (2) 0 5 0 0 0 1 5 5 8 7 | LER NUMBER (6) | | | PAGE (3) | | |
| | | YEAR | SEQUENTIAL NUMBER | REVISION NUMBER | | | |
| | | 0 1 3 | 0 0 | 0 2 | OF | 0 3 | |

TEXT (If more space is required, use additional NRC Form 366A's) (17)

Description of Event

During a reactor startup on November 22, 1987 (1047 hours) following a planned maintenance outage, three (3) control rod drives (AA) were observed to have "double" notched during withdrawal. Not knowing the cause, reactor startup was immediately terminated and all control rods were inserted to allow investigation of the problem.

On November 22, 1987 (1743 hours), the control rod drive performance test; Part C "CRD Timing and Rate Set Valve Positions" was conducted. Results showed that drives experiencing "double" notching had "fast" withdrawal times and two (2) control rod drives were found to have withdraw times of 21.7 and 22.6 seconds. These values exceeded the Big Rock Point Technical Specification 5.2.2(a)(iv) minimum withdraw time limit of 23 seconds.

Cause

Big Rock Point Plant's control rod drive maneuvering system uses discharge pressure from the control rod drive pumps to the control rod drive piston and the discharged water during piston movement is returned to the suction of the primary system recirculating pumps. This differential pressure established causes drive withdrawal and insertion depending on valve manipulations performed by control room operators. Rate set valves are included in the insert and withdraw headers to control the speed of drive movement.

The control rod drive timing tests are performed during the Refueling Outages as required by Technical Specification 5.2.2(a). These tests are normally performed with the primary system at atmospheric pressure and the recirculating pumps out of service. Investigation following the November 22, 1987 event showed that slight increased drive speed occurred with the recirculating pumps inservice. Tests were then performed with variations of recirculating pump valve positions (to vary flow) and found that withdraw speeds were affected. The apparent reason for this increased speed is that under full flow pump operation the differential pressure is somewhat greater across the drive piston.

Corrective Actions Taken

All affected drives were retimed on November 23, 1987 with the most conservative plant conditions; recirculating pumps inservice and at full flow. The drives were also "jog" tested to insure no "double-notching" would occur.

Corrective Action to Prevent Recurrence

1. Further evaluation and testing will be performed prior to and during the 1988 Refueling Outage to determine the effect of various system parameters on drive speed.

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

| | | | | | | | |
|---|--|----------------|----------------------|--------------------|----------|----|-----|
| FACILITY NAME (1) Big Rock Point Plant | DOCKET NUMBER (2) 0 5 0 0 0 1 5 5 8 7 | LER NUMBER (6) | | | PAGE (3) | | |
| | | YEAR | SEQUENTIAL NUMBER | REVISION NUMBER | | | |
| | | 8 7 | 0 1 3 | 0 0 | 0 3 | OF | 0 3 |

TEXT (If more space is required, use additional NRC Form 365A's) (17)

2. Following evaluation, procedure changes will be implemented where necessary to ensure drives are tested during limiting plant conditions.

Safety Assessment

Core physics analysis is performed to ensure that control rod withdraw does not exceed the maximum allowable deposited enthalphy specified by Exxon design report XN-NF-78-51. This analysis assumes a conservative rod withdraw time of .60 seconds. The minimum withdrawal time recorded in this event was 21.7 seconds which is greater than the limiting value of the physics analysis. This concludes that no damage to the fuel would occur even under the assumption that the drive was completely withdrawn in 21.7 seconds.



Consumers
Power

**POWERING
MICHIGAN'S PROGRESS**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

December 22, 1987

Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

DOCKET 50-155 - LICENSE DPR-6 - BIG ROCK POINT PLANT -
LICENSEE EVENT REPORT 87-013 - TECHNICAL SPECIFICATION VIOLATION - LIMIT
FOR CRD WITHDRAW TIME

Licensee Event Report (LER) 87-013 (Technical Specification Violation - Limit
for CRD Withdraw Time) is attached. This event is reportable to the NRC
per 10CFR50.73(a)(2)(i).

Ralph R Frisch
Senior Licensing Analyst

CC Administrator, Region III, NRC
NRC Resident Inspector - Big Rock Point Plant

Attachment

IE22
1/1