

DEC 22 1987

Docket No. 50-483

Union Electric Company  
ATTN: Mr. Donald F. Schnell  
Vice President - Nuclear  
Post Office Box 149 - Mail Code 400  
St. Louis, MO 63166

Gentlemen:

SUBJECT: Kukla Terminal Blocks (Reference: NRC EQ Inspection Report  
50-483/87015)

As requested by Region III, NRR completed a review of the EQ test documentation for Kukla terminal blocks used in 10 CFR 50.49 designated applications at Callaway. NRR concluded that qualification of the terminal blocks has been demonstrated. This conclusion is based, in part, on our understanding that the terminal blocks are not used in instrumentation circuits. This information was discussed and confirmed during a telephone conversation between Mr. M. Kopp of my staff and Mr. R. Haines of your staff on December 21, 1987.

Should you have any further questions please contact Mr. R. Gardner of my staff at (312) 790-5524.

Original signed by F. J. Jablonski (for)

J. J. Harrison, Chief  
Engineering Branch

cc: A. P. Neuhalfen, Manager Quality  
Assurance  
Tom P. Sharkey, Supervisor,  
Compliance  
DCD/DCB (RIDS)  
Licensing Fee Management Branch  
Resident Inspector, RIII  
Region IV  
Resident Inspector, Wolf Creek  
K. Drey  
Chris R. Rogers, P.E.  
Utility Division, Missouri  
Public Service Commission  
CFA, Inc.

RIII  
*ma* 12/24/87  
Kopp/jk  
12/22/87

RIII  
*rw*  
Westberg  
12/22/87

RIII  
*rw* *for*  
Gardner  
12/22/87

RIII  
*H*  
Harrison  
12/ /87

*for*  
*yes*

8712290136 871222  
PDR ADOCK 05000483  
PDR

1/0 IE28