35-23359-01MD August 14, 1987 PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-IV-87-37 This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region IV staff on this date. FACILITY: Syncor Corporation Licensee Emergency Classification: Notification of Unusual Event Oklahoma City, Oklahoma Alert Site Area Emergency General Emergency X Not Applicable SUBJECT: REPORT OF MOLYBDENUM-99 BREAKTHROUGH ON TECHNETIUM-99m GENERATOR The licensee reported that on the morning of August 14, 1987, they measured a breakthrough of Mo-99 during the first elution of a technetium-99m generator. The measured Mo-99 activity was a 24 mCi fraction of the estimated 3000-3200 mCi elution. None of the contaminated radiopharmaceutical was dispensed. The 2.7 Ci generator was manufactured by New England Nuclear, lot 8732-2F-37, expiration 8/26/87. The generator is being returned at the manufacturer's request for further analysis. Neither the licensee nor the NRC plans to issue a press release. The state of Oklahoma will be informed. Region IV received notification of this occurrence by telephone from the licensee at 11:00 a.m., 8/14/87. Region IV has informed NMSS. This information has been confirmed with a licensee representative. CONTACT: D. Blair Spitzberg, FTS 728-8191 DISTRIBUTION: MAIL: ADM: DMB (Original) Willste H. St. E/W MNBB DOT: (Trans only) Chairman Zech EDO OIA NMSS RES PA AEOD Comm. Bernthal Comm. Roberts OGC VIB FAX: INPO Comm. Carr MPA OE NSAC ACRS (Air SECY GPA CA Phillips Rights) PDR RRI NRR DCS NRC OC LICENSEE: (Reactor Licensee) Regional Offices transmitted via 5520 8/14/87 @ RIV: DYDRSS RDMartin RLBangart 4:00 p.m. 9/14/87 114/87 TE-34

8708240026 870814 PDR 1&E PNO-IV-87-037 PDR