

NEDO-24568  
81NED049R1  
CLASS I  
APRIL 1982  
REVISION 3

**MARK I CONTAINMENT PROGRAM  
PLANT UNIQUE LOAD  
DEFINITION  
ENRICO FERMI ATOMIC POWER  
PLANT: UNIT 2**

870B180187 870B14  
PDR ADDCK 05000341  
PDR

**GENERAL  ELECTRIC**

NEDO-24568

NEDO-24568  
81NEDO49R1  
Class 1  
April 1982  
Revision 3

MARK I CONTAINMENT PROGRAM

PLANT UNIQUE LOAD DEFINITION

ENRICO FERMI ATOMIC POWER PLANT: UNIT 2

This document prepared by personnel of  
Nuclear Services Engineering

Approved: A. E. Rogers  
A. E. Rogers, Manager  
Reactor Performance Analysis

Approved: R. J. Brandon  
R. J. Brandon, Manager  
Nuclear Services Engineering

---

NUCLEAR FUEL AND SERVICES DIVISION • GENERAL ELECTRIC COMPANY  
SAN JOSE, CALIFORNIA 95125

GENERAL  ELECTRIC

LEGAL NOTICE

The only undertakings of General Electric Company respecting information in this document are contained in the contract between Detroit Edison Company and General Electric Company for Mark I Containment Consulting Services, and nothing contained in this document shall be construed as changing the contract. The use of this information by anyone other than Detroit Edison Company, or for any purpose other than that for which it is intended, is not authorized; and with respect to any unauthorized use, General Electric Company makes no representation or warranty, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document.

## CONTENTS

	<u>Page</u>
ABSTRACT	
INTRODUCTION	1
LOCA PRESSURE AND TEMPERATURE TRANSIENTS	3
DBA VENT SYSTEM THRUST LOADS, ZERO $\Delta P$ AND OPERATING $\Delta P$	18
POOL SWELL TORUS VERTICAL LOADS	47
POOL SWELL IMPACT AND DRAG LOADS	56
VENT HEADER DEFLECTOR LOADS	65
DISTRIBUTION	73

## TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
EF 4.1.1-1	Plant Conditions at Instant of DBA Pipe Break (Operating $\Delta P$ )	6
EF 4.1.1-1a	Plant Conditions at Instant of DBA Pipe Break (Zero $\Delta P$ )	9
EF 4.1.2-1	Plant Conditions at Instant of IBA Pipe Break	12
EF 4.1.3-1	Plant Conditions at Instant of SEA Pipe Break	15
EF 4.2-1	Nomenclature for DBA Vent System Thrust Load Section	21
EF 4.2-2	Plant Conditions at Instant of DBA Pipe Break for Thrust Load Calculations (Zero $\Delta P$ )	23
EF 4.2-3	Plant Conditions at Instant of DBA Pipe Break for Thrust Load Calculations (Operating $\Delta P$ )	35
EF 4.3.9-1	Vent Header Deflector Load	69

## ILLUSTRATIONS

<u>Figure</u>	<u>Title</u>	<u>Page</u>
EF 4.1.1-1	DBA Containment Pressure Response (Operating $\Delta P$ )	7
EF 4.1.1-1a	DBA Containment Pressure Response (Zero $\Delta P$ )	10
EF 4.1.1-2	DBA Containment Temperature Response (Operating $\Delta P$ )	8
EF 4.1.1-2a	DBA Containment Temperature Response (Zero $\Delta P$ )	11
EF 4.1.2-1	IBA Containment Pressure Response	13
EF 4.1.2-2	IBA Containment Temperature Response	14
EF 4.1.3-1	DBA Containment Pressure Response	15
EF 4.1.3-2	DBA Containment Temperature Response	17
EF 4.2-1	Definition of Positive Thrust Loads	24
EF 4.2-2	Single Main Vent Forces (Zero $\Delta P$ )	26
EF 4.2-3	Vent Header Forces per Mitre Bend ( $7 \circ \Delta P$ )	27
EF 4.2-4	Single Downcomer Forces (Zero $\Delta P$ )	28
EF 4.2-5	Total and Net Vertical Forces (Zero $\Delta P$ )	29
EF 4.2-6	Single Main Vent Forces (Zero $\Delta P$ )	30
EF 4.2-7	Vent Header Forces per Mitre Bend (Zero $\Delta P$ )	31
EF 4.2-8	Single Downcomer Forces (Zero $\Delta P$ )	32
EF 4.2-9	Total and Net Vertical Forces (Zero $\Delta P$ )	33
EF 4.2-10	Pressure Time Histories (Zero $\Delta P$ )	34
EF 4.2-11	Pressure Time Histories (Zero $\Delta P$ )	35
EF 4.2-12	Single Main Vent Forces (Operating $\Delta P$ )	37
EF 4.2-13	Vent Header Forces per Mitre Bend (Operating $\Delta P$ )	38
EF 4.2-14	Single Downcomer Forces (Operating $\Delta P$ )	39
EF 4.2-15	Total and Net Vertical Forces (Operating $\Delta P$ )	40
EF 4.2-16	Single Main Vent Forces (Operating $\Delta P$ )	41
EF 4.2-17	Vent Header Forces per Mitre Bend (Operating $\Delta P$ )	42

## ILLUSTRATIONS (Continued)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
EF 4.2-18	Single Downcomer Pressures (Operating $\Delta P$ )	43
EF 4.2-19	Total and Net Vertical Forces (Operating $\Delta P$ )	44
EF 4.2-20	Pressure Time Histories (Operating $\Delta P$ )	45
EF 4.2-21	Pressure Time Histories (Operating $\Delta P$ )	46
EF 4.3.1-1	Net Torus Vertical Load (Operating $\Delta P$ )	50
EF 4.3.1-2	Net Torus Vertical Load (Zero $\Delta P$ )	51
EF 4.3.2-1	Average Submerged Pressure (Operating $\Delta P$ )	52
EF 4.3.2-2	Average Submerged Pressure (Zero $\Delta P$ )	53
EF 4.3.2-3	Torus Air Pressure (Operating $\Delta P$ )	54
EF 4.3.2-4	Torus Air Pressure (Zero $\Delta P$ )	55
EF 4.3.3-1	Pool Swell Displacement Distribution (Zero $\Delta P$ )	59
EF 4.3.3-2	Pool Swell Displacement Distribution (Operating $\Delta P$ )	60
EF 4.3.3-3	Pool Swell Velocity Distribution (Zero $\Delta P$ )	61
EF 4.3.3-4	Pool Swell Velocity Distribution (Operating $\Delta P$ )	62
EF 4.3.4-1	Longitudinal Vent Header Impact Velocity Distribution Based on EPRI Main Vent Orifice Test	63
EF 4.3.4-2	Longitudinal Time Delay Distribution Based on EPRI Main Vent Orifice Test	64
EF 4.3.9-1	Vent Header Load (Zero $\Delta P$ )	68

ABSTRACT

This document provides unique definition of specific containment loading conditions that would result from a postulated loss-of-coolant accident in the Enrico Fermi Atomic Power Plant: Unit Number 2. Transient information is provided for containment pressures and temperatures, vent system thrust, torus vertical loads, vent system pool swell impact loads and vent header deflector loads. The document has been prepared under the Mark I Containment Program to aid Detroit Edison Company in the performance of a containment structural evaluation.

## INTRODUCTION

This report provides specific transient loading information resulting from a postulated loss-of-coolant accident (LOCA) in the Enrico Fermi Atomic Power Plant: Unit Number 2. This report, in conjunction with the Mark I Containment Load Definition Report, was prepared for the Detroit Edison Company to use in the structural evaluation of the Mark I Containment system.

The following specific LOCA-related transient information is included:

- Pressure and temperature time histories for the drywell and wetwell (Operating and Zero  $\Delta P$ )
- Vent system thrust loads
- Net vertical pool swell loads and average submerged pressures on the wetwell
- Pool swell impact and drag loads on the vent system
- Vent header deflector loads.

Transient information is presented via a series of figures for each of the above areas. An alpha-numeric identification scheme was developed for the figures such that the alpha designation denotes the plant of interest, while the first three digits of the numeric designation denote the applicable discussion section in the Mark I Containment Program Load Definition Report (NEDO-21888).

Transient conditions presented in this report are results of plant unique testing and/or analysis for specific plant conditions that have been provided or requested by the aforementioned utility. Changes to those specific

plant conditions could result in changes to the transient information reported herein. If, after further review of this document, the responsible utility considers that such changes would be appropriate, the document can be modified accordingly.

NEDO-24568

LOCA Pressure and Temperature Transients

LOCA Pressure and Temperature Transients

This section provides the LOCA-induced pressure and temperature transients for the drywell and wetwell. The initial conditions for which the pressure and temperature responses were evaluated are also presented. Transient conditions are included for the design basis accident (DBA), intermediate break accident (IBA), and small break accident (SBA). The list of applicable figures and tables for this section is given on the following page.

The peak drywell pressure and temperature and the wetwell pressure and temperature at 30 sec are identified on the DBA containment pressure and temperature plots (Operating and Zero  $\Delta P$ ) (Figures 4.1.1-1, 4.1.1-1a, 4.1.1-2, and 4.1.1-2a).

The peak containment pressures, the containment temperatures at the end of RPV blowdown, and the containment pressures and temperatures at the time of ADS initiation are identified on the IBA and SBA containment pressure and temperature plots (Figures 4.1.2-1, 4.1.2-2, 4.1.3-1, and 4.1.3-2).

## ENRICO FERMI 2

PLANT UNIQUE PRESSURE/TEMPERATURE RESPONSE FIGURES AND TABLES

<u>Figure/Table Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Table EF 4.1.1-1	Plant Conditions at Instant of DBA Pipe Break (Operating $\Delta P$ )	Revision 3
Table EF 4.1.1-1a	Plant Conditions at Instant of DBA Pipe Break (Zero $\Delta P$ )	
Figure EF 4.1.1-1	DBA Containment Pressure Response (Operating $\Delta P$ )	
Figure EF 4.1.1-1a	DBA Containment Pressure Response (Zero $\Delta P$ )	
Figure EF 4.1.1-2	DBA Containment Temperature Response (Operating $\Delta P$ )	
Figure EF 4.1.1-2a	DBA Containment Temperature Response (Zero $\Delta P$ )	
Table EF 4.1.2-1	Plant Conditions at Instant of IBA Pipe Break (Operating and Zero $\Delta P$ )	
Figure EF 4.1.2-1	IBA Containment Pressure Response (Operating and Zero $\Delta P$ )	
Figure EF 4.1.2-2	IBA Containment Temperature Response (Operating and Zero $\Delta P$ )	
Table EF 4.1.3-1	Plant Conditions at Instant of SBA Pipe Break (Operating and Zero $\Delta P$ )	
Figure EF 4.1.3-1	SBA Containment Pressure Response	
Figure EF 4.1.3-2	SBA Containment Temperature Response	

Table EF 4.1.1-1

PLANT CONDITIONS AT INSTANT OF DBA PIPE BREAK  
(Operating  $\Delta P$ )

102% Licensed Power (MWh)	3358
Initial Suppression Pool Temperature ( $^{\circ}$ F)	70.0
Downcomer Submergence (ft)	3.33
Airspace Volume (ft <sup>3</sup> )	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Drywell	0.75
Wetwell	0.575




Figure EF 4.1.1-1. DBA Containment Pressure Response  
(Operating AP)




Figure 4.1.1-2. DBA Containment Temperature Response  
(Operating  $\Delta P$ )

Table EF 4.1.1-1a  
PLANT CONDITIONS AT INSTANT OF DBA PIPE BREAK  
 (Zero  $\Delta P$ )

102% Lic. .sed Power (Mwt)	3358
Initial Suppression Pool Temperature ( $^{\circ}$ F)	70.0
Downcomer Submergence (ft)	3.33
Airspace Volume (ft <sup>3</sup> )	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Drywell	0.75
Wetwell	0.75




Figure EF 4.1.1-1a DBA Containment pressure Response  
(Zero  $\Delta P$ )

NEDO-24568-03




Figure EF 4.1.1-2a DBA Containment Temperature Response  
(Zero  $\Delta P$ )

NEDO-24568-03

Table EF 4.1.2-1  
PLANT CONDITIONS AT INSTANT OF IIA PIPE BREAK

102% Licensed Power (Mwt)	3358
Initial Suppression Pool Temperature ( $^{\circ}$ F)	95
Downcomer Submergence (ft)	3.33
Airspace Volume (ft <sup>3</sup> )	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Drywell	Bounds both
Wetwell	zero and operating $\Delta P$ conditions




Figure EF 4.1.2-1. IBA Containment Pressure Response




Figure EF 4.1.2-2. IBA Containment Temperature Response

Table EF 4.1.3-1  
PLANT CONDITIONS AT INSTANT OF SBA PIPE BREAK

102% Licensed Power (Mwt)	3358
Initial Suppression Pool Temperature ( $^{\circ}$ F)	95
Downcomer Submergence (ft)	3.33
Airspace Volume (ft $^3$ )	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Drywell	Bounds both
Wetwell	zero and operating
	$\Delta P$ conditions




Figure EF 4.1.3-1. SBA Containment Pressure Response




Figure EF 4.1.3-2. SBA Containment Temperature Response

NEDO-24568

DBA Vent System Thrust Loads - Zero  $\Delta P$ , Operating  $\Delta P$

DBA Vent System Thrust Loads - Operating and Zero  $\Delta P$

This section provides thrust loads for the main vents, vent header, and downcomers resulting from the postulated DBA for plant operation at a positive and zero drywell-wetwell pressure differential. The list of applicable figures and tables for this section is given on the following page.

Revision 3

## ENRICO FERMI 2

PLANT UNIQUE DBA VENT SYSTEM THRUST LOAD FIGURES AND TABLES -  
ZERO AND OPERATING  $\Delta P$ 

<u>Figure/Table Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Table EF 4.2-1	Nomenclature for DBA Vent System Thrust Load Section	Revision 3
Table EF 4.2-2	Plant Conditions at Instant of DBA Pipe Break for Thrust Load Calculations (Zero $\Delta P$ )	
Table EF 4.2-3	Plant Conditions at Instant of DBA Pipe Break for Thrust Load Calculations (Operating $\Delta P$ )	
Figure EF 4.2-1	Definition of Positive Thrust Loads	
Figure EF 4.2-2	Single Main Vent Forces (0-5 secs) (Zero $\Delta P$ )	
Figure EF 4.2-12	Single Main Vent Forces (0-5 secs) (Operating $\Delta P$ )	
Figure EF 4.2-3	Vent Header Forces per Mitre Bend (0-5 secs) (Zero $\Delta P$ )	
Figure EF 4.2-13	Vent Header Forces per Mitre Bend (0-5 secs) (Operating $\Delta P$ )	
Figure EF 4.2-4	Single Downcomer Forces (0-5 secs) (Zero $\Delta P$ )	
Figure EF 4.2-14	Single Downcomer Forces (0-5 secs) (Operating $\Delta P$ )	
Figure EF 4.2-5	Total Vertical Forces, Net Vertical Force (0-5 secs) (Zero $\Delta P$ )	
Figure EF 4.2-15	Total Vertical Forces, Net Vertical Force (0-5 secs) (Operating $\Delta P$ )	
Figure EF 4.2-6	Single Main Vent Forces (0-30 secs) (Zero $\Delta P$ )	
Figure EF 4.2-16	Single Main Vent Forces (0-30 secs) (Operating $\Delta P$ )	
Figure EF 4.2-7	Vent Header Forces per Mitre Bend (0-30 secs) (Zero $\Delta P$ )	
Figure EF 4.2-17	Vent Header Forces per Mitre Bend (0-30 secs) (Operating $\Delta P$ )	
Figure 4.2-8	Single Downcomer Forces (0-30 secs) (Zero $\Delta P$ )	
Figure 4.2-18	Single Downcomer Forces (0-30 secs) (Operating $\Delta P$ )	

## ENRICO FERMI 2

PLANT UNIQUE DBA VENT SYSTEM THRUST LOAD FIGURES AND TABLES -  
ZERO AND OPERATING  $\Delta P$  (Continued)

<u>Figure/Table Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Figure EF 4.2-9	Total Vertical Forces, Net Vertical Force (0-30 secs) (Zero $\Delta P$ )	Revision 3
Figure EF 4.2-19	Total Vertical Forces, Net Vertical Force (0-30 secs) (Operating $\Delta P$ )	
Figure EF 4.2-10	Pressure Time Histories (0-5 secs) (Zero $\Delta P$ )	
Figure EF 4.2-20	Pressure Time Histories (0-5 secs) (Operating $\Delta P$ )	
Figure EF 4.2-11	Pressure Time Histories (0-30 secs) (Zero $\Delta P$ )	
Figure EF 4.2-21	Pressure Time Histories (0-30 secs) (Operating $\Delta P$ )	

Table EF 4.2-1  
NOMENCLATURE FOR DBA VENT SYSTEM THRUST LOAD SECTION

PDW	Drywell pressure
PWW	Wetwell airspace pressure
P1	Main vent pressure
P2	Vent header pressure
P3	Downcomer pressure
F1V1	Vertical force on a single main vent end cap
F1H1	Horizontal force on a single main vent end cap
F1V2	Vertical force on a single main vent mitre bend (applicable to Browns Ferry and Oyster Creek only)
F1H2	Horizontal force on a single main vent mitre bend (applicable to Browns Ferry and Oyster Creek only)
F2V	Vertical force on vent header (per mitre bend)
F2H	Horizontal force on vent header (per mitre bend)
F3V	Vertical force on a single downcomer mitre bend
F3H	Horizontal force on a single downcomer mitre bend


F4V	Vertical force on second mitre bend of a single downcomer (if applicable)
F4H	Horizontal force on second mitre bend of a single downcomer (if applicable)
F1V1T	Total main vent end cap vertical force = F1V1 x number of main vents
F1V2T	Total main vent mitre bend vertical force = F1V2 x number of main vents
F2VT	Total vent header vertical force = F2V x number of vent header mitre bends
F3VT	Total vertical force (first downcomer mitre bend) = F3V x number of downcomers
F4VT	Total vertical force (second downcomer mitre bend) = F4V x number of downcomers
FNETV	FNETV = F1V1T + F1V2T + F2VT + F3VT + F4VT
A <sub>VH</sub>	Vent header flow area
A <sub>VP</sub>	Total main vent flow area

Table EF 4.2-1 (Continued)  
NOMENCLATURE FOR DBA VENT SYSTEM THRUST LOAD SECTION

A <sub>DC</sub>	Total downcomer flow area
n <sub>1</sub>	Number of main vents
n <sub>2</sub>	Number of downcomers
n <sub>3</sub>	Number of vent header mitre bends
$\dot{m}_T$	Total mass flow rate
v <sub>1</sub>	Fluid velocity in main vent
v <sub>2</sub>	Fluid velocity in vent header
v <sub>3</sub>	Fluid velocity in downcomer
$\theta_1$	Angle of main vent with horizontal
$\theta_2$	Angle of first downcomer mitre bend with horizontal
$\theta_3$	Angle of second downcomer mitre bend with horizontal
$\alpha$	Angle of main vent mitre bend with horizontal
$\beta$	90° - (vent header mitre bend angle)

Table EF 4.2-2  
PLANT CONDITIONS AT INSTANT OF DBA PIPE BREAK FOR THRUST  
LOAD CALCULATIONS - ZERO  $\Delta P$

Thermal Power (102% of licensed) (MWh)	3358
Initial Suppression Pool Temperature ( $^{\circ}$ F)	70
Downcomer Submergence (ft)	3.33
Airspace Volume ( $\text{ft}^3$ )	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Operating ( $\Delta P$ ) DW-Ww	
Drywell	0.75
Wetwell	0.75



SECTION A-A

F<sub>1V1</sub> = VERTICAL FORCE ON MAIN VENT END CAP  
 F<sub>1H1</sub> = HORIZONTAL FORCE ON MAIN VENT END CAP  
 F<sub>2V</sub> = VERTICAL FORCE ON VENT HEADER (PER MITRE BEND)  
 F<sub>2H</sub> = HORIZONTAL FORCE ON VENT HEADER (PER MITRE BEND)  
 F<sub>3V</sub> = VERTICAL FORCE ON DOWNCOMER MITRE BEND  
 F<sub>3H</sub> = HORIZONTAL FORCE ON DOWNCOMER MITRE BEND

FORCES ARE SHOWN IN THEIR ASSUMED POSITIVE DIRECTION

Figure EF 4.2-1. Definition of Positive Thrust Loads

VENT SYSTEM THRUST LOADS FIGURES AND TABLES - ZERO ΔP

<u>Figure/Table Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Table EF 4.2-2	Plant Conditions at Instant of DBA Pipe Break for Thrust Load Calculations	Revision 3
Figure EF 4.2- 2	Single Main Vent Forces (0-5 sec)	
Figure EF 4.2- 3	Vent Header Forces per Mitre Bend (0-5 sec)	
Figure EF 4.2- 4	Single Downcomer Forces (0-5 sec)	
Figure EF 4.2- 5	Total Vertical Forces, Net Vertical Force (0-5 sec)	
Figure EF 4.2- 6	Single Main Vent Forces (0-30 sec)	
Figure EF 4.2- 7	Vent Header Forces per Mitre Bend (0-30 sec)	
Figure EF 4.2- 8	Single Downcomer Forces (0-30 sec)	
Figure EF 4.2- 9	Total Vertical Forces, Net Vertical Force (0-30 sec)	
Figure EF 4.2- 10	Pressure Time Histories (0-5 sec)	
Figure EF 4.2-11	Pressure Time Histories (0-30 sec)	




Figure EF 4.2-2. Single Main Vent Forces  
(Zero  $\Delta P$ )




Figure EF 4.2-3. Vent Header Forces Per Mitre Bend  
(Zero  $\Delta P$ )




Figure EF 4.2-4. Single Downcomer Forces  
(Zero  $\Delta P$ )




Figure EF 4.2-5. Total and Net Vertical Forces  
(Zero  $\Delta P$ )




Figure EF 4.2-6. Single Main Vent Forces  
(Zero  $\Delta P$ )




Figure 4.2-7. Vent Header Forces Per Mitre Bend  
(Zero  $\Delta P$ )




Figure EF 4.2-8. Single Downcomer Forces  
(zero  $\Delta P$ )




Figure EF 4.2-9. Total and Net Vertical Forces  
(Zero  $\Delta P$ )




Figure EF 4.2-10. Pressure Time Histories  
(Zero  $\Delta P$ )




Figure EF 4.2-11. Pressure Time Histories  
(Zero  $\Delta P$ )

Table EF 4.2-3

PLANT CONDITIONS AT INSTANT OF DBA PIPE BREAK FOR THRUST LOADCALCULATIONS - OPERATING ΔP

Thermal Power (102% of licensed) (MWt)	3358
Initial Suppression Pool Temperature (°F)	70
Downcomer Submergence (ft)	3.33
Airspace Volume (ft <sup>3</sup> )	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Drywell	0.75
Wetwell	0.575




Figure EF 4.2-12. Single Main Vent Forces  
(Operating  $\Delta P$ )




Figure EF 4.2-13. Vent Header Forces Per Mitre Bend  
(Operating  $\Delta P$ )




Figure EF 4.2-14. Single Downcomer Forces  
(Operating  $\Delta P$ )

NEDO-24568




Figure EF 4.2-15. Total and Net Vertical Forces (Operating  $\Delta P$ )




Figure EF 4.2-16. Single Main Vent Forces (Operating  $\Delta P$ )

NEDO-24568




Figure EF 4.2-17. Vent Header Forces Per Mitre Bend  
(Operating  $\Delta P$ )




Figure EP 4.2-18. Single Downcomer Forces  
(Operating  $\Delta P$ )




Figure EF 4.2-19. Total and Net Vertical Forces  
(Operating  $\Delta P$ )




Figure EF 4.2-20. Pressure Time Histories (Operating  $\Delta P$ )




Figure EF 4.2-21. Pressure Time Histories  
(Operating  $\Delta P$ )

NEDO-24568

Pool Swell Torus Vertical Loads


Revision 3

Pool Swell Torus Vertical Loads

This section provides the net torus vertical load and shell pressure histories resulting from the drywell air purge to the wetwell during the postulated DBA. The list of applicable figures for this section is given on the following page.

ENRICO FERMI 2  
POOL SWELL TORUS VERTICAL LOADS FIGURES

<u>Figure Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Figure EF 4.3.1-1	Net Torus Vertical Load (Operating $\Delta P$ )	Revision 3
Figure EF 4.3.1-2	Net Torus Vertical Load (Zero $\Delta P$ )	
Figure EF 4.3.2-1	Average Submerged Pressure (Operating $\Delta P$ )	
Figure EF 4.3.2.2	Average Submerged Pressure (Zero $\Delta P$ )	
Figure EF 4.3.2.3	Torus Air Pressure (Operating $\Delta P$ )	
Figure EF 4.3.2.4	Torus Air Pressure (Zero $\Delta P$ )	

Figure EF 4.3.1-1. Net Torus Vertical Load (Operating  $\Delta P$ )




Figure EF 4.3.1-2. Net Torus Vertical Load (Zero AP)




Figure EF 4.3.2-1. Average Submerged Pressure (Operating  $\Delta P$ )




Figure EF 4.3.2-2. Average Submerged Pressure (Zero  $\Delta P$ )




Figure EF 4.3.2-3. Torus Air Pressure (Operating  $\Delta P$ )




Figure EF 4.3.2-4. Torus Air Pressure (Zero AP)

NEDO-24568

Pool Swell Impact and Drag Loads

Pool Swell Impact and Drag Loads

This section provides the pool swell displacement and velocity distributions for evaluation of impact and drag loads on structures located above the pool. For the conditions specified and noted herein, the pool swell event does not produce impact or drag loading on the vent header. The list of applicable figures for this section is given on the following page.

## ENRICO FERMI 2

PLANT UNIQUE POOL SWELL IMPACT AND DRAG LOAD FIGURES

<u>Figure No.</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Figure 4.3.3-1	Pool Swell Displacement Distribution (Zero $\Delta P$ )	Revision 3
Figure 4.3.3-2	Pool Swell Displacement Distribution (Operating $\Delta P$ )	
Figure 4.3.3-3	Pool Swell Velocity Distribution (Zero $\Delta P$ )	
Figure 4.3.3-4	Pool Swell Velocity Distribution (Operating $\Delta P$ )	
Figure 4.3.4-1	Longitudinal Vent Header Impact Velocity Distribution Based on EPRI Main Vent Orifice Test	
Figure 4.3.4-2	Longitudinal Time Delay Distribution Based on EPRI Main Vent Orifice Test	




Figure EF 4.3.3-1. Pool Swell Displacement Distribution (Zero  $\Delta P$ )  
Radial Distance,  $X/R$




Figure EF 4.3.3-2. Pool Swell Displacement Distribution (Operating  $\Delta P$ )




Figure EF 4.3.3-3. Pool Swell Velocity Distribution (zero  $\Delta P$ )  
Radial Distance,  $X/R$




Figure EF 4.3.3-4. Pool Swell Velocity Distribution (Operating  $\Delta P$ )




Figure EF 4.3.4-1. Longitudinal Vent Header Impact Velocity Distribution Based on EPRI Main Vent Orifice Test




Figure EF 4.3.4-2 . Longitudinal Time Delay Distribution Based on EPRI Main Vent Orifice Test

NEDO-24568

Vent Header Deflector Loads

Pool Swell Vent Header Deflector Loads

This section provides the vent header deflector loads from the pool swell resulting from the drywell air purge to the wetwell during the postulated DBA.

The loads presented are full scale running load as a function of time from LOCA break, for three values of Z/L (distance along the deflector). Z/L = 0 corresponds to the middle of the vent bay and Z/L = 1.0 corresponds to the middle of the non-vent bay.

These loads were derived from the method discussed in the Mark I Containment Program Vent Header Deflector Load Definition (NEDO-24612).

ENRICO FERMI

PLANT UNIQUE POOL SWELL VENT HEADER DEFLECTOR LOADS

<u>Figure/Table Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Figure EF 4.3.9-1	Vent Header Deflector Load	Revision 3
Table EF 4.3.9-1	Vent Header Deflector Load	Revision 3


Figure EF 4.3.9-1. Vent Header Load (Zero  $\Delta P$ )

Table EF 4.3.9-1

VENT HEADER DEFLECTOR LOAD  
\*\*\*\*\*DEFLECTOR FULL SCALE LOADS\*\*\*\*\*

Fermi 2, Type 3 Deflector

Z/L=1.0		Z/L=0.5		Z/L=0.0	
Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)
380.89	.00	380.89	.00	380.89	.00
382.87	.00	382.87	.00	382.87	.00
384.86	.00	384.86	.00	384.86	.00
386.84	.00	386.84	.00	386.84	.00
388.83	.00	388.83	.00	388.83	.00
390.81	.00	390.81	.00	390.81	.00
392.79	.00	392.79	.00	392.79	.00
394.78	.00	394.78	.00	394.78	.00
396.76	.00	396.76	.00	396.76	.00
398.74	.00	398.74	.00	398.74	.00
400.73	.00	400.73	.00	400.73	.00
402.71	.00	402.71	.00	402.71	.00
404.70	.00	404.70	.00	404.70	.00
406.68	.00	406.68	.00	406.68	.00
408.66	1261.05	408.66	.00	408.66	.00
410.65	1122.33	410.65	.00	410.65	.00
412.63	951.00	412.63	.00	412.63	.00
414.62	751.16	414.62	1172.77	414.62	.00
416.60	615.05	416.60	1053.58	416.60	.00
418.58	674.44	418.58	909.58	418.58	.00
420.57	739.39	420.57	735.07	420.57	.00
422.55	811.22	422.55	571.19	422.55	.00
424.53	888.91	424.53	620.62	424.53	.00
426.52	896.69	426.52	671.97	426.52	.00
428.50	1012.00	428.50	728.09	428.50	1006.34
430.49	1135.91	430.49	789.77	430.49	905.65
432.47	1279.00	432.47	865.07	432.47	790.21
434.45	1436.56	434.45	894.76	434.45	654.78
436.44	1600.71	436.44	1008.12	436.44	495.53
438.42	1775.79	438.42	1129.52	438.42	509.99
440.40	1960.38	440.40	1262.11	440.40	550.98
442.35	2044.28	442.39	1398.44	442.39	592.20
444.37	2232.57	444.37	1537.72	444.37	636.98
446.36	2425.61	446.36	1681.50	446.36	683.98
448.34	2625.95	448.34	1831.57	448.34	678.66
450.32	2840.45	450.32	1956.66	450.32	753.68
452.31	3069.76	452.31	2127.55	452.31	835.17
454.29	3169.51	454.29	2172.83	454.29	922.05
456.28	3394.30	456.28	2338.04	456.28	1012.93
458.26	3619.44	458.26	2505.21	458.26	1108.01
460.24	3641.13	460.24	2672.29	460.24	1200.38
462.23	3487.18	462.23	2839.12	462.23	1294.70

Table EF 4.3.9-1

VENT HEADER DEFLECTOR LOAD (Continued)  
\*\*\*\*\*DEFLECTOR FULL SCALE LOADS\*\*\*\*\*

Fermi 2, Type 3 Deflector

Z/L=1.0

Z/L=0.5

Z/L=0.0

Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)
464.21	3300.61	464.21	3005.27	464.21	1389.82
466.19	3082.68	466.19	3169.55	466.19	1395.04
468.18	2840.85	468.18	3186.34	468.18	1483.21
470.16	2593.34	470.16	3047.60	470.16	1576.73
472.15	2340.02	472.15	2900.13	472.15	1675.66
474.13	2062.27	474.13	2732.86	474.13	1775.82
476.11	1757.78	476.11	2542.31	476.11	1875.02
478.10	1610.17	478.10	2331.82	478.10	1973.97
480.08	1611.02	480.08	2103.82	480.08	2071.83
482.06	1594.48	482.06	1850.44	482.06	2166.30
484.05	1585.19	484.05	1589.74	484.05	2261.39
486.03	1595.18	486.03	1333.23	486.03	2361.26
488.02	1603.78	488.02	1312.74	488.02	2307.45
490.00	1598.48	490.00	1309.72	490.00	2196.56
491.98	1589.90	491.98	1304.87	491.98	2076.73
493.97	1608.40	493.97	1319.34	493.97	1956.17
495.95	1611.56	495.95	1322.76	495.95	1824.83
497.94	1589.45	497.94	1306.43	497.94	1676.43
499.92	1561.66	499.92	1284.88	499.92	1517.49
501.90	1568.21	501.90	1256.03	501.90	1347.85
503.89	1563.17	503.89	1226.45	503.89	1166.11
505.87	1573.16	505.87	1239.41	505.87	985.94
507.85	1574.07	507.85	1245.76	507.85	798.88
509.84	1553.93	509.84	1237.02	509.84	706.30
511.82	1558.21	511.82	1244.75	511.82	717.56
513.81	1563.74	513.81	1253.09	513.81	728.59
515.79	1557.60	515.79	1252.90	515.79	735.84
517.77	1559.13	517.77	1257.86	517.77	744.63
519.76	1571.85	519.76	1270.63	519.76	756.31
521.74	1557.17	521.74	1263.55	521.74	759.41
523.72	1544.74	523.72	1257.77	523.72	762.52
525.71	1565.56	525.71	1275.88	525.71	775.69
527.69	1555.20	527.69	1271.24	527.69	778.71
529.68	1530.46	529.68	1255.81	529.68	776.45
531.66	1531.12	531.66	1258.76	531.66	782.13
533.64	1515.38	533.64	1249.47	533.64	781.93
535.63	1478.51	535.63	1224.31	535.63	773.89
537.61	1462.81	537.61	1214.54	537.61	772.65
539.60	1456.84	539.60	1211.83	539.60	774.50
541.58	1401.21	541.58	1171.89	541.58	758.08
543.56	1361.85	543.56	1143.75	543.56	746.83
545.55	1352.35	545.55	1137.76	545.55	746.10

Table EF 4.3.9-1

VENT HEADER DEFLECTOR LOAD (Continued)  
\*\*\*\*\*DEFLECTOR FULL SCALE LOADS\*\*\*\*\*

Fermi 2, Type 3 Deflector

Z/L=1.0	Z/L=0.5	Z/L=0.0			
Time (msec)	Load (1b/ft)	Time (msec)	Load (1b/ft)	Time (msec)	Load (1b/ft)
547.53	1330.35	547.53	1122.25	547.53	740.47
549.51	1296.07	549.51	1097.32	549.51	729.84
551.50	1257.44	551.50	1068.86	551.50	717.10
553.48	1238.75	553.48	1055.31	553.48	711.62
555.47	1218.75	555.47	1040.65	555.47	705.38
557.45	1168.52	557.45	1002.84	557.45	687.00
559.43	1114.44	559.43	961.86	559.43	666.61
561.42	1066.82	561.42	925.57	561.42	648.29
563.40	1014.04	563.40	885.13	563.40	627.49
565.38	983.77	565.38	861.75	565.38	615.36
567.37	968.78	567.37	853.51	567.37	611.08
569.35	942.15	569.35	838.16	569.35	602.95
571.34	910.01	571.34	818.05	571.34	592.14
573.32	878.83	573.32	798.19	573.32	581.33
575.30	838.40	575.30	770.23	575.30	566.00
577.29	773.32	577.29	721.04	577.29	538.98
579.27	696.09	579.27	660.33	579.27	505.38
581.26	662.54	581.26	635.50	581.26	491.08
583.24	609.21	583.24	593.04	583.24	466.99
585.22	552.84	585.22	547.01	585.22	440.77
587.21	498.77	587.21	502.06	587.21	414.96
589.19	450.56	589.19	460.41	589.19	391.40
591.17	398.71	591.17	414.19	591.17	365.43
593.16	347.22	593.16	368.24	593.16	339.04
595.14	296.97	595.14	323.33	595.14	312.70
597.13	247.66	597.13	279.22	597.13	286.30
599.11	198.09	599.11	234.82	599.11	259.21
601.05	149.09	601.09	190.89	601.09	231.89
603.08	100.70	603.08	147.46	603.08	204.40
605.06	52.78	605.06	104.41	605.06	176.67
607.04	5.20	607.04	61.62	607.04	148.66
609.03	.00	609.03	19.24	609.03	120.46
611.01	.00	611.01	.00	611.01	92.09
613.00	.00	613.00	.00	613.00	63.55
614.98	.00	614.98	.00	614.98	34.84
616.96	.00	616.96	.00	616.96	6.00
618.95	.00	618.95	.00	618.95	.00
620.93	.00	620.93	.00	620.93	.00
622.92	.00	622.92	.00	622.92	.00
624.90	.00	624.90	.00	624.90	.00
626.88	.00	626.88	.00	626.88	.00
628.87	.00	628.87	.00	628.87	.00

Table EF 4.3.9-1

VENT HEADER DEFLECTOR LOAD (Continued)  
 \*\*\*\*\*DEFLECTOR FULL SCALE LOADS\*\*\*\*\*

Fermi 2, Type 3 Deflector

Z/L=1.0	Z/L=0.5	Z/L=0.0			
Time (msec)	Load (1b/ft)	Time (msec)	Load (1b/ft)	Time (msec)	Load (1b/ft)
630.85	.00	630.85	.00	630.85	.00
632.83	.00	632.83	.00	632.83	.00
634.82	.00	634.82	.00	634.82	.00
636.80	.00	636.80	.00	636.80	.00
638.75	.00	638.79	.00	638.79	.00
640.77	.00	640.77	.00	640.77	.00
642.75	.00	642.75	.00	642.75	.00
644.74	.00	644.74	.00	644.74	.00
646.72	.00	646.72	.00	646.72	.00
648.70	.00	648.70	.00	648.70	.00
650.69	.00	650.69	.00	650.69	.00
652.67	.00	652.67	.00	652.67	.00
654.66	.00	654.66	.00	654.66	.00
656.64	.00	656.64	.00	656.64	.00
658.62	.00	658.62	.00	658.62	.00

NUCLEAR ENERGY DIVISIONS • GENERAL ELECTRIC COMPANY  
SAN JOSE, CALIFORNIA 95125



TECHNICAL INFORMATION EXCHANGE  
TITLE PAGE

AUTHOR	SUBJECT	TIE NUMBER
Personnel of Nuclear Services Engineering		81NED049
TITLE		DATE
Mark I Containment Program Plant Unique Load Definition Enrico Fermi Atomic Pwr Plant: Unit 2		April 1982
	GE CLASS	I
	GOVERNMENT CLASS	
REPRODUCIBLE COPY FILED AT TECHNICAL SUPPORT SERVICES, R&UO, SAN JOSE, CALIFORNIA 95125 (Mail Code 211)	NUMBER OF PAGES	80
SUMMARY		
<p>This document provides unique definition of specific containment loading conditions that would result from a postulated loss-of-coolant accident in the Enrico Fermi Atomic Power Plant: Unit 2. Transient information is provided for containment pressures and temperatures, vent system thrust, torus vertical loads, vent system pool swell impact loads and vent header deflector loads. The document has been prepared under the Mark I Containment Program to aid Detroit Edison Company in the performance of a containment structural evaluation.</p>		

By cutting out this rectangle and folding in half, the above information can be fitted into a standard card file.

DOCUMENT NUMBER NEDO-24568

INFORMATION PREPARED FOR Nuclear Fuel & Services Division

SECTION Nuclear Services Engineering

BUILDING AND ROOM NUMBER 1887/1204 MAIL CODE 889