

AUG 19 1987

Docket No. 50-423

LICENSEE: Northeast Nuclear Energy Company (NNECo)

FACILITY: Millstone Nuclear Power Station, Unit 3

SUBJECT: SUMMARY OF MEETING TO DISCUSS THE SAFETY PARAMETER DISPLAY SYSTEM  
(SPDS) (TAC #65805)

On August 5, 1987, representatives of the staff and NNECo met to discuss the additional information required to satisfy license condition 2.C.(12) concerning the SPDS. This license condition requires the licensee to add four parameters to the SPDS, i.e., Residual Heat Removal Flow, Containment Isolation, Containment Hydrogen Concentration, and Primary Coolant System Hot Leg Temperature. Enclosure 1 includes a list of attendees and the licensee's presentation. The highlights of the discussion are summarized as follows:

1. The containment isolation status display is separate from the SPDS monitor, but is viewable from the location of the SPDS monitor. The licensee will commit to maintain or improve the relative position, orientation and visual status panel with respect to the SPDS monitor.
2. The licensee will evaluate the other three parameters of concern to determine the SPDS display to which they should be added.

Robert L. Ferguson, Project Manager  
Project Directorate I-4  
Division of Reactor Projects I/II

Enclosure:  
As stated

cc w/enclosure:  
See next page

Distribution:

Docket File	JPartlow
Summary File	JKramer
RFerguson	MGoodman
ACRS 10	REckenrode
NRC & L PDRs	SWeiss
OGC-Beth	HBClayton
EJordan	

PDI-4  
SNorris  
8/17/87

PDI-4  
RFerguson  
8/19/87

8708260371 870819  
PDR ADDCK 05000423  
P PDR