



50-445,446

PDR

Communications
Report

Company: CES

☒ Telecon☐ Conference Report

Project:

Job No. 84056

CPSES IAP Phase 4

Date: 5/13/87

Subject:

Time:

Inspection Requirements for Pipe Supports

Place: 2:30 p.m.

Participants:

Item 4, SWEC NA-1140 Report

of Bannockburn, IL

R. Klause, W. Evans, R. Read, D. Boe

of SWEC

J. Muffett

of TU

S. Tumminelli

Cygn

Item	Comments	Req'd Action By
	<p>SWEC spoke to Mark Bressler, Chairman of the ASME NF committee concerning the issue of through thickness stresses and inspection. ASME eliminated the reduced through thickness allowables after 1974 because the lower allowables resulted in poor design in that larger welds were being specified. Further, the NF 5200 inspection requirements were not added to address lamellar tearing and that pipe supports are exempted per NF-4431. SWEC investigated material requirements which remained unchanged from 1974 to 1984. Therefore, SWEC does not consider inspection of these designs to be warranted. Cygna requested SWEC to reconsider, especially since only a few supports are involved.</p>	

8709040161 870513
PIR ADOCK 05C00445
Q PDR

Signed

Page

1 of

1

Distribution:

See Attached Distribution Sheet.

DISTRIBUTION LIST

Mr. J. Redding
Mr. L. Nace
Mr. W. Counsil
Mr. J. Muffett
Mr. D. Pigott
Ms. A. Vietti-Cook
Mr. C. Grimes
Mr. E. Siskin
Mr. B. Ramsey
Ms. N. Williams
Mr. C. Wong
Mr. R. Pascaretta
Project File