

OPERATING DATA REPORT

DOCKET NO. 50-133
 DATE JULY 3, 1987
 COMPLETED BY CCKWELC
 TELEPHONE 707/443-2787

OPERATING STATUS

1. Unit Name: HUMBOLDT BAY POWER PLANT-UNIT 3
2. Reporting Period: JUNE 1987
3. Licensed Thermal Power (MWt): 220
4. Nameplate Rating (Gross MWe): 65
5. Design Electrical Rating (Net MWe): 65
6. Maximum Dependable Capacity (Gross MWe): 65
7. Maximum Dependable Capacity (Net MWe): 63

Notes

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>4343</u>	<u>209,638</u>
12. Number Of Hours Reactor Was Critical	<u>0</u>	<u>0</u>	<u>98171</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>0</u>	<u>0</u>	<u>97252</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>15,618,456</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>4,739,732</u>
18. Net Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>4,529,873</u>
19. Unit Service Factor	<u>0</u>	<u>0</u>	<u>46.4%</u>
20. Unit Availability Factor	<u>0</u>	<u>0</u>	<u>46.4%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>0</u>	<u>34.3%</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>0</u>	<u>33.2%</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>1.91%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

N/A

25. If Shut Down At End Of Report Period, Estimated Date of Startup: DECOMMISSIONING

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-133

UNIT HBPP #3

DATE JULY 3, 1987

COMPLETED BY CC KINGS

TELEPHONE 707/443-2787

MONTH JUNE, 1987

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	0
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-133
 UNIT NAME H6PP #3
 DATE JULY 3, 1981
 COMPLETED BY CCK/2004
 TELEPHONE 767/443-2787

REPORT MONTH JUNE 1981

Nbr.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report #	System Code ⁴	Component Codes ⁵	Cause & Corrective Action to Prevent Recurrence
76-6	760702	S	720	H	I	N/A	-	-	SAFSTOR DECOMMISSIONING

1 F - Forced
S - Scheduled

2 Reason:

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

3

Method:

- 1 - Manual
- 2 - Manual Scram
- 3 - Automatic Scram
- 4 - Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit I - Same Source

DCS
2

PACIFIC GAS AND ELECTRIC COMPANY

PG&E



1034 SIXTH STREET • EUREKA, CALIFORNIA 95501 • (707) 443-2787

R. T. NELSON
PLANT MANAGER
NUCLEAR PLANT OPERATIONS - HUMBOLDT

July 13, 1987

Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Docket No. 50-133
License No. DPR-7

Gentlemen:

Enclosed are the completed monthly report forms and the narrative of operating and major maintenance experience for Humboldt Bay Power Plant Unit No. 3 (HBPP-Unit 3) for June, 1987. These forms and the narrative are submitted in accordance with Section IX I.l.c of our Technical Specifications.

Sincerely,

R. T. Nelson
Plant Manager
Humboldt Bay Power Plant
1034 Sixth Street
Eureka, California 95501
(707-443-2787)

Enclosure

cc: Mr. J. C. Carroll
Mr. B. S. Lew
Mr. J. D. Shiffer

Mr. John B. Martin
Regional Administrator
U. S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

RTNelson:ss

IEW
11

MONTHLY NARRATIVE REPORT
OF OPERATING
AND MAJOR MAINTENANCE EXPERIENCE

This report describes the operating and major maintenance experience for the month of June, 1987. This report was prepared by the Plant Staff and is submitted in accordance with Section IX:I.1.c. of the Technical Specifications.

During the report period, the reactor has been in the cold shutdown mode with the core unloaded and the reactor vessel drained.