1		
2		
3	UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION	
4	BEFORE THE ATOMIC SAFETY AND LICENSING BOARD	
5		
6	In the Matter of) Docket Nos. 50-250-OLA-2) 50-251-OLA-2	
7	FLORIDA POWER & LIGHT COMPANY) (Turkey Point Nuclear Generating) Station, Units 3 & 4)) (Spent Fuel Pool Expansion	
8		
9	Testimony Of Edmund E. DeMario	
10	On Contention Number 5	
11		
12	QI: Please state your name and address.	
13	Al: My name is Edmund E. DeMario. I am employed by the	
14	Westinghouse Electric Corporation ("Westinghouse") as an	
15	advisory engineer in the Commercial Nuclear Fuel	
16	Division (CNFD). My business address is P.O. Drawer R,	
17	Columbia, SC, 29250.	
18	Q2: Please describe your professional qualifications and	
19	experience.	
20	A2: A summary of my professional qualifications and experi-	
20	ence is attached hereto as Exhibit A, which is incorpor-	
22	ated herein by reference.	
22	Q3: What is the purpose of your testimony?	
23	A3: The purpose of my testimony is to address Contention No.	
24	5 as limited to the effects of seismic loads that the	
25	Turkey Point spent fuel storage racks could exert upon	
26	the fuel assemblies within the spent fuel storage racks.	
27		
28	8709090099 870831	
	PDR ADDCK 05000250 G PDR	

\$

1	
2	The Testimony Of Harry J. Flanders, Jr. On Contention
3	Number 5 addresses the seismic analysis of the spent
4	fuel storage racks, and the Testimony Of Russell Gouldy
5	On Contention Number 5 addresses the administrative
6	controls for loading of spent fuel into the racks.
7	Contention No. 5 and the bases for the contention
8	are as follows:
9	Contraction 5
10	Contention 5
11	That the main safety function of the spent fuel pool which is to maintain the spent
12	fuel assemblies in a safe configuration through all environmental and abnormal loading, may not be met as a result of a recently brought to light unreviewed
13	
14	re-rack design that allows racks that
15	fuel pool. Thus, the amendment should be
3.6	revoked.
17	Bases for Contention
18	In a February 1, 1985, letter from Williams, FPL, to Varga, NRC, which
19	describes the procedures for rack lift off under the seismic event conditions [sic]
20	This is clearly an ungeviewed safety question which demands a safety analysis
21	of all seismic and harricane conditions and their potential impacts on the racks
22	in question before the license amendments are issued. Because of the potential to
23	increase the possibility of an accident
24	the possibility of a new or different kind of accident caused by loss of structural
25	integrity. If integrity is lost, the damaged fuel rods could cause a critical-
26	ity accident.
27	

28

- 2 -

(Hurricane loads were rejected as a basis for Contention 2 3 5 in the Licensing Board's memorandum and order of 4 September 16, 1985). 5 04: Please describe the design of the Turkey Point fuel 6 assemblies. 7 A4: Each Turkey Point fuel assembly is approximately 8.4 inches square and 13 feet in length. Each assembly 8 9 consists of a fifteen by fifteen array of fuel rods and guide tubes for control rods and instrumentation. Each 10 11 of the 204 fuel rods in an assembly contains uranium 12 dioxide fuel pellets clad in Zircaloy tubing, having an 13 outside diameter of 0.422 inches and a wall thickness of 14 0.0243 inches. Grids, positioned at vertical intervals along the length of the fuel rods, maintain rod spacing 15

and geometry.
The fuel assemblies and fuel rods have been
designed to perform satisfactorily throughout their
lifetime in the reactor. The loads, stresses, and
strains resulting from the combined effects of flow

21 induced vibrations, earthquakes, reactor pressure, 22 fission gas pressure, fuel growth, thermal strain, and 23 differential expansion during both steady state and 24 transient reactor operating conditions have been consid-25 ered in the design of the fuel rods and fuel assemblies. 26 These conditions in the reactor are far more severe than 27 those postulated for the Turkey Point spent fuel pool

28

1

- 3 -

1 during a seismic event. Thus, the stored spent fuel 2 assemblies and fuel rods would be able to withstand a 3 4 postulated seismic event a Turkey Point without loss of 5 structural integrity. 6 Q5: Was any analysis performed to confirm that there would be no loss of integrity in the stored spent fuel assem-7 8 blies as a result of a seismic event? 9 A5: Yes. Westinghouse performed a finite element analysis 10 to confirm that there would be no loss of integrity 11 (breaching of the fuel rod cladding) in the stored spent 12 fuel assemblies as a result of a postulated worst case 13 safe shutdown earthquake (SSE). I have reviewed the 14 Westinghouse analysis of the structural capability of 15 the fuel assemblies stored in the Turkey Point spent 16 fuel storage racks and have verified that the methodol-17 ogy used in the analysis was appropriate and that the 18 results obtained from the analysis are accurate. 19 06: Please describe this analysis.

20 During a postulated seismic event at Turkey Point Units A6: 21 3 and 4, the fuel assemblies in the spent fuel storage 22 racks would contact the stainless steel walls of the 23 storage rack cells due to the motion of the rack 24 assembly relative to the motion of the fuel assemblies. 25 Employing finite element methods of the type described 26 in the Testimony Of Harry E. Flanders, Jr. On Contention 27 Number 5, the maximum acceleration imposed upon a spent

28

- 4 -

1 2 fuel assembly as a result of an SSE at Turkey Point was 3 calculated to be 1.6g (where g is the acceleration due 4 to gravity at the earth's surface). The maximum accel-5 eration that a fuel rod in the fuel assemblies can 6 sustain without cladding failure was also calculated, 7 employing finite element analysis methods, for the 8 irradiated fuel rods and their supporting grids. 9 07: What were the results of the finite element analysis of 10 the Turkey Point spent fuel assemblies under conditions 11 of an SSE? 12 The results of the finite element analysis show that the A7: 13 spent fuel assemblies can sustain an acceleration of 36g 14 without localized cladding failure. Therefore, the 15 integrity of the fuel cladding will be maintained for 16 the worst case seismic event because the 36g accelera-17 tion required to prevent fuel cladding failure is more 18 than an order of magnitude greater than the 1.6g accel-19 eration that the fuel assemblies would experience in the 20 Turkey Point spent fuel pool racks if the maximum 21 anticipated earthquake (SSE) occurred. 22 23 24 25 26 27 28

- 5 -

1	
2	EXHIBIT A
3	PROFESSIONAL QUALIFICATIONS AND EXPERIENCE OF
4	EDHOND E. DEMARIO
5	
6	My name is Edmund E. DeMario and my business address is P.O.
7	Drawer R, Columbia, S.C. 29250. I am employed by the
8	Westinghouse Electric Corporation (Westinghouse) as an
9	Advisory Engineer in the Commercial Nuclear Fuel Division
10	(CNFD).
11	
12	I graduated from the Stevens Institute of Technology with a
13	Degree in Mechanical Engineering in 1960. I also completed
14	20 credits of graduate study in Chemical Engineering at the
15	Stevens Institute of Technology.
16	
17	In September 1961, I joined General Dynamics at the
10	Vandenburg Air Force Base as a Test Engineer on the Atlas
10	Missile program and in August 1963 I joined Lockheed at the
19	Vandenburg Air Force Base as a Test Engineer on the AGENA
20	Space Vehicle Program.
21	
22	In February 1966 T joined Boll Apropustors at Wheetfield
23	N V oc b Dreiset Dreises is the designed at wheathed,
24	N.I. as a Project Engineer in the design and development of
25	new space engines.
26	
27	
28	

- 6 -

In January 1969, I joined the Nuclear Fuel Division of the Westinghouse Electric Corporation as a Design Engineer where I was responsible for designing advanced fuel assemblies and performing analyses and tests to evaluate the fuel performance under the various reactor conditions.

- 7 -

8 After being promoted to the position of Fellow Engineer in 9 1976, I was subsequently promoted to the position of Advisory 10 Engineer in December 1981, with the responsibility for the 11 mechanical design of advanced fuel assemblies. In addition, 12 I am responsible for the training of engineers in fuel 13 assembly design.

14

1

15

16 I have been responsible for the mechanical design of advanced 17 fuel assemblies including the 17 x 17 fuel assembly, the 18 Vantage-5 and the Optimized Fuel Assembly.

19

20 I am a Professional Engineer in the State of Pennsylvania.
21
22
23

24 25

26

27