1				
2	INTER CONTROLOR ANTROLOR			
3	NUCLEAR REGULATORY COMMISSION			
4	BEFORE THE ATOMIC SAFETY AND LICENSING BOARD			
5				
6	In the Matter of A Docket Nos 50-250-010-2			
7	FLORIDA POWER & LIGHT COMPANY			
8	(Turkey Point Nuclear Generating ) Station, Units 3 & 4) (Spent Fuel Pool Expansion			
9	(Spent Fuel Pool Expansion)			
10		Testimony of Eugene W. Thomas On Contention Number 6		
11	Q1:	Please state your name and address.		
12	Al:	My name is Eugene W. Thomas. I am employed by Bechtel		
13		Eastern Power Corporation as Assistant Chief Civil		
14		Engineer. My mailing address is 15740 Shady Grove Road,		
15		Gaithersburg, Maryland 20877.		
16	Q2:	Please describe your professional gualifications and		
17		experience.		
18	A2:	A summary of my professional qualifications and		
19		experience is attached as Exhibit A and is incorporated		
20		herein by reference.		
21	Q3:	What is the purpose of your testimony?		
22	A3:	The purpose of my testimony is to address Contention 6.		
23		Contention 6 and the bases for that contention are as		
24		follows:		
25		Contention 6		
26		The Licensee and Staff have not		
27	adequately considered or analyzed materials deterioration or failure in			
28				
PDR	AD00	CK 05000250 PDR		

1		
2	materials integrity resulting from the	
3	increased generation heat and radioactivity, as a result of increased	
4	spent fuel pool.	
5	Bases for Contention	
6	The spent fuel facility at Turkey Point	
7	was originally designed to store a lesser amount of fuel for a short period of time. Some of the problems that have not been analyzed properly are:	
8		
9	(a) deterioration of fuel cladding as a	
10	decay heat and radiation levels	
11	storage.	
12	(b) loss of materials integrity of	
13	result of exposure to higher levels	
14	(c) deterioration of concrete peol	
15	structure as a result of exposure to	
16	of time.	
17	Specifically, the purpose of my testimony is to address	
18	material deterioration or failure in materials integrity	
19	of the spent fuel pool liner and concrete pool structure	
20	due to heat from the increased capacity of the Turkey	
21	Point spent fuel pools. Other issues raised by	
22	Contention 6 are addressed in the Testimony of William	
23	C. Hopkins on Contention Number 6 (materials	
24	deterioration or failure in materials integrity of the	
25	liner and concrete pool structure due to radiation), the	
26	Testimony of Dr. Gerald R. Kilp and Russell Gouldy on	
27	Contention Number 6 (materials deterioration or failure	
28		

2

D.

0.

in materials integrity of the fuel assemblies and storage racks), and the Testimony of William A. Boyd on Contention Number 6 (impact on K-effective of postulated gaps in the Boraflex plates in the Turkey Point spent fuel storage racks).

## Q4: Please describe the Turkey Point spent fuel pool concrete structure and liner.

1

9 A4: The spent fuel pool structure is rectangular in shape 10 with inside dimensions of 25'-4" by 41'-4" and with a 11 height of approximately 40 feet. A four foot thick 12 cross wall on one end of the prol separates the storage 13 area from the refueling canal. The walls and floor are 14 constructed of reinforced concrete with a 1/4" thick 15 stainless steel liner plate system covering the entire 16 inside surface of the pool. With the exception of a 17 three foot length of wall on either side of the 18 refueling canal which is 18" thick, the walls range from 19 3'-0" to 5'-6" thick. The floor of the pool, which also 20 serves as a base mat at grade, ranges in thickness from 21 3' to 4'-6".

The spent fuel pool liner plate is ASTM (American Society for Testing and Materials) A-240 Type 304 stainless steel. Stainless steel shapes and bar are ASTM A-276 or A-479 (Type 304) or AISI (American Irc and Steel Institute) Type 302 or 304. Stiffeners and anchorage attachments for embedments (studs and threaded rods) are ASTM A-36. Concrete is manufactured in

- 3 -

accordance with ACI (American Concrete Institute) 301.
 The main constituents of the concrete are ASTM C-150
 Type II cement and aggregate meeting the requirements of
 ASTM C-33. Reinforcing steel is ASTM A-15, intermediate
 grade.

- 7 Q5: What issues would the generation of heat in the spent 8 fuel pool raise regarding the integrity of the concrete 9 pool structure and liner?
- 10 A5: Two issues would be raised. The first issue pertains to 11 the thermal stresses induced in the structure as a 12 result of the temperature differential between the pool 13 water and ambient conditions, and the second pertains to 14 materials integrity.
- 15 Q6: Did you perform an analysis of the thermal stresses on 16 the concrete pool structure?

17 A6: Yes. The load carrying capacity of the pool structure 18 was evaluated by conducting a detailed computer analysis 19 as part of the overall evaluation of the pool for 20 increased capacity. Using the ANSYS program, which is a 21 public domain, industry recognized standard structural 22 analysis technique, the pool structure was mathematic-23 ally modeled as a large number of solid finite elements 24 with sufficient detail to accurately capture response to 25 load. All loads imposed on the structure were 26 considered, including the effect of heat from the pool 27 water as well as all postulated extreme environmental

28

1

- 4 -

2 conditions, as addressed in the original licensing 3 documents. There may also be nuclear heating of the 4 concrete and steel as a result of radiation. Nuclear 5 heating has the same mechanical effect on the concrete 6 structures and liner plate as thermal heating. As 7 discussed in the Testimony of William C. Hopkins on 8 Contention Number 6, the magnitude of nuclear heating is 9 insignificant as compared with thermal heating caused by 10 the temperature of the pool water.

11 Thermal effects were not a specific concern since 12 the increased capacity of the pool results in only minor 13 variations from the original design condition, but were 14 included to provide an entire load identification of the 15 structure. Water temperatures in the pool for the 16 operating, abnormal and postulated boiling conditions 17 (212° F) were considered. Since the most severe loads 18 on the structure due to heat are caused by temperature 19 gradients (i.e., large temperature differences on 20 opposite sides of the pool walls), the ambient 21 temperature outside the pool was assumed to be as low as 22  $30^{\circ}$  F, resulting in a gradient of as much as  $182^{\circ}$  F 23 through the wall thickness for analytical purposes.

The 30° F temperature specified on the outside surface of the pool is extremely conservative for the site environment of Southern Florida. A review of 33 years of meteorological records for that area indicated

- 5 -

1

that the lowest mean five consecutive days temperature was 48° F. Thermal conductivity analysis shows that for a three foot thick wall, a steady state temperature gradient condition for the worst postulated temperatures would take five days to develop. The review of the 33 years of records also indicated that the lowest recorded temperature was 31° F, which lasted only three hours.

9 Using methods addressed in ACI Committee 349 10 report, "Criteria for Reinforced Concrete Nuclear 11 Containment Structure," ACI Journal, January 1972, the 12 loads from the computer analysis were converted into 13 reinforcing steel and concrete stresses at various 14 critical locations on each of the walls and the floor. 15 These stresses were shown to be within the licensing 16 condition imposed on the original design as identified 17 in the Turkey Point Units 3 and 4, "Updated Final Safety 18 Analysis Report," Docket Nos. 50-250 and 50-251, 19 Appendix 5A. Further, the analysis shows that the pool 20 maintains its structural integrity even under severe 21 conditions of postulated boiling water combined with the 22 effects of the design basis earthquake.

23 Q7: Did you evaluate thermal stresses on the spent fuel pool 24 liner plate?

A7: Yes. The liner plate was conservatively not considered
 to provide structural capability in the structural
 analysis of the pool concrete structure. However, a

28

1

2

3

4

5

6

7

8

- 6 -

2 separate analysis was conducted to determine the effects 3 of thermal, hydrostatic and hydrodynamic loads on the 4 functionality of the liner plate system. This analysis 5 reviewed the buckling potential of the liner plate, as 6 well as stresses in welds and embedded metal associated 7 with the liner system. The analysis showed that there 8 would be no loss of function under all postulated 9 conditions.

10 Q8: Do you have a conclusion with respect to thermal 11 stresses on the concrete pool structure and the liner 12 plate?

13 A8: Yes. The pool was analyzed considering the thermal and 14 mechanical effects of the increased spent fuel capacity 15 for normal, abnormal and postulated boiling water 16 conditions, in conjunction with postulated accident 17 conditions as specified in the Updated Final Safety 18 Analysis Report. The results of the analysis 19 demonstrate that the pool structure and liner plate meet 20 the original licensing acceptance conditions and 21 maintain their structural integrity under all of these 22 conditions.

Q9: Was the effect of temperature on the integrity of the
 Turkey Point concrete pool structures and liner plates
 considered during the initial design process?

26

1

27

28

- 7 -

1 2 A9: Yes. The thermal environment was taken into 3 consideration in the selection of materials during the 4 initial design process. The increased capacity of the 5 pool does not raise a new issue regarding deterioration 6 of the concrete pool structure, including the liner 7 plate, as a result of exposure to increased temperatures 8 over extended periods of time. 9 Q10: Please describe the effect of temperature on the 10 stainless steel in the liner plate. 11 AlO: Stainless steel was chosen for the liner plate because 12 of its demonstrated ability to perform in various 13 nuclear power plant applications, including those 14 subject to much more severe thermal environments than 15 that of the spent fuel pool. Stainless steel maintains 16 its integrity and long-term stability at temperatures 17 in excess of 1,000° F, which is far above the 18 temperature expected in the spent fuel pool. 19 Reductions in strength occur with increased steel 20 temperature; however, for the temperature under 21 consideration (212° F and less), no appreciable 22 reduction occurs, as reflected in the ASME Boiler and 23 Pressure Vessel Code, Section III, Nuclear Power Plant 24 Components, Division I, Appendix I. 25 Q11: Please describe the effect of temperature on the 26 concrete and reinforcing steel of the spent fuel pool. 27

28

- 8 -

2 All: The concrete and reinforcing steel of the spent fuel 3 pool are also capable of maintaining their integrity, 4 durability and long-term stability under the thermal 5 environment imposed by the increased pool capacity. 6 Concrete exposed to elevated temperatures will exhibit 7 some changes in its characteristics. Such changes are 8 dependent on the type and nature of the concrete 9 constituents and on the proportions in which these 10 constituents are combined. For concrete materials, 11 such as those in the Turkey Point spent fuel pool 12 structure, which have met the minimum requirements of 13 the controlling ASTM standards and are combined in 14 accordance with appropriate ACI guidelines, temperatures below approximately 300° F have an 15 16 insignificant effect on their properties. A limestone 17 type aggregate and portland cement, both of which meet 18 appropriate ASTM standards, were used in the Turkey 19 Point spent fuel pool. ACI guidelines as previously 20 identified were employed for proportioning and mixing 21 processes.

Free water, which is the result of excess water available in the wet concrete mix not utilized in the hydration process, can be a concern for some structures with temperatures above approximately 200° F. However, in the case of the Turkey Point spent fuel pool concrete structure, more than adequate time (the plant

- 9 -

1

2 has been in operation for more than a dozen years) has 3 been available for any free water, which was not 4 utilized in the hydration process, to egress. 5 Therefore, free water does not present a concern with 6 respect to the concrete pool structures at Turkey 7 Point, and these structures will not be adversely 8 affected by the heat generated in the spent fuel pools. 9 Unless the concrete is saturated with moisture (which 10 is not the case at Turkey Point), temperature on the 11 order of 300° F will have an insignificant effect on 12 the mechanical properties of the concrete including its 13 strength.

14 Finally, the reinforcing steel in the concrete 15 structure is similar to other steels in that it 16 maintains its integrity and stability at temperatures 17 far above that which will be experienced by the pool 18 structure. Consequently, any reduction in strength c. 19 the reinforcing steel as a result of the heat loads 20 experienced in the spent fuel pool will be 21 insignificant.

Q12: Does Florida Power & Light Company have a materials surveillance or monitoring program to detect any heatinduced degradation of the Turkey Point spent tuel pool liners and concrete pool structures?
Al2: No. Such a program is unnecessary for the following

reasons:

28

27

1

- 10 -

1 2 0 The Turkey Point spent fuel pool liners and 3 concrete structures were designed and licensed to 4 store spent fuel for the lifetime of the plant. 5 The spent fuel pool expansion increases the amount 6 of fuel stored but not the duration of use of the 7 spent fuel pools. 8 The concrete pool structure and liner have been 0 9 shown to be capable of withstanding, without 10 significant effect upon their properties, 11 temperatures exceeding those to which they will be 12 exposed during the lifetime of the plant. 13 013: Would you please summarize your testimony? 14 A13: The concrete pool structure and liner were evaluated to 15 determine whether they could withstand the thermal 16 stresses and heat loads expected as a result of the 17 spent fuel pool expansion. This evaluation 18 demonstrates that the concrete pool structure and liner 19 will maintain their integrity for the maximum 20 temperature differentials expected for the Turkey Point 21 spent fuel pool. Furthermore, both the liner and the 22 pool structure consist of materials which are widely 23 used in the nuclear industry and which have a proven 24 ability to withstand the heat loads expected in the 25 Turkey Point spent fuel pool. 26 27

- 11 -

1			
2		EXHIBIT A	
3			
4	STATEMENT OF PROFE	SSIONAL QUALIFICATIONS OF EUGENE W. THOMAS	
5	CURRENT POSITION	Assistant Chief Civil Engineer, Bechtel Eastern Power Corporation	
6	EDUCATION	BSCE, Drexel Institute of Technology,	
7		1964 MSME, Drexel Institute of Technology,	
8		1969	
9	SUMMARY		
10	1/2 Year	Assistant Chief Civil Engineer, Bechtel, 1987-Present	
11	5 Vears	Civil staff supervisor Rechtel 1092-	
12	~ *C010	1987	
13	2-1/2 Years	Civil group supervisor, nuclear power plant, Bechtel, 1979-1982	
15	3-1/2 Years	Deputy civil group supervisor, nuclear power plant, Bechtel, 1976-1979	
16	2-1/2 Years	Group leader, nuclear power plant, Bechtel, 1973-1976	
17	3-1/2 Years	Engineering specialist, nuclear power	
19	6 Warner 1	planes, beenter, 1970-1975	
20	b Years	Senior dynamics engineer and dynamics engineer, Boeing, 1964-1970	
21	EXPERIENCE WITH BECHTEL		
22	Mr. Thoma	s is currently serving as Assistant Chief	
23	Civil Engineer in t	he Civil Engineering Department. In this	
24	position, he provid	es technical assistance to the chief civil	
25	engineer, reviews t	he technical adequacy of engineering	
26	design for both fos	sil and nuclear power plant projects,	
27	develops design met	hods and standards, and acts as a	
28			

ŝ

.

- 12 -

the second states and the second

consultant to the various projects in resolution of difficult or unusual problems. Mr. Thomas is also a member of Bechtel's Dynamics Committee, which establishes criteria for seismic analyses and design criteria for vibrating and rotating equipment.

1

28

7 Mr. Thomas served as the civil staff supervisor 8 prior to this with duties and responsibilities similar to 9 those in his current position.

10 Previously, Mr. Thomas was assigned as civil group 11 supervisor for the multi-unit SNUPPS project, 1150 MW PWR 12 nuclear units, involving several utilities. He was 13 responsible for design of the powerblock and safety-related 14 site structures, technical resolution of field problems, 15 preparation of specifications and bid packages, technical 16 evaluation of bids, and review of vendor drawings for civil 17 related items.

18 In earlier assignments to SNUPPS, Mr. Thomas was 19 deputy group supervisor and reactor building group leader.

20 As an engineering specialist, Mr. Thomas was 21 involved in piping whip restraint design, miscellaneous 22 concrete and structural steel design, and FSAR preparation 23 for Millstone Nuclear Power Station's 870 MW PWR Unit 2 for 24 Northeast Nuclear Energy Company. He also worked on pipe 25 whip restraint design for the Davis-Besse Nuclear Power 26 Station 900 MW PWR Unit 2 project for the Toledo Edison 27 Company/The Cleveland Electric Illuminating Company; seismic

- 13 -

analysis for the auxiliary and control buildings, pipe hanger design and miscellaneous concrete and structural steel design for the 693 MW PWR Turkey Point Plant Units 3 and 4 for Florida Power & Light Company; and seismic analysis of the containment for the Edwin I. Hatch Nuclear Plant, two 800 MW BWR units for Georgia Power Company.

8

9

1

## EXPERIENCE WITH BOEING

Prior to joining Bechtel, Mr. Thomas was a senior dynamics engineer and dynamics engineer. Using flight test data, finite element and other analytical methods, he determined dynamic characteristics of air frames. He also prepared computer programs for predicting rotor dynamic loads on helicopters and for determining structural natural frequencies for large models.

17 PROFESSIONAL MEMBERSHIPS

18 National Society of Professional Engineers, American Concrete Institute

20 REGISTRATION

21 Registered Professional Engineer in Maryland, Missouri, and Kansas

22

23

25

26

27