



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 113
License No. DPR-66


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, et al. (the licensee), dated February 10, 1987 and supplemented by letter dated April 10, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A, as revised through Amendment No. 113, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This amendment is effective on issuance, to be implemented no later than 30 days after issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Director
Project Directorate I-4
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 27, 1987

ATTACHMENT TO LICENSE AMENDMENT NO.113

FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

Remove

3/4 3-42

3/4 3-63

Insert

3/4 3-42

3/4 3-63

TABLE 3.3-8

METEOROLOGICAL MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>INSTRUMENT MINIMUM ACCURACY</u>	<u>MINIMUM OPERABLE</u>	
1. WIND SPEED			
a. Nominal Elev. 500'	± 0.5 mph*	Any	
b. Nominal Elev. 150'	± 0.5 mph*	3 of 6	
c. Nominal Elev. 35'	± 0.5 mph*		
2. WIND DIRECTION			
a. Nominal Elev. 500'	$\pm 5^\circ$	Any	
b. Nominal Elev. 150'	$\pm 5^\circ$	3 of 6	
c. Nominal Elev. 35'	$\pm 5^\circ$		
3. AIR TEMPERATURE ΔT			
a. ΔT Elev. 500'	$\pm 0.1^\circ\text{C}$	Any	
b. ΔT Elev. 150'	$\pm 0.1^\circ\text{C}$	2 of 4	

* Starting speed of anemometer shall be < 1 mph.

TABLE 3.3-13, (Cont'd)

TABLE NOTATION

ACTION 27 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, the contents of the tank may be released to the environment provided that prior to initiating the release:

1. At least two independent samples of the tank contents are analyzed, and at least two technically qualified members of the facility staff independently verify the release rate calculations and discharge valve lineup.

or

2. Initiate continuous monitoring with a comparable alternate monitoring channel. Surveillance Requirements applicable to the inoperable channel shall apply to the comparable alternate monitoring channel when used to satisfy this technical specification requirement.

Otherwise, suspend release of radioactive effluents via this pathway.

ACTION 28 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided the flow rate is estimated at least once per 4 hours.

ACTION 29 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided:

1. Grab samples are taken at least once per 8 hours and these samples are analyzed for gross activity within 24 hours.

or

2. Initiate continuous monitoring with a comparable alternate monitoring channel. Surveillance Requirements applicable to the inoperable channel shall apply to the comparable alternate monitoring channel when used to satisfy this technical specification requirement.

ACTION 30 - With the number of channels OPERABLE less than required by Minimum Channels OPERABLE requirement, immediately suspend PURGING of Reactor Containment via this pathway if both RM-VS-104A and B are not operable with the purge/exhaust system in service.