

LICENSEE EVENT REPORT (LER)

APPROVED OMS NO. 2160-0161

EXPIRES 8/31/88

FACILITY NAME (1) Millstone Nuclear Power Station Unit 1										DOCKET NUMBER (2) 0 5 0 0 0 2 4 5 1 OF 0 2										PAGE 13																					
TITLE (4) Vital Area Door Without Alarm Capability																																									
EVENT DATE (6)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)																															
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES					DOCKET NUMBER (8)																											
									Millstone Unit 2					0 5 0 0 0 3 3 6																											
0 4	1 4	8 6	8 6	0 1	3	0 0	0 4	1 8	Millstone Unit 3					0 5 0 0 0 2 4 5																											
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § 1.61 (Check one or more of the following) (11)																																							
N		20.402(b)										20.405(e)										80.73(a)(2)(w)										73.71(b)									
POWER LEVEL (10)		20.405(a)(1)(i)										80.38(e)(1)										80.73(a)(2)(v)										73.71(e)									
1 1 0 1 0		20.405(a)(1)(ii)										80.38(e)(2)										80.73(a)(2)(vii)										OTHER (Specify in Abstract below and in Text, NRC Form 365A)									
		20.405(a)(1)(iii)										80.73(a)(2)(iii)										80.73(a)(2)(viii)(A)																			
		20.405(a)(1)(iv)										80.73(a)(2)(iv)										80.73(a)(2)(viii)(B)																			
		20.405(a)(1)(v)										80.73(a)(2)(v)										80.73(a)(2)(ix)																			
LICENSEE CONTACT FOR THIS LER (12)																																									
NAME Patricia L. Weekley, Security Supervisor										TELEPHONE NUMBER 2 0 3 4 4 4 1 4 3 2 9																															
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																																									
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC																																
A	I	A		N																																					
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)																															
YES (If yes, complete EXPECTED SUBMISSION DATE)										X NO																															

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

At approximately 0905 hours on 4/14/86 a Security Officer discovered vital area door [REDACTED] without alarm capabilities and in an unsecured state with no Security Officer posted. Alarm points for door [REDACTED] were inactivated at 0847 hours per a request from a Security Officer assigned to I&C personnel working on the door equipment. The vital area door was without alarm capability, unsecured and had no [REDACTED] for approximately 18 minutes. The Security Officer who discovered the problem with door [REDACTED] and notified the CAS of the situation. The vital area was checked for unauthorized personnel and/or activities with none being found.

8709150176 870910
PDR FOIA
WILLIAM87-410 PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO 3150-0104

EXPIRES 8-7-88

FACILITY NAME (1)

DOCKET NUMBER (2)

LER NUMBER (5)

PAGE (3)

Millstone Nuclear Power Station
Unit 1

YEAR	SEQUENTIAL NUMBER	REVISION NUMBER
0	5	0

DOCKET NUMBER (2)	LER NUMBER (5)	PAGE (3)
0500024586	013-0202	02

TEXT (If more space is required, use additional NRC Form 366A's) (17)

Identification of Occurrences

At approximately 0905 hours on 4/14/86 vital area door [REDACTED] was discovered to be without alarm capabilities, in an unsecured state, with no [REDACTED] at the door.

Effects

0847-0905 hours - Uncontrolled access to a vital area, [REDACTED]

Description of Compensatory Measures

[REDACTED]

Description of Apparent Cause

The Security Officer assigned to the I&C technician working on the door equipment was not at the door when the alarm points were inactivated. He was at the [REDACTED] associated with the door. The [REDACTED] for this particular door is not in visual range of the vital area barrier door. Proper procedure would have been [REDACTED] to maintain vital area access control.

Corrective Action

The Security Officer was removed from shift and a determination to retrain, or discontinue employment is being made. The Supervisor for the Security I&C personnel has discussed this event with the technicians. They have been advised that the Security Guards, assigned to them while they work, are there to [REDACTED]. If the technicians have a question about proper compensatory measures they are not to start work until it is resolved by contacting the Security Shift Supervisor.

[REDACTED]

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY



General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 666-6911

April 18, 1986

MP-8961
Docket No. 50-245
Docket No. 50-336
Docket No. 50-423

Mr. Richard W. Starostecki, Director
Division of Project and Resident Programs
NRC Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Starostecki:

This letter forwards a report of a security related event pursuant to the requirements of 10CFR part 73, paragraph 73.71(c).

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

FOR: Wayne D. Romberg
Station Superintendent

BY: James J. Kelley
Station Services Superintendent
Millstone Nuclear Power Station

WDR/PLW:mo

Attachment: Report of Security Event 86-013-00

cc: Director of Inspection and Enforcement U.S. Nuclear Regulatory
Commission, Washington, D.C. 20555

~~_____~~
~~_____~~
~~_____~~

C/10