



Log # TXX-6716
File # 10110
909.2
Ref # 10CFR50.55(e)

William G. Council
Executive Vice President

September 11, 1987

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
COMPONENT COOLING WATER (CCW) HEAT EXCHANGER
SEISMIC QUALIFICATION
SDAR: CP-87-18 (INTERIM REPORT)

Gentlemen:

On June 8, 1987, we verbally notified your Mr. I. Barnes of a deficiency involving error identified during a review of the vendor (Struthers Wells) qualification documentation for the CCW heat exchangers that indicated the seismic and nozzle loading conditions exceed specification requirements and could be overstressed. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e). Our most recent interim report, logged TXX-6607, was submitted on August 3, 1987.

We are continuing our evaluation of the impact of this issue on the safety of plant operations.

Our next report will be submitted no later than November 6, 1987.

Very truly yours,

W. G. Council
W. G. Council

By: *G. S. Keeley*
G. S. Keeley
Manager, Nuclear Licensing

MCP/lp

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8709150330 870911
PDR ADDCK 05000445
S PDR

IE27
1/0

USNRC-DS

1987 SEP 15 A 9 39