



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

Conner

Docket No. 50-336

SEP 27 1978

Northeast Nuclear Energy Company
ATTN: Mr. W. G. Council
Vice President - Nuclear
Engineering and Operations
P. O. Box 270
Hartford, Connecticut 06101

Gentlemen:

SUBJECT: Inspection 50-336/78-26

This refers to your letter dated September 12, 1978, in response to our letter dated August 21, 1978.

We have reviewed and evaluated the information which you have supplied; and, have determined that the item is an item of noncompliance. The specific issues involved were that the actual instrument channel trip settings and the acceptance criteria of the surveillance procedure initially reviewed by the inspector were not in conformance with the Technical Specifications.

Your cooperation with us is appreciated.

Sincerely,

Boyce H. Grier
Boyce H. Grier
Director

cc:

J. F. Opeka, Station Superintendent
D. G. Diedrick, Manager of Quality Assurance
J. R. Himmelwright, Licensing Safeguards Engineer

bcc:

IE Mail & Files (For Appropriate Distribution)
Central Files
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
Technical Information Center (TIC)
REG:I Reading Room
State of Connecticut

7810060211

~~7810060211~~
3/1/78