

MAY 31 1989

Docket Nos. 50-352

Philadelphia Electric Company
ATTN: Mr. C. A. McNeill, Jr.
Executive Vice President
Nuclear
Correspondence Control Desk
P.O. Box 7520
Philadelphia, PA 19101

Gentlemen:

Subject: Limerick Generating Station, Unit 1 Integrated Leak Rate Test (ILRT)
Schedule

The commission has reviewed your proposed schedule for the Integrated Leak Rate Test (ILRT), submitted to Mr. Russell of this office, from Mr. Fogarty (letter dtd. June 20, 1988) in accordance with Limerick Technical Specifications and 10 CFR 50, Appendix J, Paragraph II.A.6(a).

The commission has found the proposed schedule, to perform a complete Local Leak Rate Test (LLRT) during each refueling outage, and the next ILRT (type A test) during the third refueling outage, to be acceptable.

If you have questions, please contact this office

Original Signed By:
Jack R. Strosnider

Jack R. Strosnider, Chief
Engineering Branch
Division of Reactor Safety

OFFICIAL RECORD COPY

LIMERICK 1 REVISED - 0001.0.0
05/31/89

8906120159 890531
PDR ADOCK 05000352
PDC

IE:01

cc w/encl:

J. S. Kemper, Sr., Senior Vice President - Nuclear Construction
G. M. Leitch, Vice President - Limerick Generating Station
S. J. Kowalski, Vice President - Nuclear Engineering
D. R. Helwig, General Manager - Nuclear Services
M. J. McCormick, Jr., Manager - Limerick Generating Station
W. T. Ullrich, Manager - Limerick Unit 2 Startup
A. S. MacAinsh, Manager - Limerick Quality Division
G. A. Hunger, Jr., Director - Licensing Section
T. B. Conner, Jr., Esquire
E. J. Bradley, Esquire, Assistant General Counsel
H. D. Honan, Branch Head - Nuclear Engineering Licensing
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encl:

Region I Docket Room (with concurrences)
Section Chief, DRP
Robert J. Bores, DRSS
J. Linville, RI
P. K. Eapen, RI

RI:DRS
Trapp

5/31/89

RI:DRS
Eapen

5/31/89

RI:DRS
Strosnider

5/31/89

OFFICIAL RECORD COPY

LIMERICK 1 REVISED - 0002.0.0
05/31/89