



ARKANSAS POWER & LIGHT COMPANY

POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 [501] 377-4000

May 31, 1989

2CAN058923

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

ATTN: Mr. Chester Poslusny, Jr., NRR Project Manager
NRR Mail Stop 13-D-18


SUBJECT: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Additional Information Request Response -
Simulator Certification (TAC No. 72912)

Dear Mr. Poslusny:

Your letter dated March 27, 1989 (2CNA038902) requested additional information and data to assure complete documentation of our certification of the ANO-2 Simulator. The information you requested is included as an enclosure and its associated attachments to this letter, with the responses numbered according to the specific questions contained in your request.

It should be noted that in December 1987 members of our staff contacted Mr. Wachtel, the NRC reviewer designated for the ANO-2 Simulator review, to obtain guidance in preparing the certification submittal. Mr. Wachtel could not provide specific guidance on the submittal content, but stated that our process for selecting transients and our exception to the operating limit appeared to be adequate.

Very Truly Yours,


Dale E. James
Supervisor, Licensing

DEJ:RBT

Enclosure

8906130183 890531
PDR ADDCK 05000368
PDC
P

M003
11

ENCLOSURE

ANSWERS

- A-1. The answer to this question is broken down by section of the Performance Test. For each section all three parts of the question are answered. The format is as follows:

Performance Test Section Title

1. Final Conditions
2. Description of Baseline Data Used to Determine Fidelity to the Reference Plant
3. Deficiencies Found as a Result of the Test, Corrective Actions Planned and Dates by Which Corrections will be Made

Computer Real Time Test

1. Data was recorded and saved verifying computer real time during normal, abnormal, and emergency situations.
2. Not related to reference plant fidelity.
3. No deficiencies were identified.

Normal Operation Test

1. Normal operation procedures were completed, signed and attached. ICs were established and stored.
2. Baseline data used was the ANO Unit 2 Operating Procedures, 2102 series. These procedures direct operations for 100% power to cold shutdown and back to 100% power.
3. Fourteen discrepancies were identified, none of which were evaluated as to have a negative impact on training. All fourteen have been corrected.

Steady State Operation Test

1. Steady state data was collected for 30%, 60% and 100% power. This data was tape saved and compared to plant data.
2. Baseline data used was from plant computer logs.
3. No deficiencies were identified.

Surveillance Test

1. Surveillance procedures were completed, initialed and attached.
2. Baseline data used was the latest revision of ANO Unit 2 Plant Surveillance Test Procedures.
3. Five deficiencies were identified, none of which were evaluated as to have a negative impact on training. All five have been corrected.

Transient Test

1. Transients were run until such time that a stable, controllable and safe condition was attained which could be continued to a cold shutdown condition. Data was collected, saved and compared to baseline data.
2. Baseline data for 7 of the transients performed consisted of plant transient reports from ANO Unit 2. Baseline data for the other 2 transients performed consisted of sections from the ANO Unit-2 FSAR.
3. Five discrepancies were identified, none of which were evaluated as to have a negative impact on training. All five discrepancies have been corrected.

Malfunction Test

1. For malfunctions that did not result in a plant trip but did require a shutdown, the malfunction test was terminated when the shutdown was initiated.

For malfunctions that did result in a plant trip (automatic or manual), the malfunction test was terminated when the plant was being controlled in accordance with the appropriate section of the EOP.

For malfunctions that were not covered by the above, the malfunction test was terminated when the plant reached stable conditions.

2. The anticipated plant response, detailed on the APR form gives initial plant response. These responses were obtained by discussion between Training and Operations department personnel and were approved by SRO Licensed representatives of each group.

The simulator was operated in accordance with approved plant procedures. Symptoms, automatic actions, and plant response described in these procedures were used to evaluate simulator performance and there was no need to attempt to define every possible alarm or response in the malfunction test body.

3. Twenty deficiencies were identified, none of which were evaluated as to have a negative impact on training. All twenty have been corrected.

Included as an Attachment (see Attachment 1) to this letter are the "Anticipated Plant Response" sheets.

A-2. At the time Exception 2 was written, the interpretation of Section 4.3 of ANSI/ANS 3.5-1985 was that an "Operating Limit" is a limit on the simulator which caused a "Blow Up" or the simulator could not handle the condition it was placed in. In December of 1987, there was considerable confusion in the industry regarding the "Operating Limit". Mr. Wachtel was contacted to obtain clarification. He was told that to this date (12/87) there was not a condition into which the simulator was placed that would cause "Negative Training". He was told that our options were to create an operating limit with no basis or to take an exception and our decision was to take an exception. He agreed.

The statement in Items 6.1.3f and 6.3.3f, Attachment 3 of the submittal, "Simulator Fidelity Testing Guideline" of the submittal, was included to reflect the interpretation as stated above. If the simulator "Blew Up" or could not handle the condition it was placed in, then the test would have been terminated and deemed unsatisfactory. At that time if the condition could not be corrected, then according to Exception 2 an operating limit would have been established. If this interpretation, as stated in Exception 2, was still being used, then the means for alerting the instructor would still not be needed.

However, in September of 1988, this section was re-evaluated. The following items were determined necessary to satisfy Section 4.3 of ANSI/ANS 3.5-1985.

1. Containment Pressure High > 60 psig
2. Containment Pressure Low < 10 psig
3. Containment Temperature > 460° F
4. RCS Pressure > 2750 psia
5. S/G Pressure > 1200 psia
6. Core Exit Thermocouple > 1200° F
7. Core Power > 3000 MWth
8. RCS Two-Phase Flow
9. RCS T_{HOT} > 700° F
10. S/G Overfill

These operating limits have been implemented and tested. A flashing light on the instructor station is in place to alert the instructors that an operating limit has been reached.

A-3. The following were performed as transient tests:

- 1) Turbine Trip/Reactor Trip, High MSR Level
- 2) "A" MSIV Closure
- 3) Main Turbine Runback
- 4) Loss of Circulating Water
- 5) "D" RCP Trip/Reactor Trip
- 6) Reactor Trip, "A" SG Level
- 7) Partial Loss of Off-Site Power (Natural Circulation)
- 8) Main Steam Line Break
- 9) Loss of Coolant Accident

As stated in Item I.B, "Transient Testing", of the abstract, the purpose of this test was to ensure that simulator performance was consistent with real plant performance in areas where documented plant response is available. ANO Unit 2 Transient Reports and Licensing Event Reports were utilized to select the transients included in this section. In addition, the Safety Analysis Report was used as a standard for two of the transients selected. In all cases, the selection process for which transients would be performed was to match the list in Appendix B of ANSI/ANS 3.5-1985 as closely as possible while using best available plant data to compare the results. In December of 1987, Mr. Wachtel was informed of this process we were using to determine what the transients we tested would be. That is, we would use documented plant transients to evaluate simulator fidelity. Additionally, we would use the FSAR as a basis for the LOCA and MSLB because that is the best (only) information available.

The maximum power ramp (100% down to approximately 75% and back to 100%) was not chosen as a transient test due to the nature of operation at ANO-2. The power manipulation is controlled manually and the probability of being able to exactly replicate the test each year and produce comparable results would be nearly impossible.

A-4. Attachment 3, "Simulator Fidelity Testing Guideline" has recently been revised. (See Attachment 2.) During this review, several items were added to Section 4.1.c. The statement concerning 25% of the malfunctions being tested annually was one of the items added.

Also, refer to the operability test included with the submittal. On page 3, Item 1.0, 4, states as a purpose of the Simulator Operability Test, "test a minimum of 25% of malfunctions in ANS-3.5, 1985, 3.1.2".

A-5. Attachments 7, 8 and 9, "Simulator Modification Control Guidelines", "Simulator Design Control Guidelines", and "Simulator DCP Control Guideline", have recently undergone extensive review and revision. The "Simulator Design Control Guideline" has been incorporated into the "ANO Training Administrative Guideline: Simulator Modification Control". The "Simulator DCP Control Guideline" has been replaced with the "ANO Training Administrative Guideline: Documents Which Affect Training". Copies of these have been provided as attachments to this letter. (See Attachments 3 & 4.)

These documents reflect the simulator modification and the design control process.

A-6. The version (Rev. 0) of the Simulator Operability Test included with the submittal has undergone two revisions. The latest revision is included as an attachment (see Attachment 5) to this letter.

The tests performed for initial certification are a subset of the enclosed Simulator Operability Test. The tests listed in Rev. 0 of the Simulator Operability Test were performed for initial certification.

Refer to the answer for Question 1 regarding test results.

ATTACHMENT 1
ANTICIPATED PLANT RESPONSE SHEETS

100- Anticipated Plant Response

MANUFACTURER'S TITLE: LOCAL CIVICS RET'D upstream LOHA) DATE PERFORMED: 1/7/1987
PERFORMED BY:

Reactor Coolant System SECONDARY / NO CHARGE

	A	B
Press		
Level		
Flow		
T _h		
T _c		
Taux		
Pin Point		
LO Flow		
Cool Flow		
VCT Flow		
VCT LVL		
VCT Press		
SIT Level		
SIT Press		
OT Temp		
OT Lvl		
OT Press		

	CONTAINMENT	RADIATION MONITORING
Press	15	
Temp		
Surge Lvl		
Humidity		
MS Line	X	
Port Head		
Vacuum Line		
SG Sample		
Cans		

OTHER UNIQUE PARAMETERS / RECORDS

LDFCV with flow demands for the
stirring gear outlet (based on per local). The
LO Reactor pressure regulator will allow down
to control pressure. VCT levels will decrease
as a note. Demand on the aux & HLR back.
For Demand (pressure) will be settle based
on the demand side.

DE 87-153
H2 Flow was 28 gpm every
with back pressure REG values
closed.

ACCEPTED:

John D. Johnson

APPROVED: 1/7/1987

TOO many Anticipated "Plans" Reg posse

Malfunction Title: Loss of CGW to L/D HX Date performed: 11/4/87 Performed by: Alfred

Reader Coolant System		SECONDARY N/C		OTHER UNUSUAL PARAMETERS / TRIGARDS	
A	B	A	B	RESULTS	
Press	1	MS Flow		Tensi out of L/D HX will incase Boronone Ten and Reactor, Tor with isolate 3-way valve will shift TIO bypass D/I's	
Level	1	MFW Flow			
Flow	1	SG Press			
Th	1	SG Line			
Tc	1	GAS LINE			
Tong	1	HDF Flow			
Br Pwr	1	CORE Flow			
uG Flow	1	COLS PWR			
Chg Flow	1	MFP SPEED			
VCT LVL	1				
Vct Press	1				
SIT Level	1				
SIT Press	1				
OT Level	1				
OT Temp	1				
OT -	1				
ESPEC. ATTENTION		RADITION MGT DRAG		MS Line	
		SG Sample		SG Sample	
		Vacuum Pump		Vacuum Pump	
		Cont. Pump		Cont. Pump	
		CAMS		CAMS	

Approved: 16 Dec 1987 on file

Accepted: 9/10/87 on file

Accepted: 9/10/87 on file

ANTICIPATED PLANT RESPONSE

MALFUNCTION TITLE: Devoid Selected Cooling System Secondary		SECONDARY		OTHER UNIQUE PARAMETERS / TRENDS	
Press	UC	A	B	The zone would tend to move more when demand is indicated on indicated by a car position and sequence orientation	
Level					
Flow					
Tn					
Tc					
Tanx					
Pn_Pwr					
LO Flow					
CW Flow					
VCT LVL					
VCR Press					
SIT Level					
SIT Press	UC				
OT LEVEL					
OT TEMP					
OT_Press					
ESD& ACTUATION		RADIATION MONITORING		CAM S	
MS Line	UC				
SG Sample					
Vacuum Pn					
Carb Area					

(3)

MANUFACTURER TITLE: Delco Sealed Gaseous Nitrogen performed: 1/15/87 PERFORMED BY: *John C. Henningsen*APPROVED: *John C. Henningsen*

on Design

ACCEPTED:

John C. Henningsen

ANTICIPATED PLANT RESPONSE

Malfunction Title: Loss of Both MFP's Date performed: 1/3/91 Performed by: M. Hold

Reactor Coolant System		Secondary		Other Unique Parameters / Trends	
Press level	↑	A	B	The Turbine outlet valve will be fully open due to the operator mode being the plant when loss of all MFP is detected. It will then close with time on the RERL or low steam demand. EGR will activate and reduce SC Demand.	
Flow	↑	↓	↓		
T _h	→	↑	↑		
T _c	↑	↑	↑		
T _{out}	↑	↑	↑		
Out Power	↑	↑	↑		
LO Flow	↑	↑	↑		
Cool Flow	↑	↑	↑		
VCT LVL	↑	↑	↑		
VCT Press	↑	↑	↑		
SIT Level	↑	↑	↑		
SIT Press	↑	↑	↑		
OT LEVEL	↑	↑	↑		
OT TEMP	↑	↑	↑		
OT PRESS	↑	↑	↑		
ESFR ACTUATION		RESULTS		Response was as expected.	
CONTAINMENT					
Press	NC	CONTAINMENT MONITORING			
Temp					
HUMIDITY					
SUMP LVL					
RADIATION MONITORING					
MS Line	UL				
SG Sample					
Vacuum Pump					
CONT. READ					
CAMS					

Approved: 1. Project Manager 2. S. Johnson

Accepted: M. Hold 1/10/91

MANUFACTURER TITLE: Document Title 11

DATE PREPARED: 10/10/2011
PREPARED BY: AP/AD

REACTOR COOLANT SYSTEM		SECONDARY		OTHER UNUSUAL PARAMETERS/TRENDS	
Press	A	B			
Level	C	C			
Flow	-	-			
T _c	R	R			
T _c	R	R			
T _c	R	R			
T _c	R	R			
Out Power	-	-			
LO Flow	-	-			
CHG Flow	-	-			
VCT LVL	-	-			
VCT Press	-	-			
SIT Level	-	-			
SIT Press	-	-			
OT Level	-	-			
OT Temp	-	-			
OT Press	-	-			
ESEAS ACTUATION		RADIATION MONITORING		MS LINE	
SIT		SG Sample		SG Sample	
VACUUM PUMP		VACUUM PUMP		VACUUM PUMP	
CONT. AREA		CONT. AREA		CONT. AREA	
CHAMPS		CHAMPS		CHAMPS	
RESUL TS		RESUL TS		RESUL TS	
CONTAINMENT		CONTAINMENT		CONTAINMENT	
PRESS		PRESS		PRESS	
TEMP		TEMP		TEMP	
HUMIDITY		HUMIDITY		HUMIDITY	
SAMPLE LVL		SAMPLE LVL		SAMPLE LVL	
RADIATION MONITORING		RADIATION MONITORING		RADIATION MONITORING	
MS LINE		MS LINE		MS LINE	
7		7		7	

Approved: 10/10/2011 25 October

Accepted: Michael Mihailovitch

ANTICIPATED PLANT RESPONSE

Malfunction Title: Turbine Trip
Initiator: Turbine Aborted
Performed by: Plant

Reactor Coolant System		Secondary		Other Unusual Parameters / Events	
Press	C	A	B	Turbine trip will cause a shutdown	
Level	C	C		Hx and SG on line	
Flow	↑	↑	↑	SG pump	
T _h	C	C		SG Level	
T _c	C	C		Core flow	
Tang	C	C		HDX flow	
Ex Power	C	C		Core flow	
LO Flow	C	C		COSS flow	
Cry Flow	C	C		MFP speed	
VCT LVL	C	C		Containment	
VCT Press	C	C		Press	
SIT Level	C	C		TEMP	
SIT Press	C	C		HUMIDITY	
OT LEVEL	C	C		SURF LVL	
OT TEMP	C	C		RADIATION MONITORING	
OT Press	C	C		MS Line	
ESF ACTUATION		RESULTS		SG Sample	
		NO UNEXPECTED RESULTS		Vacuum Pump	
				Cont Area	
				CAMS	

APPROVED: L. P. Bennett

REVIEWED: W. A. Anderson

ACCEPTED: W. D. Johnson

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: STX CEA 1 J U DATE PREPARED: 11/5/87 PERFORMED BY: Officer

Reactor Coolant System

SECONDARY

OTHER UNIQUE PARAMETERS / SECONDS

Press	A	B
Press level	NC	
Flow		
T _{in}		
T _{out}		
Taux		
Out Power		
LO Flow		
Cool Flow		
COLS Pure		
MFP Speed		
VCF Flow		
VCF LVL		
VCF Press		

CONTAINMENT

SIT Level	SIT Press	TEMP	HUMIDITY	SUMP LVL	RADIATION MONITORING	MS Line	SG Sample	VACUUM PUMP	CONT PUMP	CAMS
SI T Level										
SI T Press										
SI T TEMP										
SI T HUMIDITY										
SI T SUMP LVL										
SI T RADIATION										
ESD ACUTATION										

APPROVED: 16 Gamma On Order

ACCEPTED: HPC-O/TH/0000

(9)

ANTICIPATED PLANT RESPONSE

MANUFACTURE TITLE: Deepak Lal Motani
Reactor Coolant System Secondary
Date performed: 11/5/87 PERFORMED BY: Mehta
OTHER UNIQUE PARAMETERS / TERMS
10

	Press Level	MS Flow	MC Flow	A	B	
Flow						
Tn						
Tc						
Taux						
Pn Purt						
LQ Flow						
Cool Flow						
VCT LVL						
VCT Press						
	SIT Level	SIT Press	MC Flow	A	B	
SIT LEVEL						
GT TEMP						
GT PRESS						
	ESFC ACTUATION	RADIATION MONITORING	CONTAINMENT	A	B	
MS Line						
SG Sample						
Inium Pmp						
Cont Area						
Cams						

APPROVED: 1. R. Mehta
2. P. Patel

and P. Patel

ACCEPTED: PTC-D/ln leadoff

EDUCATIONAL PLANS - REGIONS

MANUFACTURER'S TITLE: Delco CEA Combiner units presented 1/15/1977 performed by. *[Signature]*

Reactor Coolant System		Secondary		Other Unique Parameters / Trends	
Press	VCR	A	B	C	D
Legal		MS Flow	X		
Flow		MFW Flow			
T _H		SG Press			
T _C		SG Level			
Tang		Gross Pow			
P _n Pow		HDR Flow			
L _O Flow		Cool Flow			
Out Flow		COLSS Pow			
VCT LVL		MFP Spd			
Vcr Press		Containment		RESULTS	
SIT LVEL		Press	X	No Unexpected Results	
SIT Press					
OT LVEL		Temp			
OT TEMP		Humidity			
OT-Press		Sump LVL			
ESEAS ACTUATION		RADIATION MONITORING			
MS Line	X	MS Line	X		
SG Sample		SG Sample			
Vacuum Pwd		Vacuum Pwd			
CONT Agent		CONT Agent			
CAMS		CAMS			

Approved: 1 Feb 2010

ACCIDENTS:

AU 11C 14450 PLANS REGISTRATION

MATERIALS AND METHODS: Unpublished data from 11/5/87 prepared by: Robert S. Cawley

Revolver Co. Ltd + 2736m

OT 23410 2013 PRECIPITATION / THERMALS

CEP under more or less one demand
depending on whether a DCEP would

The question would follow the hope which
would call for terminating the reaction.
His hands were now burning & dry

卷之三

NO UNPREDICTED RESULTS

* These parameters did not change due to test being performed below the ~~post~~

note

W.W. W.

Approved: 1-26-04

RECORDED DATE: 12/21/1999 UNCLAS - INFORMATION

AUTOMATIC PLANT RESPONSE

MANUFACTURER TITLE: SGTR (CCP CARRY), ALPHA A/4 DATE PERFORMED: 11/3/97 PERFORMED BY: Phil

Secondary		Secondary		Secondary		Secondary		Secondary		Secondary		Secondary		Secondary		Secondary		Secondary		Secondary			
Reactor Coolant System		SGTR (CCP CARRY)																					
Press'	→ +	A	B	A	B	A	B	A	B	A	B	A	B	A	B	A	B	A	B	A	B	A	B
Level'	→ +	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
Flow	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
Tc	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
Tang	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
Pa/Rewr	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
IG Flow	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
VCT/LVL	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓
VCR Press'	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓	↓
SIT Level	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
SIT Press'	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
OT Level	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
OT Temp	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
OT Press	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
ESD/S Actuations	YES	YES	YES	YES	YES																		
MS Line	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
SG Sample	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
Incubator	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑
Cans	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑	↑

OTHER UNIQUE PARAMETERS / RECORDS

Three draws on water from 1000 liter tank
as measured by True air EOP. Used less pressure
as required, based on the effect atom generation
will increase.

RESULTS

* A MFLU flow + AS EXPECTED

* A 5/4 level + AS EXPECTED
* Cross pur + slightly due to MFLU +

Note: SGTR was going strong MFLU
+ draw of pressurized water
+ draw of pressurized water
+ draw of pressurized water

YES - SIDS YES

ADDITION: 11/3/97, 11:57 AM

ADDITION: NO. 011, 11/3/97

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: SGTR (w/o CCP chart), DATE PERFORMED: 1/3/07, PERFORMED BY: Oh, Labr		OTHER UNIQUE PARAMETERS / TRENDS	
SECONDARY			
		A	B
Press Level	→ →	MS Flow → →	→ →
Flow	↑ ↑	MFW Flow ↑ →	↑ →
T _h	↑ ↑	SG Press ↑ ↑	↑ ↑
T _c	↑ ↑	SG Level ↑ ↑	↑ ↑
T _{out}	↑ ↑	Geo Flow ↑ ↑	↑ ↑
On Power	↑ ↑	HOR Flow ↑ ↑	↑ ↑
LO Flow	↓ ↓	Cool Flow ↑ ↑	↑ ↑
Cry Flow	↓ ↓	COLSS Purge ↑ ↑	↑ ↑
VCT LVL	↓ ↓	MFP SPEED ↑ ↑	↑ ↑
VCT Pres	→ →	Containment → →	→ →
SIT Level	↑ ↑	Press ↑ ↑	↑ ↑
SIT Press	↑ ↑	TEMP ↑ ↑	↑ ↑
OT LEVEL	↑ ↑	Humidity ↑ ↑	↑ ↑
OT TEMP	↑ ↑	Sump LVL ↑ ↑	↑ ↑
OT. Press	↑ ↑	RADIATION MONITORING	
ESEAS ACTUATION		MS Line ↑ ↑	↑ ↑
NONE		SG Sample ↑ ↑	↑ ↑
In�ual Pump		Contain Pump ↑ ↑	↑ ↑
Cont. Pump		Cams ↑ ↑	↑ ↑

TERMINATION: Run until SGTR indications are available.

No unexpected results

Accepted: John M. Miller

Approved: John M. Miller

Date: 25 Jan 2007

ANTICIPATED PLANT RESPONSE

MALFUNCTION TITLE: LOCAL (AEGEAN) (CONT.)

DATE PERFORMED: 11/4/87 PERFORMED BY: Alfred

REACTOR COOLANT SYSTEM		SECONDARY			
OTHER UNIQUE PARAMETERS/TESTS					
the reactor will have quenching in low Dose/ Reactor pressure. Operation will follow EOP requiring RCP termination. RC press will quenching fail to shutdown and continue decreasing. RC temperature will allow due to injection. RAS and MMS will activate over time.					



CONSTRAINTS

SIT LEVEL	SIT PRESS	TEMP	HUMIDITY	SUMP LVL	RADIATION MONITORING
+	+	↑	↑	↑	MS Line
-	+	↓	↑	↑	SG Sample
-	-	+	↑	↑	Vacuum Pump
-	-	-	↑	↑	Cont. Pump
-	-	-	-	↑	Cams

ESFR ACTUATION
YES SIRS, C13, CSRS,

NO UNEXPECTED RESULTS

NOT	NO UNEXPECTED RESULTS
NO	NO UNEXPECTED RESULTS

NOTE: After initial dose and flow
 levels or pipe burst, the
 system for normal
 operation will

APPROVED: John Bennett 20-02-92

ACCEPTED: John Bennett 20-02-92

16

ANTICIPATED "PLAN" RESPONSE

MALFUNCTION TITLE: Loss of CHP & loss of circ DATE PERFORMED: 1/1/17 PERFORMED BY: Shabir

REACTOR COOLANT SYSTEM		SECONDARY		OTHER UNIQUE PARAMETERS / TERMS	
		A	B		
Press	→	MS Flow	↑		
Level	→	MEN Flow	↑		
Flow	↑	SG PEGS	↑		
T _H	↑	SG Level	↑		
T _C	↑	GEO PMS	↑		
Tang	↑	HDP Flow	↑		
On Power	↑	CORE Flow	↑		
LO Flow	↑	CLOS Flow	↑		
Cry Flow	↑	MFR Sprng	↑		
VCF LVL	↓				
VCF Press	↓				
SIT Level	↑				
SIT Press	↑				
OT LEVEL	↑				
OT TEMP	↑				
OT Press	↑				
ESF ACTUATION		RADIATION MONITORING			
MS Line		MS Line	↑		
SG Sample		SG Sample	↑		
Innum Pmp		Innum Pmp	↑		
Cont Area		Cont Area	↑		
CAMS		CAMS	↑		

No Unexpected Loss/D

RESULTS

Accepted: R Bennett 2/2/2018

Approved: R Bennett 2/2/2018

DOCUMENT - ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: NSLB (LICENSING OFFICE)
DATE PERFORMED: 11/4/87 PERFORMED BY: Howard

Reactor Coolant System

		SECONDARY		OTHER UNIVALE PARAMETERS / TRENDS	
		A	B		
Press	→	MS Flow	↑ ↓ ↑ ↓	The plant will then shutdown (Basic, no SC Press - -)	
Level	↓	MFR Flow	↑ ↓ ↑ ↓	at which time the affected s/c press will	
Flow	↑ ↓	SG PPGES	↑ ↓ ↑ ↓	continue to decrease if the other will increase with	
Th	↑ ↓	SG Level	↑ ↓ ↑ ↓	The affected s/c Doda dry.	
Tc	↑ ↓	Gross Pow	↑ ↓ ↑ ↓		
Tang	↑	HDR Flow	↑ ↓ ↑ ↓		
Pn Power	↑ ↓	Cool Flow	↑ ↓ ↑ ↓		
LO Flow	↑ ↓	Cool Pow	↑ ↓ ↑ ↓		
Cool Flow	↑ ↓	MFP Speed	↑ ↓ ↑ ↓		
VCT LVL	↑ ↓	VCT Press	↑ ↓ ↑ ↓		
CONTAINMENT					
SIT Level	↑	Press	↑ ↓ ↑ ↓		
SIT Press	↑	Temp	↑ ↓ ↑ ↓		
OT Level	↑	Humidity	↑ ↓ ↑ ↓		
OT Temp	↑	Sump Lvl	↑ ↓ ↑ ↓		
OT Press	↑	RADIATION MONITORING			
ESEAS ACTUATION		MS Line	↑ ↓ ↑ ↓		
YES: SIGS, CIS, CSAs, MSIS		SG Sample	↑ ↓ ↑ ↓		
		Vacuum Pump	↑ ↓ ↑ ↓		
		Cont Area	↑ ↓ ↑ ↓		
		Cham S	↑ ↓ ↑ ↓		
<i>Approved: <u>Howard</u> M. O'Connell Date: <u>11/4/87</u></i>					
<i>Accepted: <u>Howard</u> M. O'Connell Date: <u>11/4/87</u></i>					

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: MSB (Large, Heavy, Non) DATE PERFORMED: 1/4/87 PERFORMED BY: C. Anderson

Reactor Coolant System

SECONDARY OTHER UNIVALENT PARAMETERS / TRENDS

	A	B
Press	1	1
Level	1	1
Flow	1	1
Tn	1	1
Tc	1	1
Taux	1	1
On Power	1	1
LO Flow	1	1
Cry Flow	1	1
VCT LVL	1	1
VCT Press	1	1
SIT Level	1	1
SIT Press	1	1
OT LEVEL	1	1
OT TEMP	1	1
OT Press	1	1
ESF ACTUATION	1	1
YRS - MYSIS / SIDS	1	1

The reactor will then switch on Dura on low SG pressure. This will decrease initial MSIS actuation at which time the SG will rapidly and permanently will increase. EFW will activate 2 low hole generators.

CONTAINMENT

Press	1	1	1
TEMP	1	1	1
Humidity	1	1	1
Sump LVL	1	1	1
RADIATION MONITORING	1	1	1

MS Line	1	1	1
SG Sample	1	1	1
Instrument Pd	1	1	1
Containment	1	1	1
CAMS	1	1	1

RESULTS

NO INEXPRESSED RESULTS

APPROVED: [Signature] Date: [Signature]

ACCEPTED: [Signature] Date: [Signature]

ANTICIPATED PLANT RESPONSE		UNIQUE PARAMETERS / SECONDS	
MALFUNCTION TITLE: Clean Lake (Small)		DATE PERFORMED: 11/14/00	
REACTOR COOLANT SYSTEM		SECONDARY	
Press	→ ↓	A	B
Level	↓ →	MS Flow	↓ ↓
Flow	→ ↑	MFC Flow	↑ ↓
Tn	→ ↓	SG Press	↓ ↓
Tc	→ ↓	SG Level	↑ ↓
Tong	→ ↓	Gas Flow	↓ ↓
Br Pwr	↑ ↓	HDF Flow	→ ↓
LO Flow	↓ →	Cool Flow	↑ ↓
CHG Flow	↓ →	COLSS Flow	↓ ↓
VCT LVL	→ ↓	MFP SPEED	→ ↓
VCT Press	↓ →	CONSTRAINT	
SIT Level	→ ↓	Press	NC
SIT Press	→ ↓	TEMP	↓ ↓
OT LEVEL	→ ↓	HUMIDITY	↓ ↓
OT TEMP	→ ↓	SURF LVL	↓ ↓
OT Press	→ ↓	RADIATION MONITORING	↓ ↓
ESEAS ACTUATION		MS Line	NC
WIRE		SG Sample	↓ ↓
VACUUM LINE		CONT PWR	↓ ↓
CONT PWR		CAMS	↓ ↓

APPROVED: 1. to Reactor Tech Division

REPORTER: Reactor Tech Division

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: PWR Sim-Space Line (Large)		DATE PERFORMED: 11-4-87		PERFORMED BY: [Signature]			
REACTOR COOLANT SYSTEM		SECONDARY					
		OTHER UNIQUE PARAMETERS / RECORDS					
Press	A →	A	B	(Assume that operator stops RCP at < 30 MTS.)			
Level	↓ *	→		The plant will have quenching or worse/no press.			
Flow	↑	→		When DC press decreases the header set (or Head)			
T _c	↑	→		pressure a bubble will form in the RV			
T _e	↑	→		Bubbles remaining per head.			
Taux	↑	→					
Pn_Pwr	↑	→					
LO Flow	↓ *	→					
Cry Flow	↓ *	→					
VET LVL	↓ *	→					
VCF Press	↓ *	↑					
SIT Level	→			Containment	RESULTS		
SIT Press	↓	→					
OT LEVEL	↓	→					
OT TEMP	↓	→					
OT Press	↓	→					
EFCAS ACTUATION							
YES - EFCAS, CFS, CFS							
depending on size							

MS Flow	NC		
MEW Flow			
SG POGGS			
SG LEVEL			
GEO MW			
HDP Flow			
CORE FLOW			
COLSS FLOW			
MFP SPEED			
VCF LVL			
VCF Press			
SIT Level	→		
SIT Press	↓	→	
OT LEVEL	↓	→	
OT TEMP	↓	→	
OT Press	↓	→	
RADIATION MONITORING			
MS Line	↓		
SG Sample	↓		
Vacuum Pump	↓		
Cont Area	↓		
CAMS	↓		

* COMPENSATED PZR LVL ↑
 UNCOMPENSATED LVL ↑ AS EXPECTED
 CAUSING CVCs PARAMETERS TO RESPOND
 AS THEY SHOULD.
 ** CAMS SHOWED NO INCREASE DUE TO SIAS/SOC.
 CONTAINMENT PARAMETERS DIDN'T RESPOND.

DD 87-307
 Cleared


Accepted: W. Teal / Chapt. 6
 12/1/87

Approved: J. Belmont / 2nd Review

ANTICIPATED PLANS RESPONSE

MALEFUNCTION TITLE: Pre Safety Valve Fail Date Recommended: 11/15/87 performed by: Glenn

REACTOR COOLANT SYSTEM		SECONDARY		OTHER UNIQUE PARAMETERS / RECORDS	
Press	↓	A	B	Pre setting will remain at 100% power during normal reactor or steam generator transient. The OT parameters, acoustic nature & radiation levels will change. OT. parameters will increase with nuclear chain activation at which time levels will go to saturation or cont. prior to containment parameters will start to increase. Pre lvl will decrease until water in head reaches T-set at which time level will increase. It increases with the OT in sufficient, contained parameter will ↑.	
Level	↓	MS Flow	NY		
Flow	↓	MFCW Flow			
Tn	↓	SG Press			
Tc	↓	SG Level			
Tong	↓	GEO MW			
On Power	↓	HDR Flow			
LO Flow	↓	CORE Flow			
CHG Flow	↓	COLSS PWR			
VCT LVL	↓	MFP SPEED			
VCT Press	↓				
CONSTRAINT		RESULTS			
SIT Level	↓	PC	↑	* compensated pre level ↓, uncompensated lvl ↑ as expected, causing cucs parameters to respond as expected	
SIT Press	↓	TEMP	↑	** constraint parameters increased as expected.	
OT LEVEL	↑	HUMIDITY	↑		
OT TEMP	↑	SUMP LVL	↑		
OT. Press	↑	RADIATION MONITORING			
ESCAPES ACTUATION		SITAS,			
		MS Line	NY		
		SG Sample			
		Vacuum Pump			
		Cont. Pump			
		CAMS			

APPROVED: G. Brown +  for PWR

REPORTED: D. A. M. Duggan 

REACTOR - REACTOR SYSTEM
ANTICIPATED PLANS - REACTOR SYSTEM

MALFUNCTION TITLE: fire spray valve fails OPEN DATE PERFORMED: 1/5/87		PERFORMED BY: C. Anderson	
Reactor Coolant System		OTHER UNIQUE PARAMETERS / TRENDS	
Press	↓	A	B
Level	↑	MS Flow	NC
Flow	↑	MFW Flow	
T _h	↑	SG PEGS	
T _c	↑	SG Level	
Taux	↑	Gros MWS	
On Power	↑	HDR Flow	
LO Flow	↑	Cool Flow	
Cry Flow	↑	Cold Spray	
VCF LVL	↑	MFP SPEED	↓
VCF Press	↑	CONTAINMENT	
SIT Seal	↑	Press	NC
SIT Press	↑	Temp	
OT LEVEL	↑	Humidity	
OT TEMP	↑	Sump Lvl	
OT. PEGS	↑	RADIATION MONITORING	
ESD ACTUATION		MS Line	N
SIM POSSIBLE		SG Sample	
		Vacuum Pump	
		Cont Area	
		Comms	

RESULTS		DISPENSER	
After tripping the first 2 rep's "C" & D an abnormally high Sig DP developed.		DR P7 - 309	
This does not result in negative tripping			
MS Line	N	SG Sample	
Vacuum Pump		Cont Area	
Cont Area		Comms	

APPROVED: 1. C. Anderson

2. C. Anderson

DATE: 1/5/87 APPROVED: C. Anderson

MALFUNCTION TITLE: Loss of 1 MFP (A pump) Date Preceded: 11/3/87 PERFORMED BY: Lang

Reactor Coolant System

SECONDARY		OTHER UNIQUE PARAMETERS / TRENDS	
		A	B
Press level	↑	MS Flow ↓ + ↑	The turbine will not reach 70% power.
Flow	↑	MFP Flow ↓ + ↑	The operator will need crs (on AOP)
Th	↑	SG Press ↓ + ↑	The water & Tong's Turb. Turbine bypass valve will open in reverse to remove excess energy.
Tc	↑	SG Level ↓ + ↑	
Tong	↑	Gen MFP ↓ + ↑	
Boil Powr	↓	HDP Flow ↓ + ↑ *	
LO Flow	↑	Cool Flow ↓ + ↑	
Cry Flow	↑	Cool S. Pump ↓ + ↑	
VCF LVL	↑	MFP SPEED ↓ + ↑	
VCF Press	↑	CONTAINMENT	
SIT LEVEL	↑	Press ↓ + ↑	* HDP flow ↓ due to lower power level.
SIT Press	↑	Temp ↓ + ↑	** A MFP SPEED + ON LOSS OF A MFP
OT LEVEL	↑	Humidity ↓ + ↑	B MFP SPEED + ON LOSS OF 8 MFP
OT TEMP	↑	Sump LVL ↓ + ↑	
OT. Press	↑	RADIATION MONITORING	
ESSENTIAL SITUATION		MS Line ↓ + ↑	
		SG Sample ↓ + ↑	
		Vacuum Pump ↓ + ↑	
		Containment Cameras ↓ + ↑	

OTHER UNIQUE PARAMETERS / TRENDS

RESULTS

- * HDP flow ↓ due to lower power level.
- ** A MFP SPEED + ON LOSS OF A MFP
- B MFP SPEED + ON LOSS OF 8 MFP

Accepted: Lang Date: 11/3/87

Approved: 1 R. Bennett Date: 11/3/87

Accepted: Lang Date: 11/3/87

AUTOCIPATED PLANT RESPONSE

MANUFACTURER TITLE: MEIN ~~Initials~~ Date prepared: 1/3/87 performed by: ~~Initials~~ 24

Reactor Coolant System Secondary

OTHER UNIQUE PARAMETERS / SECONDS

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z
Press	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Level	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Flow	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Tn	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Tc	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Tang	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
On Power	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
LO Flow	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Cry Flow	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
VCT LVL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Vct Press	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
SIT LEVEL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
SIT PRESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
OT LEVEL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
OT TEMP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
OT PRESS	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
ESD ACTUATION	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
MS Line	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
SG Sample	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Vacuum Pump	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Cont Area	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Cams	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

Fus Pow to the Headers s/c and increase
on valve demand. Pow to the operate s/c
will decrease initially until Fus
consumes. S/c Demand will continue
to increase until Duct MPV are taken
the demand l. speed is reduced to control
head rate. The operate MPV will open
to accommodate for decrease in Fus Pow/Demand.

RESULTS

#CCS Trans charges were minimized due to prompt, cont
operator action.

No Unexpected Results

CONTAINMENT

Press

Temp

Humidity

Sump Lvl

RADIATION MONITORING

MS Line

SG Sample

Vacuum Pump

Cont Area

Cams

Accepted: Michael M. Williams

Approved: I. R. Bennett
Date: Pending

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: Failure of Rx trip logic attempted: 1/25-87 PERFORMED BY: C. A. Lamm		OTHER UNIQUE PARAMETERS / TERMS	
SECONDARY		A	B
Press Level			
Flow			
T _h			
T _c			
T _{ave}			
On Purge			
LO Flow			
CHG Flow			
VCT LVL			
VCT Press			
SIT Level			
SIT Press			
OT Level			
OT Temp			
OT - Press			
EQUIP. ACTUATIONS		RADIATION MONITORING	
MS Line		MS Line	
SG Sample		SG Sample	
Inventoried		Inventoried	
Cont. Brain		Cont. Brain	
CAMS		CAMS	

APPROVED: Handwritten signature

ACCEPTED:

Handwritten signature

DOCUMENT NUMBER: REC'D DATE

MALFUNCTION TITLE: NO. 1 TURBINE PRECOOLER: 1/1-1/87 PERFORMED BY: Creel

26

REACTOR COOLED SYSTEM		SECONDARY		OTHER UNUSUAL PARAMETERS TESTED	
Press	↓	A	B	to be recorded by shift	
Level	→	↓	↑	changing and random	
Flow	→	↓	↑	random and unrecorded	
T _h	→	↓	↑		
T _c	→	↓	↑		
T _g	→	↓	↑		
P _g P _{ur}	→	↓	↑		
L ₀ Flow	→	↓	↑		
C ₁ Flow	→	↓	↑		
VCT L _{in}	→	↓	↑		
VCT Press	→	↓	↑		
SIT Level	→	↓	↑		
SIT Press	→	↓	↑		
OT Level	→	↓	↑		
OT Temp	→	↓	↑		
OT Press	→	↓	↑		
ESCAPE ACCUMULATION	→	↓	↑		
CAMS	→	↓	↑		
CONT. Freq	→	↓	↑		
LEVEL PUMP	→	↓	↑		
SG Sample	→	↓	↑		
MS Line	→	↓	↑		

APPROVED: 1/10/87

BY: O. D. J.

ACCEPTED: 1/10/87

BY: J. C. Creel

ARDO PLAN: RESPONSIVE

Malfunction Title: Loss of AC (Bussel) U units demanded! 11-5/87 performed by: C. A. (21)

Rambar Coolant System

Press Level	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z
MS Flow	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
MEW Flow	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
SG Press	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
SG Level	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
Gross Min	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
HDP Flow	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
Cool Flow	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
Cross Flow	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
MPF Spand	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
SG Flow	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
VCT Lvl	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
VCT Press	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
SIT Level	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
SIT Press	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
OT Level	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
OT Temp	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
OT Press	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
ESFCR Fluctuation	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
MS Line	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
SG Sample	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
Vacuum Pump	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
Cont. Pump	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	
Cams	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	△	

OTHER UNUSUAL PARAMETERS / EVENTS

Due to the variety of buses that can be lost the Test Director should verify that all loads associated with the selected bus deenergizes

RESULTS

- Main Chiller tanks
- 40 reservoir minor expansions
- Rad monitors
- DR - 87 - 310
- 87-311
- 87-312

Approved: R. Chittenden 20 Dec 91

Accepted: R. Chittenden 20 Dec 91

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: Lenz & DC Bus 1 Date Performed: 11-6-87 performed by: J. Scheck		OTHER UNIQUE PARAMETERS/TERMS	
Secondary			
Press	A	B	Due to the variety of buses that can be lost. The test direction should verify that all loads associated with the selected bus deenergizes.
level	MS Flow		
Flow	MFC Flow		
Th	SG Press		
Tc	SG Level		
Tang	GND MUS		
Px Power	HDF Flow		
LO Flow	Cool Flow		
Cry Flow	Cool Pure		
VCT LVL	MFP Speed		
VCT Press	Containment		DE's 87-313 87-314 87-315
SIT Level	Press		
SIT Press	Temp		
OT Level	Humidity		
OT Temp	Sump Lvl		
OT Press	RADIATION MONITORING		
ESEAS ACTUATION			
MS Line			
SG Sample			
Inum Pump			
Cust Pump			
CAMS			

These dimensions were minor and do not result in nucleus framing.

Approved: J. H. Scheck 25 Dec 87

Accepted: David H. McCallum

AUXILIARY PLANT RESPONSE

MALFUNCTION TITLE: Dropped CEA (M02)		DATE PERFORMED: 1/14/87		PERFORMED BY: Phil (L1)	
Reactor Coolant System		SECONDARY		OTHER UNIQUE PARAMETERS / TERMS	
Press Level	↓	A	B	The operation will demand per AOP due to reducing turbine load to match TWR. The plant will be able to do some power with the reduction of charged CEA. Depending on load, a burner in UT pool could start. (constant to Quadwell)	
Flow	↑				
T _h	↑				
T _c	↑				
T _{ex}	↓				
Out Power	↓				
LO Flow	↓				
Cry Flow	↓				
VCT LVL	↓				
VCT Press	↓				
SIT Level	↓				
SIT Press	↓				
OT Level	↓				
OT Temp	↓				
OT Press	↓				
ESF ACTUATION		RADIATION MONITORING		Data - File but to reduce power Feed Water Temp / TWR + under TWR open	
MS Line		MS Sample		File Feed Water Temp / TWR + under TWR open	
SG Sample		Vaccum Pump			
Cont Area		CAMS			

APPROVED: 1/14/87 - Phil

ACCEPTED: 02/01/87 - Phil

W

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: TBV AND EGGS & FLOW THERM. DATE PERFORMED: 11-5-97
REACTOR COOLANT SYSTEM

	SECONDARY	OTHER UNIQUE PARAMETERS / TERMS
Press	↓	A B P ↑ P ↑
Level	↓ -	MFS Flow P ↓ P ↑
Flow	→ -	MFW Flow → -
T _n	↓ -	SG PAGES ↓ -
T _c	↓ -	SG LEVELS ↓ -
T _{out}	↓ -	GAS FLOW ↓ -
Re. Power	↑ -	HDR FLOW ↓ -
LO Flow	↓ -	CORE FLOW ↓ -
Cool Flow	↑ -	COLSS FLOW ↓ -
VCT LVL	↓ -	MFP SPEED ↓ -
VCT Pres	↓ -	CONSTANT DENSITY ↓ -
SIT Level	→ -	PRESS ↓ -
SIT Press	→ -	TEMP ↓ -
OT LEVEL	→ -	HUMIDITY ↓ -
OT Temp	→ -	SURF LVL ↓ -
OT. Press	→ -	RADIATION MEASUREMENTS ↓ -
ESFA's ACTUATION		MS LINE ↓ -
		SG Sample ↓ -
		Valve/Line Pwd ↓ -
		CONST. PRES ↓ -
		CAPS ↓ -

()
OTHER UNIQUE PARAMETERS / TERMS

Simulator will be at ≈ 270 FP & PFB NO
MFW pumps.

No unexpected results

APPROVED: 1. K. Clark
2. Director

REVIEWED: 1. K. Clark
2. Director

ACCEPTED: 1. K. Clark
2. Director

AUTOCAPTURED PLANT RESPONSE

MANUFACTURE TITLE: Loss of SGU & SGU & Piping		TEST DATE: 4-87		PERFORMED BY: J. Blum	
Reactor Coolant System		Secondary		OTHER UNIQUE PARAMETERS / RECORDS	
Press	↑	A	B	SAC return temperature and increase followed by soc and time in the PCT time increase. CET's would follow.	
Level	↑	MS Flow	NC		
Flow	→	MEW Flow	NC		
T _h	↑	SG PRESS			
T _c	↑	SG LEVEL			
T _{out}	↑	GEO MIN			
Boil Power	↑	HOP Flow			
LO Flow	↑	CORE Flow			
Cool Flow	↑	COLSS RUSE			
VCT LVL	↑	MEP SPEED			
VCT PRESS	↑	CONTAINMENT		RESULTS	
SIT Level	↑	Press	NC	RESPONDED AS EXPECTED	
OT PRESS	↑			TEMP	
OT LEVEL	↑			HUMIDITY	
OT TEMP	↑			SUMP LVL	
OT PRESS	↑			RADIATION MONITORING	
ESEFA ACTUATION				MS LINE	
ESFAC ACTUATION				SG Sample	
ESFAC ACTUATION				Infrared	
ESFAC ACTUATION				Port Head	
ESFAC ACTUATION				CAMS	

Approved: J. K. Edelton

Date: 2/20/98

Accepted: J. Blum

W

ANTICIPATED PLAN RESPONSE

MANUFACTURE TITLE: Loss of SW. to Components DATE PERFORMED: 11-5-03 PERFORMED BY: Dan Schulte

Reactor Coolant System		SECONDARY		OTHER UNIQUE PARAMETERS / TRENDS					
Press level	A B								
MFS Flow									
MFW Flow									
SG Press									
SG Level									
GRD Flow									
HDP Flow									
Cool Flow									
COLSS Flow									
MFD Speed									
LO Flow									
CH Flow									
VCT LVL									
Vcr Press									
SIT Level									
SIT Press									
OT LEVEL									
OT TEMP									
OT Press									
ESCAPES ACTUATION		PREPARATION MONITORING		MS Line					
SIT Sample		Vacuum Pwd		Cont Area					
CAMS									
<u>TESTED components</u>									
• E04-B									
• T/Lube Oil Cooler									
• MFWP 40 are									
• CCM NX - Loop 2									
• SCL etc									

APPROVED: I. R. Schulte and Gordon

ACCEPTED: D. M. Hartman

AUSTICIPATED PLANT RESPONSE

MAJFUNCTION TITLE: Loss of A HOP' J U DATE PERFORMED: 1/3/87' PERFORMED BY: John J. (23)

Reactor Coolant System		Secondary		Other Unique Parameters / TRENDS	
Press	NC	A (TRIMD)		This will start the other condensate pump to cause the SG Line pump to open. MFP will decrease slightly due to the pressure decrease.	
level		—	—		
Flow		—	—		
Th		—	—		
Tc		—	—		
Tang		—	—		
Px Pump		→	↑		
LO Flow		—	—		
CHG Flow		—	—		
VCT LVL		—	—		
VCT Press		—	—		
SIT Level		NC			
SIT Press		—	—		
OT LEVEL		—	—		
OT TEMP		—	—		
OT PRESS		—	—		
ESD's ACTUATION					
CONTAMINANT		RADIATION MONITORING		UNEXPECTED RESPONSES	
MS Line	NC				
SG Sample					
Vacuum Pump					
Cont Pump					
Chams					

APPROVED: John J. Date: 1/3/87

REPORT #: A-100-A-100

REVISION: 1

AUXILIARY PLANT RESPONSE


MANUFACTURE TITLE: Loss of SFC Flow (mode 2)

Reactor Coolant System


SECONDARY




CONTAINMENT





ESD ACTUATION



OTHER UNIQUE PARAMETERS / TRENDS




RESULTS



MANUFACTURE TITLE: Loss of SFC Flow (mode 2)

SECONDARY



APPROVED: R. John, 2nd Review

ACCREDITED: N. Shultz, 2nd Review

AUTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: Fuel Coolant Failure A.R.C. AND DATE PREPARED: 11/18/97 PERFORMED BY: H. Liu (20)	
Reactor Coolant System	
	N/C
Press level	/
Flow	/
T _n	/
T _c	/
T _{out}	/
Gen Power	/
HRP Flow	/
Cool Flow	/
Cool Pure	/
MFR Speed	/
VCT Lvl	/
VCT Press	/
SIT Level	/
SIT Press	/
OT Level	/
OT Temp	/
OT Press	/
ESRAC Actuation	/

SECONDARY N/C		OTHER UNIQUE PARAMETERS / TRENDS	
N/C		CUCS Radiation Monitor will show increase for both Gross and Isotope specific activity.	
MS Flow	A		
MFU Flow	B		
SC Press			
SG Level			
Gen Flow			
HRP Flow			
Cool Flow			
Cool Pure			
MFR Speed			
VCT Lvl			
VCT Press			
SIT Level			
SIT Press			
OT Level			
OT Temp			
OT Press			
ESRAC Actuation			

APPROVED: H. Liu Date: 11/18/97

ACCEPTED: Shih-Chuan Lin Date: 11/18/97

RECOMMENDED PRACTICED PLANS: RECOMMENDATION

MEASURED TITLES: Loss of older books, 2008
PUBLISHER CATALOGUE 2008
OPTIQUE IN
SOCIETY OF LIBRARIES, 2008

Secondary		Other Unique Parameters / Trends	
		A	B
Press level		Plant will not trip. Receive trips on parameters supplied by the fast channel \rightarrow also pctrips	
Flow			
T _n			
T _c			
Taux			
Pn Powr			
LQ Flow			
Chg Flow			
VCT LVL			
VCT Press			
SIT Level			
SIT Press			
OT LEVEL			
OT TEMP			
OT- Press			
ESD ACTUATION			
RADIATION MONITORING			
MS LINE			
SG Sample			
Vacuum Pmp			
Cont Press			
CAMS			

MANUFACTURER TITLE: Loss of EDG (Bun. Mode) Date PERFORMED: 11/15/17		PERFORMED BY: John	
REACTOR COOLANT SYSTEM		SECOND ORDER NC	
ANTICIPATED PLANT RESPONSE		OTHER UNIQUE PARAMETERS / TERMS	
Press Level	A 0	EDG output broken will trip	
Flow			
Th			
Tc			
Tang			
Br Power			
LO Flow			
Chg Flow			
VCT LVL			
VCT Press			
SIT Level			
SIT Press			
OT Level			
OT TIME			
OT Press			
ESCAPE INSTRUMENTATION		RADIATION MONITORING	
MS Line			
SG Sample			
Medium Pmp			
Cont Area			
CAMS			

Approved: 1. R. Edmonson

Date: 11/15/17

Accepted: John H. Johnson

AUXILIARY PLANT RESPONSE

MANUFACTURER TITLE: Loss of a cold pump DATE PERFORMED: 11-5-87 PERFORMED BY: C. Anderson		(4)	
REACTOR COOLANT SYSTEM		OTHER UNIQUE PARAMETERS / RECORDS	
Press	A B	Standby pump will auto start and align to supply float. Non critical associated cool param (Tc, Tmp) should change.	
level			
Flow			
Tn			
Tc			
Tavg			
Br Pwr			
LO Flow			
Cool Flow			
Cool Air			
MFR Speed			
VCF LVL			
VCF Press			
SIT Level			
SIT Press			
OT LEVEL			
OT TIME			
OT. Shut down			
ESPC. Shut down			
MS Line			
SG Sample			
Uadium Pump			
Cont. Pump			
CAMS			

Approved: 12/1/87 by [Signature]

Accepted: [Signature]

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: Loss of CCW		DATE PERFORMED: 11-5-87		PERFORMED BY: San Cecilia	
Secondary Coolant System		OTHER UNIQUE PARAMETERS / TRENDS			
Press level	A	B	CCW Temperatures on all components will increase until the operator is required to manually trip the reactor possible isolation of CCW due to increase temp return to R/HX.		
Flow					
TN					
Tc					
Tong					
Px Power					
IG Flow					
Cry Flow					
VCT Lvl					
Vcr Press					
SIT Level					
SIT Press					
OT Level					
OT Temp					
OT Press					
ESRAC Attuation					
MS Line					
SG Sample					
Vacuum Pump					
Cont Brain					
CAMS					

APPROVED: L.R. Echard, J. M. Danner

ACCEPTED: Cecilia

RECOMMENDED: AUTOMATIC FILTER BACKWASHING
RESPONSE

MANUFACTURER TITLE: Linn Power Chaser/Tailor DATE PERFORMED: 11/5/87 PERFORMED BY: *H. H. Young*

Secondary Colorant System		Secondary		Other Unique Parameters/TRENDS	
Press	A	B		When selected channel fails high void receive trips on off-tie/parallel associated with that channel.	
Level	MS Flow				
Flow	MFW Flow				
Th	SG Press				
Tc	SG Level				
Tang	Gear MS				
On/Off	HDR Flow				
LO Flow	Cou Flow				
Cou Flow	Coless Ave				
VCT Lin	MFP Speed				
VCT Press					
SIT Level					
SIT Press					
OT Level					
OT Temp					
OT-QC					
E3000 Evaluation					
MS Line					
SG Sample					
Vacuum Pump					
Color Print					
Chrom S					

(45)

MANUFACTURER TITLE: 2 Linear Channels failed / Date performed: 7/1/91

PERFORMED BY: C. Anderson

ANTICIPATED PLAN: RESPONSE

Reactor Coolant System Secondary

		A	B
Press	↓	↓	
level	↓	↓	
Flow	→	→	
TN	↓	↓	
Tc	↓	↓	
Tong	↓	↓	
Pn Power	↓	↓	
HO Flow	↓	↓	
Cool Flow	↓	↓	
Colss flow	↓	↓	
MFP speed	↓	↓	
VCT LVL	↑	↑	
Vct Press	↓	↓	

CONTAINMENT

	Press	Temp	Humidity	Sump Lvl	Radiation Monitoring
SIT Level	↑	↑	↑	↑	
SIT Press	↑	↑	↑	↑	
OT Level	↑	↑	↑	↑	
OT Temp	↑	↑	↑	↑	
OT Press	↑	↑	↑	↑	
ESPR fluctuation					

OTHER UNIQUE PARAMETERS / TRENDS

Reactor will trip quickly on high linear power with normal transient to Hot Standby

No Normal or unexpected Transients or parameter

Approved: D. Marshall

Accepted: C. Anderson

MANUFACTURE TITLE: Loss of 297B J J DATE APPROVED: 1/3/01 APPROVE BY: John Woods

Reactor Coolant System		Secondary		Other Unique Parameters/Trends		RESULTS	
Process		A	B				
Level							
Flow							
T _H							
T _C							
T _{out}							
Gen. Mw							
Gen. Mw							
HTR Flow							
LO Flow							
CH ₄ Flow							
VCT LVL							
VCT Press							
SIT Level							
SIT Press							
QTR Level							
QTR Temp							
QTR. Press							
ESEAS Actuation							
MS Line							
SG Sample							
vacuum Pmp							
Cont Area							
CHMS							

APPROVED: T. Miller
Date: 1/3/01
Comments: No comments

ACCEPTED: John Woods

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: boss of 297A Date PERFORMED: 7/1/87 PERFORMED BY: M. Hall

OTHER UNIQUE PARAMETERS/TRENDS

Reactor Coolant System		Secondary			
		A	B		
Press	↑	↓	↓		
level	↑	↓	↓		
Flow	↑	↑	↓		
T _H	↑	↑	↑		
T _C	↑	↑	↑		
T _{out}	↑	↑	↑		
Ex Power	↑	↑	↓		
Log Flow	↑	↑	↓		
Chg Flow	↑	↑	↓		
VCT LVL	↑	↑	↓		
VCT Press	↑	↑	↓		
Containment					
SIT Level	↑	↑			
SIT Press	↑	↑			
OT LEVEL	↑	↑			
OT TEMP	↑	↑			
OT. Press	↑	↑			
Radiation Monitoring					
MS Line	↑	↑			
SG Sample	↑	↑			
Vacuum Pump	↑	↑			
Cont Room	↑	↑			
Cam S	↑	↑			

RESULTS

Containment		Radiation Monitoring	
Press	↑	↑	
TEMP	↑	↑	
Humidity	↑	↑	
Sump LVL	↑	↑	
ESD ACTUATION			
MS Line	↑		
SG Sample	↑		
Vacuum Pump	↑		
Cont Room	↑		
Cam S	↑		

Approved: M. Hall in P.O.

Accepted: M. Hall

Reviewed: M. Hall

MANUFACTURER TITLE: GE NUCLEAR ENERGY INC. DUE DATE ACCEPTED: 11/10/2011

(47)

PERFORMED BY:

1)

Secondary		Other Unique Parameters / Terms	
Containment		Results	
Press	A	B	The line will be connected to the SG line at the bottom of the plant and will be connected to the SG line at the top of the plant.
Level			
Flow			
Tn			
Tc			
Tow			
Br Pwr			
LO Flow			
Cool Flow			
VCT Lvl			
VCT Press			
SIT Level			
SIT Press			
OT Level			
OT Temp			
OT Press			
ESFC ACTUATION		RADIATION MONITORING	
MS Line		SG Sample	
SG Line		VACUUM PUMP	
CONT Area		CONT AREA	
CAMS		CAMS	

- * CEA's will invert due to loss of voltage on the CEA buses, TURBINE THD will be caused by UV on the CEA buses
- 2A1 : 2A2 will RE-MAGNITUDE AFTER THE TURBINE TRIP
- ** L/D ISOLATED THREE END PUMPS, VCT LEVEL, PRESSURE DECREASE
- *** ACTIVE RZ TRIP

APPROVED: GE NUCLEAR ENERGY INC.

ACCEPTED:

GE NUCLEAR ENERGY INC.

ANTICIPATED PLANT - RESPONSE

(48)

MANUFACTURER TITLE: Dilution At Farrow		DATE PREPARED: 7/21/87		PERFORMED BY: Craig Anderson			
Reactor Coolant System		OTHER UNIQUE PARAMETERS / TERMS					
SECONDARY							
Press		A	B				
Level	/	/	/				
Flow	/	/	/				
T _H	/	/	/				
T _C	/	/	/				
T _{avg}	/	/	/				
Par Power	/	/	/				
LO Flow	/	/	/				
Cool Flow	/	/	/				
VCT LVL	/	/	/				
VCT Press	/	/	/				
SIT Level	/	/	/				
SIT Press	/	/	/				
OT Level	/	/	/				
OT Temp	/	/	/				
OT Press	/	/	/				

8

UNIQUE PLANT - RESPONSE

(48)

REACTOR COOLANT SYSTEM		CIRCULATION		RADIATION MONITORING	
SECONDARY		PRIMARY			
PRESSURE		TEMP		LEVEL	
MS Line	NC	NC	NC	MS Line	NC
SG Sample	NC	NC	NC	SG Sample	NC
Valve Pos	NC	NC	NC	Valve Pos	NC
Cont Posn	NC	NC	NC	Cont Posn	NC
CAMS	NC	NC	NC	CAMS	NC

APPROVED: 1. P. M. Steele ~ P. D. ~

ACCREDITED: Fluor Daniel

ANTICIPATED PLANT RESPONSE

49

MANAGEMENT TITLE: Loss of Coolant & Date Prepared: 7/6/07 PERFORMED BY: M. Vela

REACTOR COOLANT SYSTEM	SECONDARY		OTHER UNIQUE PARAMETERS / TRENDS	
	A	B	SEQUENCE - LOSS OF 2P4C	
Press. Head	↑	↑	- Low Press Alarm seen Ndt & 2	
Flow	↑	↑	- Pano Trip alarm for 2P4C	
T _h	↑	↑	- Low Head Press alarm	
T _c	↑	↑	- START STBY SW Pumper Loop 2 (2P4C)	
Tank	↑	↑	- Alarms for ACW and STHR #2 clear.	
Ex. Pump	↑	↑		
LO Flow	↑	↑		
Cool Flow	↑	↑		
Cold Flow	↑	↑		
MFP Speed	↑	↑		
VCT LVL	↑	↑		
VCT Press	↑	↑		
SIT LEVEL	↑	↑		
SIT PRESS	↑	↑		
OT TEMP	↑	↑		
OT LEVEL	↑	↑		
OT. Press	↑	↑		
ESFS ACTUATION		RADIATION MONITORING		
MS Line		↑	↑	
SG Sample		↑	↑	
Volumin Pump		↑	↑	
Port Area		↑	↑	
CFMS		↑	↑	

APPROVED: M. Vela

ACCEPTED:

M. Vela D. Marshall

ANTICIPATED PLANT RESPONSE

(50)

MANUFACTURE TITLE: LOSS OF SWC **DATE PREPARED:** 1/16/87 **PERFORMED BY:** John L. Hobbs

Reactor Coolant System

SECONDARY		OTHR UNIQUE PARAMETERS/TRENDS	
Press	↗ ↗	↗ ↗	Loss of Aux Cooling To The Stator Water Coolers. Expected Events will be a Turbine Runback and a Reactor Trip if the condition is NOT cleared. CEA initiation and/or Boration should be initiated per the operating procedure.
level	↗ ↗	↗ ↗	
Flow	→ →	↗ ↗	
T _H	↑ ↘	↗ ↗	
T _C	↑ ↘	↗ ↗	
T _{out}	↑ ↘	↗ ↗	
Gen Pow	↗ ↗	↗ ↗	
HTR Flow	→ →	↓ ↓	
Cool Flow	↗ ↗	↗ ↗	
COLSS Pow	↑ ↑	↑ ↑	
MFP Speed	↗ ↗	↗ ↗	
CONSTRAINTS		RESULTS	
SIT Level	↑ ↑	Press	
SIT Press	↑ ↑	TEMP	
OT LEVEL	↑ ↑	HUMIDITY	
OT TEMP	↑ ↑	SUMP LVL	
OT. Press	↑ ↑	RADIATION MONITORING	
ESSENTIAL ACTUATION		CAMPS	
MS Line	↑ ↑	SG Sample	
Vacuum Pump	↑ ↑	Containment	
Contain	↑ ↑	CAMS	

Approved: L. Hobbs or Seal

Accepted:

W.H.D. Marshall

MANUFACTURE TITLE: Per BQ Hqs Dn

ANTICIPATED "PLANT" RESPONSE

Reactor Coolant System

SECONDARY OTHER UNIQUE PARAMETERS / TRENDS

	A	B
Press	↑	↑
Level	↑	↑
Flow	↑	↑
T _H	↑	↑
T _C	↑	↑
Tang	↑	↑
Br. Power	↑	↑
LO Flow	↑	↑
CH Flow	↑	↑
VCT LVL	↑	↑
VCT Press	↑	↑
SIT Level	↑	↑
SIT Press	↑	↑
OTL LEVEL	↑	↑
OT TEMP	↑	↑
OT PRESS	↑	↑
ESEAS ACTUATION		
MS Line	↑	↑
SG Sample	↑	↑
Vacuum Pump	↑	↑
Cont Pump	↑	↑
CPMS	↑	↑

Par Spray should activate as necessary
To maintain pressure w/in acceptable
Uq/4 ps

RESULTS

CONSTRAINT

Press	↑	↑
TEMP	↑	↑
Humidity	↑	↑
Sump Lvl	↑	↑
RADIATION MONITDRS		
MS Line	↑	↑
SG Sample	↑	↑
Vacuum Pump	↑	↑
Cont Pump	↑	↑
CPMS	↑	↑

APPROVED: M. J. Friend

ACC 20740:

M. J. Friend

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: S.I.O. & Minor Shaking date received: 1/16/87 performed by: M. Seaborn

Reactor Coolant System		SECONDARY		OTHER UNIQUE PARAMETERS / TRENDS	
		A	B		
Press	✓	↗	↘	Rx Trip on High Pressure (~2162)	
Level	✓	↗	↘	Parameters show trend due to Turbine trip	
Flow	↑	↑	↑	and subsequent process to Hot STBY	
Th	✓	↗	↘		
Tc	✓	↗	↘		
Tang	✓	↗	↘		
Pt. Power	✓	↗	↘		
LD Flow	✓	↗	↘		
Cy Flow	✓	↗	↘		
VCT LVL	✓	↗	↘		
VCT Press	✓	↗	↘		
SIT Level	↑	↑	↑	CONSTRAINT	RESULTS
SIT Press	↑	↑	↑		
OT LEVEL	↑	↑	↑		
OT TEMP	↑	↑	↑		
OT. Press	↑	↑	↑		
ESD's ACTUATION		RADIATION MONITORING		CHRS	
MS Line		MS Sample		Vacuum Pump	
SG Sample		Cont. Pump		Chamber S	

APPROVED: T. D. P. M.

RECORDED:

M. D. P. M.

(52)

DOCUMENTATION PLAN

RESPONSE

MANUFACTURER TITLE: Fuses Failure DATE PERFORMED: 1/6/87 PERFORMED BY: H. K. L.

53

Reactor Coolant System		SECOND ORDER		OTHER UNIQUE PARAMETERS / SECONDS	
		A	B		
Press					
level					
Flow					
T _H					
T _C					
T _{out}					
Gas flow					
HDR flow					
COOL flow					
COLSS flow					
MFP speed					
CONSTRAINT					
VCF press					
SIT level					
SIT press					
OT level					
OT temp					
OT press					
RADIATION MONITORING					
MS Line					
SG Sample					
Vacuum Pump					
Point Dose					
CAMS					
RESULTS					
APPENDIX: <u>APPENDIX</u>					

APPROVED: H. K. L.

DRAWN: D. D. P.

REVISED: 110. D. D. P.

(54)

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: Engle CEA DATE PREPARED: 11/5/87 PERFORMED BY: Shieled

REACTOR COOLANT SYSTEM		SECONDARY		OTR&E UNQUOTE PARAMETERS TRENDS	
		A	B		
Press	↗ ↗	↗ ↗	↗ ↗	Pressures at SIT not up due to low various CEA's. In secondary, heat load +0.1 A increased at PWR. The 50% increase in primary temps will result in decrease in the sec't.	Pressures at SIT not up due to low various CEA's. In secondary, heat load +0.1 A increased at PWR. The 50% increase in primary temps will result in decrease in the sec't.
Level	↗ ↗	↗ ↗	↗ ↗		
Flow	↗ ↗	↗ ↗	↗ ↗		
Tn	↗ ↗	↗ ↗	↗ ↗		
Tc	↗ ↗	↗ ↗	↗ ↗		
Tave	↗ ↗	↗ ↗	↗ ↗		
Px/Pwr	↗ ↗	↗ ↗	↗ ↗		
LO Flow	↗ ↗	↗ ↗	↗ ↗		
Cool Flow	↗ ↗	↗ ↗	↗ ↗		
CH4 Flow	↗ ↗	↗ ↗	↗ ↗		
VCT LVL	↗ ↗	↗ ↗	↗ ↗		
VCT Press	↗ ↗	↗ ↗	↗ ↗		
CONTAINMENT					
SIT Level	↗ ↗	↗ ↗	↗ ↗	Press	↗ ↗
SIT Press	↗ ↗	↗ ↗	↗ ↗	TEMP	↗ ↗
OT LEVEL	↗ ↗	↗ ↗	↗ ↗	HUMIDITY	↗ ↗
OT TIME	↗ ↗	↗ ↗	↗ ↗	SUMP LVL	↗ ↗
OT. Press	↗ ↗	↗ ↗	↗ ↗	RADIATION MONITORING	↗ ↗
ESD& ACTUATION					
MS Line	↗ ↗	↗ ↗	↗ ↗	MS Sample	↗ ↗
SG Sample	↗ ↗	↗ ↗	↗ ↗	INSTRUMENT	↗ ↗
CONT Area	↗ ↗	↗ ↗	↗ ↗	CAMS	↗ ↗

APPROVED: 11/5/87 by [Signature]

ACCREDITED: 11/5/87 by [Signature]

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: Valsinor Pump Failure DATE PERFORMED: 11/6/87 PERFORMED BY: M. Schell
 Reactor Coolant System

	A	B
Press. level	↑	↑
Flow	↑	↑
Tn	↑	↑
Tc	↑	↑
Tang	↑	↑
Br. Power	↑	↑
LO Flow	↑	↑
CHG Flow	↑	↑
VCT LVL	↑	↑
VCT Press	↑	↑

CONTAINMENT

SIT Level	↑
SIT Press.	↑
OT LEVEL	↑
OT TEMP	↑
OT. Prges	↑
ESFS ACTUATION	↑
MS Line	↑
SG Sample	↑
Vacuum Pump	↑
Cont. Head	↑
CAMS	↑

OTHER UNIQUE PARAMETERS/TRENDS

Should Auto start STBY Vacuum Pump

RESULTS

No expected events. On loss of site power, Contain pressure related to site, resulting in an auto start of the STBY vacuum pump. Contain press returned to steady state back to initial value

APPROVED: + Mark

ACCEPTED:

J. D. Clegg

DATE:

ANTICIPATED PLANT RESPONSE

MANUFACTURER TITLE: RST Pump Testing Date Performed: 11/16/18 / Performed by: 2011/ok/ok

(56)

REACTOR COOLANT SYSTEM		SECONDARY		OTHER UNIQUE PARAMETERS/TRENDS	
Press	/	A	B	Perform on SDC, Min. P. For Decay 1/112 sec. To 10%	/
Level	/	/	/		
Flow	/	/	/		
Th	/	/	/		
Tc	/	/	/		
Tang	/\	/\	/\		
Br. Power	/	/	/		
LO Flow	/	/	/		
Cry. Flow	/	/	/		
VCT LVL	/	/	/		
VCT Press	/	/	/		
CONTAINMENT		RESULTS			
SIT Level	/	/	/	No Unpredicted Results. Decay heat load sufficient To cause heat up as indicated by the thermo couple, Th and TC. Radiation loss decreased initially from loss of the EPR pump and increased slowly due to the expansion of the RCS from the heat up.	
SIT Press	/	/	/		
OT Level	/	/	/		
OT Temp	/	/	/		
OT. Press	/	/	/		
ESD ACTUATION		RADIATION MONITORING			
MS Line	/	/	/		
SG Sample	/	/	/		
Vacuum Pump	/	/	/		
Cont Room	/	/	/		
Cams	/	/	/		

APPROVED: 11/16/18
in Red

ACCEPTED:

Third Coast

ANTICIPATED PLANT RESPONSE

(57)

MANUFACTURER TITLE: General Electric Trip 1 U Unit Presented: 11-6-97 performed by: M. Scholz

Reactor Coolant System

SECOND ORDER		OTHER UNIQUE PARAMETERS / SECONDS	
A	B	C	D

Press			
Level	↑	↑	↑
Flow	↑	↑	↑
T _h	↑	↑	↑
T _c	↑	↑	↑
T _{as}	↑	↑	↑
Ex Power	↑	↑	↑
LO Flow	↑	↑	↑
CH Flow	↑	↑	↑
VCT LVL	↑	↑	↑
VCT Press	↑	↑	↑
SIT Level	↑	↑	↑
SIT Press	↑	↑	↑
OT LEVEL	↑	↑	↑
OT TEMP	↑	↑	↑
OT PRESS	↑	↑	↑
ESFC ACTUATION			

Trip off "A" Reactor Coolant pump at 100% flow.

CONSTRAINT

RESULTS

Press			
TEMP	↑	↑	↑
HUMIDITY	↑	↑	↑
SUMP LVL	↑	↑	↑
RADIATION MONITORING			
MS LINE	↑	↑	↑
SG Sump	↑	↑	↑
Vacuum Pd	↑	↑	↑
COAT HEAD	↑	↑	↑
CHAMS	↑	↑	↑

No unexpected results. Canned or stand-by the stand-by constraint page.

APPROVED: M. D. Miller
REVIEWED: M. D. Miller
DATE: 10/12/97

ACCEPTED: M. D. Miller
DATE: 10/12/97

M.D. Miller

ANTICIPATED PLANT RESPONSE

Malfunction Title: Gland Seal Failed to Seal
Date Performed: 10/27/07 performed by M. Shabot

(58)

Reactor Coolant System

OTHER UNIQUE PARAMETERS / TRENDS

	A	B
Press	↑	↗
Level	↑	↑
Flow	↑	↑
Tm	↑	↑
Tc	↑	↑
Taux	↑	↑
Br Pwr	↑	↑
LO Flow	↑	↑
CHG Flow	↑	↑
VCT LVL	↑	↑
Vcr Press	↑	↑

CONTAMINANT

	MS LINE	SG Sample	Vacuum Pump	Cont. Pump	CAMS
SIT LEVEL	↑	↑	↑	↑	↑
SIT PRESS	↑	↑	↑	↑	↑
OT LEVEL	↑	↑	↑	↑	↑
OT TEMP	↑	↑	↑	↑	↑
OT. PRESS	↑	↑	↑	↑	↑
ESEAS ACTUATION					

RESULTS

No unexpected results. loss of gland sealing steam resulted in a decrease of condenser vacuum and an initial start of the sitem vacuum pump. The low vacuum breakout at the SDCS bypass valves occurred at set point.

Approved: M. Shabot

Reviewed: M. Shabot

Accepted: M. Shabot

ANTICIPATED PLANS, RESPONSE

50

Malfunction title: Loss of Control - POF
Date performed: 11/16/15 Performed by: M. Shuler
Recorder Colorant System Secondary
Other unique parameters/remarks

Approved: [Signature]

MC20730:

A SO PLANT RESPONSE

Malfunction Title: Uncontrolled Rod Withdrawal State performed: 115/5/5 performed by: Whole

Reactor Coolant System

SECONDARY

	A	B
Press	NA	
Level	NA	NA
Flow	MS Flow	NA
T _c	MFW Flow	
T _e	SG Press	
T _{out}	SG Level	
Op Power	Gas Flow	
LO Flow	HDF Flow	
CH ₄ Flow	Cool Flow	
VCT LV	COSS Flow	
Vcr Press	MFP Speed	

OTHER UNIQUE PARAMETERS / TRENDS

UNCONTROLLED ROD WITHDRAWAL MAY BE TERMINATED BY SELECTING CEF CHECK THE CEDMCS SELECTOR SWITCH. THIS TERMINATION SHOULD BE TERMINATED BEFORE THE REACHING POINT OF ADDING LIQUID.

PROPER SIMULATOR RESPONSE COULD BE INDICATED BY VERIFYING THAT THE ROD MOTION CONTINUES AFTER SIM SWITCH IS RELEASED.

CONTAMINANT

Press	NA				
TEMP					
HUMIDITY					
SUMP LVL					
RADIATION MONITORING					
ESCR ACTUATION					
MS Line	NA				
SG Sample					
Vacuum Pump					
CONT HEAT					
CAMS					

RESULTS

Accepted:

Approved:

Initial Crossed

ATTACHMENT 2

AIR TRAINING ADMINISTRATIVE GUIDELINE

SIMULATOR FIDELITY TESTING