

ATTACHMENT 1-

NRC DOCKET 50-321
OPERATING LICENSE DPR-57
EDWIN I. HATCH NUCLEAR PLANT UNIT 1
PROPOSED CHANGE TO TECHNICAL SPECIFICATIONS

The proposed change to the Technical Specifications (Appendix A to Operating Licenses DPR-57) would be incorporated as follows:

Remove Page

3.7-21

Insert Page

3.7-21

8301110341

Table 3.7-2

Testable Penetrations with Double O-Ring Seals

<u>Penetration No.</u>	<u>Penetration Description</u>	<u>Notes</u>
X-1 A&E	Equipment Hatch	(1) (2) (4) (6)
X-2	Personnel Lock	(1) (4) (7) (8)
X-4	Head Access Hatch	(1) (2) (4) (6)
X-6	CRD Removal Hatch	(1) (2) (4) (6)
X-35-A through X35-E	TIP System	(1) (2) (4) (6)
X-43	Drywell Test	(1) (2) (4) (6)
X-200 A,B,&C	Suppression Chamber Access Manhole	(1) (2) (4) (6)
X-218 A&B	Construction Drain	(1) (2) (4) (6)

ATTACHMENT 2

NRC DOCKET 50-321
OPERATING LICENSE DPR-57
EDWIN I. HATCH NUCLEAR PLANT UNIT 1
REQUEST FOR CHANGE TO TECHNICAL SPECIFICATIONS

Pursuant to 10 CFR 170.12 (c), Georgia Power Company has evaluated attached proposed amendment to Operating Licenses DPR-57 and has concluded that:

- a) The proposed amendment does not require the evaluation of a new Safety Analysis Report or rewrite of the facility license;
- b) The proposed amendment does not contain several complex issues, does not involve ACRS review, and does not require an environmental impact statement;
- c) The proposed amendment does not involve a complex issue or more than one environmental or safety issue;
- d) The proposed amendment does involve a single safety issue, namely, addition of a testable torus penetration.
- e) The proposed amendment is therefore a Class III amendment.