

U.S. NUCLEAR REGULATORY COMMISSION

REGION III

Reports No. 50-266/89017(DRSS); 50-301/89016(DRSS)

Docket Nos. 50-266; 50-301

Licenses No. DPR-24; DPR-27

Licensee: Wisconsin Electric Power Company
231 West Michigan
Milwaukee, WI 53201

Facility Name: Point Beach Nuclear Plant, Units 1 and 2

Inspection Conducted: May 9-12, 1989

Date of Previous Security Inspection: April 3 and 4, 1989

Type of Inspection: Announced Routine Physical Security Inspection

Inspector: Terry J. Madeda
T. J. Madeda
Physical Security Inspector

5/25/89
Date

Approved By: J. L. Belanger for
James R. Creed, Chief
Safeguards Section

5/25/89
Date

Inspection Summary

Inspection on May 9-12, 1989 (Reports No. 50-266/89017(DRSS);
No. 50-301/89016(DRSS))

Areas Inspected: Management Support; Protected and Vital Area Barriers;
Access Control-Personnel, Packages and Vehicles; Alarm Stations and
Communications; Power Supply; Testing, Maintenance and Compensatory Measures;
Training and Qualifications; and Review of Licensee Actions on Previous
Inspection Findings.

Results: The licensee was found to be in compliance with NRC requirements
within the areas examined, except as noted below:

- a. Physical Security Program For Power Reactor - Access Control: Failure to
adequately search security personnel as required.
- b. 10 CFR 73.21 Requirements For The Protection of Safeguards Information:
Failure to provide an adequate level of protection for Safeguards
Information.

The licensee's site security program is being implemented in an adequate
manner. Corporate and plant support is appropriate.

Enclosure Contains
SAFEGUARDS INFORMATION
Upon Separation This
Page is Decontrolled