

June 8, 1989

Docket Nos. 50-295
and 50-304

Mr. Thomas J. Kovach
Nuclear Licensing Manager
Commonwealth Edison Company
Post Office Box 767
Chicago, IL 60690

DISTRIBUTION

Docket file
PDIII-2 r/f
LLuther
OGC
BGrimes
Plant file

NRC & Local PDRs
MVirgilio
CPatel
EJordan
ACRS (10)

Dear Mr. Kovach:

SUBJECT: ZION STATION UNITS 1 AND 2 LICENSE AMENDMENT REQUEST
DATED MAY 11, 1989

By letter dated May 11, 1989, Commonwealth Edison Company (CECo) requested a change to the Zion Technical Specifications. The proposed amendment was to change the out-of-service period associated with an inoperable diesel generator, specifically as it applies to the common "0" diesel generator in Section 3.15.2-c of the Zion Technical Specifications.

The NRC staff has reviewed the CECo's submittal and determined that the submittal does not provide appropriate technical justification in making no significant hazard consideration determination required by 10 CFR 50.92.

Because this request does not provide appropriate technical justification needed to complete a Safety Evaluation Report, the NRC staff has determined that this submittal is not adequate as it now stands. It should be noted that the previous Safety Evaluation dated March 12, 1984 performed by the staff considered all other diesels to be operable while diesel "0" is out of service. Should you desire the NRC staff to review this material to amend the Technical Specifications, it should be resubmitted with the proper technical analysis and bases.

Sincerely,

151

Chandu P. Patel, Project Manager
Project Directorate III-2
Division of Reactor Projects III,
IV, V, and Special Projects

cc: See next page

CPS
PDIII-2:PM
CPatel:dmg
6/8/89

PDIII-2:LA
LLuther *LL*
6/8/89

P.S.
PDIII-2:(A)PD
PShemanski
6/8/89

DF01
1/0



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 8, 1989

Docket Nos. 50-295
and 50-304

Mr. Thomas J. Kovach
Nuclear Licensing Manager
Commonwealth Edison Company
Post Office Box 767
Chicago, IL 60690

Dear Mr. Kovach:

SUBJECT: ZION STATION UNITS 1 AND 2 LICENSE AMENDMENT REQUEST
DATED MAY 11, 1989

By letter dated May 11, 1989, Commonwealth Edison Company (CECo) requested a change to the Zion Technical Specifications. The proposed amendment was to change the out-of-service period associated with an inoperable diesel generator, specifically as it applies to the common "0" diesel generator in Section 3.15.2-c of the Zion Technical Specifications.

The NRC staff has reviewed the CECo's submittal and determined that the submittal does not provide appropriate technical justification in making no significant hazard consideration determination required by 10 CFR 50.92.

Because this request does not provide appropriate technical justification needed to complete a Safety Evaluation Report, the NRC staff has determined that this submittal is not adequate as it now stands. It should be noted that the previous Safety Evaluation dated March 12, 1984 performed by the staff considered all other diesels to be operable while diesel "0" is out of service. Should you desire the NRC staff to review this material to amend the Technical Specifications, it should be resubmitted with the proper technical analysis and bases.

Sincerely,

Chandu P. Patel

Chandu P. Patel, Project Manager
Project Directorate III-2
Division of Reactor Projects III,
IV, V, and Special Projects

cc: See next page

Mr. Thomas J. Kovach
Commonwealth Edison Company

Zion Nuclear Power Station
Units 1 and 2

cc:

Robert J. Vollen, Esquire
109 North Dearborn Street
Chicago, Illinois 60602

Dr. Cecil Lue-Hing
Director of Research and Development
Metropolitan Sanitary District
of Greater Chicago
100 East Erie Street
Chicago, Illinois 60611

Phillip Steptoe, Esq.
Sidley and Austin
One First National Plaza
Chicago, Illinois 60603

Mayor of Zion
Zion, Illinois 60099

Illinois Department of Nuclear Safety
ATTN: Manager, Nuclear Facility Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
105 Shiloh Blvd.
Zion, Illinois 60099

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road, Bldg. #4
Glen Ellyn, Illinois 60137

Mr. Michael C. Parker, Chief
Division of Engineering
Illinois Department of Nuclear
Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704