



GPU Nuclear Corporation
 Post Office Box 480
 Route 441 South
 Middletown, Pennsylvania 17057-0191
 717 944-7621
 TELEX 84-2386
 Writer's Direct Dial Number:

June 7, 1989
 C311-89-2066

US Nuclear Regulatory Commission
 Attn: Document Control Desk
 Washington, DC 20555

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)
 Operating License No. DPR-50
 Docket No. 50-289
 Final Response to NRC Bulletin 88-10:
 Nonconforming Molded-Case Circuit Breakers

On May 8, 1989, we provided an interim response to NRC Bulletin 88-10 "Nonconforming Molded-Case Circuit Breakers." We stated that we had identified 8 of 156 molded-case circuit breakers for which adequate traceability had not been verified. This letter disposes the eight circuit breakers.

We have determined that six of the circuit breakers were not procured or stored for safety-related applications. For the two remaining breakers, we have received information from the vendor which identifies the breaker manufacturer. This assurance, along with the documentation we have, provides us with adequate traceability for these breakers.

This completes our response to the NRC Bulletin 88-10. We have concluded that all of the molded-case circuit breakers being stored for safety-related applications are traceable to the manufacturer.

Sincerely,

J. D. Hukill

H. D. Hukill
 Vice President & Director, TMI-1

8906140162 890607
 PDR ADOCK 05000289
 Q PDC

HDH/SMU/spb:2066

cc: R. Hernan
 F. Young

NOTARIAL SEAL
 SHARON P. BROWN, NOTARY PUBLIC
 MIDDLETOWN BORO, DAUPHIN COUNTY
 MY COMMISSION EXPIRES JUNE 12, 1989

Member, Pennsylvania Association of Notaries

Sworn and subscribed to before me
 this 7th day of June, 1989.

Sharon P. Brown
 Notary Public

GPU Nuclear Corporation is a subsidiary of the General Public Utilities Corporation

IER1