

Docket No. 50-155

April 12, 1989


Mr. Kenneth W. Berry
Director, Nuclear Licensing
Consumers Power Company
1945 West Parnell Road
Jackson, Michigan 49201

Dear Mr. Berry:

SUBJECT: NRC BULLETIN 88-05, Supplements 1 and 2 (TAC 68738)

We acknowledge receipt of your letter of August 3, 1988, which summarizes your efforts to address the issues of NRC Bulletin 88-05, including Supplement 1. We consider your response to the NRC Bulletin complete and acceptable. Therefore, TAC 68738 is closed.

Sincerely,



Robert M. Pulsifer, Project Manager
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects

DISTRIBUTION:

Central File
NRC PDR
Local PDR
DRSP R/F
RPulsifer
PShuttleworth
DJackson

LA: PD31: DRSP *MPA*
PShuttleworth
4/5/89

PM: PD3-1: DRSP
RPulsifer *RP*
4/6/89

(A) PD3-1: DRSP
T. H. *TH*
4/7/89

EMTB DEST
LPM: PD3-2: DRSP
DJackson
4/10/89

8904200108 890412
PDR ADDOCK 05000155
Q PNU

DF01
111

Mr. Kenneth W. Berry
Consumers Power Company

Big Rock Point Plant

cc:

Mr. Thomas A. McNish, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Mr. Thomas W. Elward
Plant Manager
Big Rock Point Plant
10269 U.S. 31 North
Charlevoix, Michigan 49720

Mr. Bud Heeres
County Commissioner
303 Sheridan
Charlevoix, Michigan 49720

Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
P. O. Box 30035
Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission
Resident Inspector Office
Big Rock Point Plant
10253 U.S. 31 North
Charlevoix, Michigan 49720



Consumers
Power

**POWERING
MICHIGAN'S PROGRESS**

Kenneth W Berry
Director
Nuclear Licensing

General Offices 1945 West Parnell Road, Jackson, MI 49201 • (517) 788-1636

August 3, 1988

Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

DOCKET 50-155 - LICENSE DPR-6 - BIG ROCK POINT PLANT -
RESPONSE TO NRC BULLETIN 88-05 - NONCONFORMING MATERIALS
SUPPLIED BY PIPING SUPPLIES, INC. AND WEST JERSEY MANUFACTURING COMPANY

Nuclear Regulatory Commission Bulletin 88-05, Nonconforming Materials
Supplied by Piping Supplies, Inc. and West Jersey Manufacturing Company, dated
May 6, 1988, requires Consumers Power Company to review purchasing records and
determine whether any ASME Code or ASTM materials have been furnished for use
in safety-related systems by the subject companies. Supplement 1 to the
bulletin reduced the scope from ASME Code and ASTM materials to ASME Code and
ASTM fittings and flanges.

In accordance with the bulletin, we have reviewed our purchasing records and
have inspected in stock pipe fittings and flanges for the Big Rock Point
Plant. We have found no evidence of receiving any material either directly
or indirectly from Piping Supplies, Inc. or West Jersey Manufacturing Company.
As a result of our findings, no additional actions are planned in response to
the bulletin.

Kenneth W Berry
Director, Nuclear Licensing

CC Administrator, Region III, NRC
NRC Resident Inspector - Big Rock Point

OC0888-0085-NL04

8808070214 880803
PDR ADUCK 05000155
Q PDC

TEL
1/0