

JUN - 2 1989

In Reply Refer To:
Dockets: 50-313/89-04
50-368/89-04
EA 89-115

Arkansas Power & Light Company
ATTN: Mr. Gene Campbell
Vice President, Nuclear
Operations
P.O. Box 551
Little Rock, Arkansas 72203

Gentlemen:

This is to confirm arrangements made with Messrs. Don Lomax and Dale James of your staff for a Management Meeting to be followed by an Enforcement Conference in the Region IV office on June 7, 1989, at 12:30 p.m. (CDT).

The purpose of the Management Meeting is to discuss your plans and schedule for issue of overdue Licensee Event Reports and other reporting issues. This meeting is expected to last about 1 hour and the Enforcement Conference will begin at about 1:30 p.m. (CDT).

The purpose of the Enforcement Conference is to discuss an apparent violation in NRC Inspection Report 50-313/89-04; 50-368/89-04. This apparent violation relates to the piping and support system design for the Unit 1 high pressure injection system with regard to temperatures expected during all possible modes of operation for the system. The attached agenda lists the issues to be discussed in the Enforcement Conference.

Should you have any questions concerning these arrangements, we will be pleased to discuss them with you.

Sincerely,

E. J. Baker

8906150192 890602
PDR ADOCK 05000313
PNU

for
L. J. Callan, Director
Division of Reactor Projects

Enclosure:
Agenda

cc:
Arkansas Nuclear One
ATTN: J. M. Levine, Executive
Director, Nuclear Operations
P.O. Box 608
Russellville, Arkansas 72801

Arkansas Radiation Control Program Director

RIV:C:DRP/A *add*
DDChamberlain;*df*
5/31/89

MB
D:DRP6/2/89
LJCallan
6/2/89

IE45
11

bcc to DMB (IE45)

bcc distrib. by RIV:

RRI

RPB-DRSS

Lisa Shea, RM/ALF

DRP

RSTS Operator

DRS

R. D. Martin, RA

Section Chief (DRP/A)

RIV File

MIS System

Project Engineer (DRP/A)

C. Harbuck, NRR Project Manager (MS: 13-D-18)

C. Poslusny, NRR Project Manager (MS: 13-D-18)

AGENDA

ARKANSAS POWER & LIGHT COMPANY (AP&L)

ENFORCEMENT CONFERENCE

- | | | |
|------|---|----------|
| I. | INTRODUCTION | NRC |
| II. | DISCUSSION OF THE FOLLOWING ISSUES RELATIVE TO THE APPARENT VIOLATION FROM NRC INSPECTION REPORT 50-313/89-04; 50-368/89-04 | NRC/AP&L |
| | A. Safety implications of identified condition | |
| | B. Full extent of licensee corrective actions | |
| | C. Design basis for HPI system piggy back mode of operation | |
| | D. Licensing basis for HPI system | |
| | E. Other licensee provided information | |
| III. | CLOSING REMARKS | NRC/AP&L |