

# UNITED STATES NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

In the Matter of )  
 )  
SUBCOMMITTEE ON INSTRUMENTATION )  
AND CONTROLS )  
 )  
 )

Pages: 1 through 84

Place: Bethesda, Maryland

Date: April 5, 1989

ACRS Office Copy - Retain  
for the Life of the Committee

## HERITAGE REPORTING CORPORATION

*Official Reporters*

1220 L Street, N.W., Suite 600

Washington, D.C. 20005

(202) 628-4888

8904210049 890405  
PDR ACRS  
T-1727

PNU

1 PUBLIC NOTICE BY THE  
2 UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
4  
5  
6

7 The contents of this stenographic transcript of the  
8 proceedings of the United States Nuclear Regulatory  
9 Commission's Advisory Committee on Reactor Safeguards (ACRS),  
10 as reported herein, is an uncorrected record of the discussions  
11 recorded at the meeting held on the above date.

12 No member of the ACRS Staff and no participant at  
13 this meeting accepts any responsibility for errors or  
14 inaccuracies of statement or data contained in this transcript.  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25



1 UNITED STATES NUCLEAR REGULATORY COMMISSION  
2 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

3 In the Matter of: )  
4 )  
5 )  
6 )

5 SUBCOMMITTEE ON INSTRUMENTATION )  
AND CONTROL SYSTEMS )  
6 )

7 Wednesday,  
8 April 5, 1989

9 Room P-110  
7920 Norfolk Avenue  
Bethesda, Maryland

10 The above-entitled matter came on for hearing,  
11 pursuant to notice, at 8:30 a.m.  
12

13 BEFORE: DR. WILLIAM KERR  
Professor of Nuclear Engineering  
University of Michigan  
14 Ann Arbor, Michigan

15 ACRS MEMBERS PRESENT:

16 MR. CHARLES WYLIE  
Retired Chief Engineer  
17 Electrical Division  
Duke Power Company  
18 Charlotte, North Carolina

19 MR. JAMES C. CARROLL  
Retired Manager, Nuclear Operations Support  
20 Department  
Pacific Gas & Electric  
21 San Francisco, California

22 ACRS COGNIZANT STAFF MEMBER:

23 M. El-Zeftaway  
24  
25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CONSULTANTS:

P. Davis  
L. Oakes  
W. Lipinski

NRC STAFF PRESENTERS:

D. Basdekas  
K. Kniel

P R O C E E D I N G S

CHAIRMAN KERR: The meeting will come to order. It is a meeting of the Advisory Committee on Reactor Safeguards, specifically the Subcommittee on Instrumentation and Control Systems.

My name is Kerr. I am Subcommittee Chairman. Other ACRS members present are Mr. Carroll, Mr. Wylie. We expect Mr. Lewis and Mr. Michelson.

Our consultants today are Mr. Lipinski, Mr. Davis, and I want to recognize Mr. Les Oakes from Oak Ridge who has recently been signed on as an ACRS consultant and is with us for the first time.

The purpose of the meeting is to review the proposed resolution of Generic Issue 115 entitled, "Enhancement of Reliability of the Westinghouse Solid State Protection System." Mr. El-Zeftawy is the cognizant ACRS staff member for the meeting.

The rules for participation were announced as part of the notice of the meeting published in the Federal Register of Wednesday, March 22nd, of this year.

A transcript of the meeting is being kept and will be available as stated in the Federal Register notice, and I would ask that each speaker identify himself or herself and use a microphone.

Are there any comments or questions from members of



1 the Subcommittee that you want to give any particular  
2 attention?

3 MR. CARROLL: I have none at this time.

4 MR. WYLIE: No.

5 MR. LIPINSKI: In looking at options, the one option  
6 that was not considered was to leave the existing system there  
7 and to add a diverse--

8 MR. WYLIE: I thought they did.

9 MR. LIPINSKI: They took one breaker out and put in  
10 a contact in its place, but no option--but what if they are  
11 both in place and add a third diverse system? And I would  
12 like that addressed.

13 CHAIRMAN KERR: You would like to know why they--

14 MR. LIPINSKI: Didn't consider it.

15 CHAIRMAN KERR: In your presentation; any other  
16 comments?

17 I would like to comment, and in light of having  
18 reviewed a resolution of another issue fairly recently, that I  
19 have found an evaluation described in, published in NUREG 5197  
20 a much more cogent and understandable analysis. I thought the  
21 preparers did--at least to me it was understandable and it  
22 seems logical, and it did not go to common mode failures,  
23 although the treatment of common mode failures still strikes  
24 me as smacking of witchcraft to some extent. Nevertheless,  
25 they used the witchcraft in an acceptable, in an accepted

1 manner.

2 MR. MINNERS: You forgot uncertainty.

3 CHAIRMAN KERR: Well, I did--in reading it, I was a  
4 bit curious and perhaps I missed this. If I did, I like to  
5 think it may have it identified. There seems to be no  
6 discussion of possible vulnerability of solid state system to  
7 electric spikes, the kind that might be generated by  
8 lightning, or perhaps it was there, and I missed it.

9 Then it also, I did not see any comments on possible  
10 common mode failures that might be due, for example, to  
11 overheating which would be caused by failure of the air  
12 conditioning system, and at least some solid state systems are  
13 vulnerable to this sort of thing, and I really wasn't sure  
14 whether I missed it or whether it is just common knowledge  
15 that it isn't vulnerable or something, so I would be  
16 interested in a comment.

17 Then in not the analysis itself, but in the letter  
18 that Mr. Beckjord wrote, there were some recommendations that  
19 resulted from this study for existing reactors, some things  
20 that might be done, not necessarily to be required by the  
21 staff I gathered, but some suggestions, and I think this is,  
22 this is a good idea because it would be unfortunate for all  
23 this effort to occur without some recommendations, and of  
24 course, one recommendation that is logical is to leave things  
25 alone, but at least the studies that were suggested may be

1 make sense.

2           However, I would also recommend that this staff not  
3 confine itself--in fact, I guess the staff didn't confine  
4 itself to existing reactors. It did I think say that this  
5 could be applied both to existing and to future reactors, and  
6 if that was the case, I would suggest also that some  
7 consideration be given to recommendation that future designs  
8 be changed slightly so that ATWS is not a problem.

9           I'm convinced that you can certainly make the  
10 consequences of an ATWS, of an ATWS much less severe than it  
11 is in some existing systems by design changes that at least  
12 people who know more about design than I do seem to think  
13 might not be so traumatic, and it does not appear to me that  
14 in the new reactors that are being considered, I guess the  
15 evolutionary ones, these changes are being considered  
16 seriously.

17           Those are the comments I had. And let's see. Mr.  
18 Kniel it says is going to open things up. Is that correct,  
19 Mr. Kniel?

20           MR. KNIEL: My name is Carl Kniel. I am Chief of  
21 the Reactor Plant Safety.

22           CHAIRMAN KERR: Don't be mike shy. Any of you who  
23 would find it more convenient to sit here at the table to use  
24 the Mike, please feel free to do so.

25           MR. KNIEL: My name is Carl Kniel. I am Chief of



1 the Reactor Plant Service Issues Branch, the Division of  
2 Safety Issue Resolution, and we are here this morning at the  
3 invitation of the Committee to give you a presentation on the,  
4 our resolution of Generic Issue 115, and this is, we are doing  
5 this in, as a follow-up to the agreement between our  
6 management and the Committee as to that you would at your  
7 option that you want to review issues for which we don't have  
8 a new requirement, and as you are aware, this particular issue  
9 doesn't have a requirement, and we sent it down to you at your  
10 option to have a meeting, and you have elected to have a  
11 meeting, and that's why we are here today, and Demetrius  
12 Basdekas is our task manager, and he will give the  
13 presentation on this issue.

14 CHAIRMAN KERR: You didn't say we are delighted to  
15 be here.

16 MR. KNIEL: No, I didn't.

17 MR. CARROLL: Are you?

18 CHAIRMAN KERR: Don't answer.

19 MR. MINNERS: Take the Fifth!

20 MR. BASDEKAS: My name is Demetrius Basdekas, and  
21 I'm with the Reactor Plant System Branch, Division of Safety  
22 Resolution, and I'm the task manager for the resolution of  
23 Generic Issue 115, which has been to develop the Westinghouse  
24 protection system.

25 During my presentation I will try to give you some

1 of the background that led to this establishment of this  
2 issue. I will give you the objectives and scope that was  
3 established for this resolution, and I perfectly understand  
4 the comments that were made earlier to the effect that perhaps  
5 this scope might or might not have included some additional  
6 options or some additional evaluation that otherwise might  
7 have been appropriate.

8 As you may recall from your previous experience, and  
9 as well as from reading the package that was sent you  
10 recently, this generic issue was established as a result of  
11 the two ATWS events that have taken place at the Salem plant  
12 in 1983. Those events initiated a number of actions, notably  
13 including the issuance of a Generic Letter 83-28, and as a  
14 sequel to that generic letter, another evaluation were  
15 performed by the staff as well as the industry, and the scope  
16 of this generic issue was established at that time as one that  
17 the staff had particular concerns regarding the reliability of  
18 the undervoltage driver card in the Westinghouse plants which  
19 had exhibited some problematic behavior in terms of failures  
20 that would have prevented possibly the action of the reactor  
21 when needed, and also the problems associated with  
22 undervoltage trip device, the undervoltage coil in the reactor  
23 assembly itself, so in other words, work will be addressed and  
24 have been, and/or are being addressed under Generic Letter  
25 83-28, and the implementation that the staff has made for the

1 scope of this generic issue is basically two options which  
2 were basically centered around fixes of problems associated  
3 with the undervoltage driver card which showed problems either  
4 by accepting the recommendations of Westinghouse which  
5 submitted, who sent a bulletin to all of the utilities  
6 outlining the problem and proposing solutions both in the near  
7 as well as in the long term as well as an additional staff  
8 recommendation of providing a redundant driver for the  
9 undervoltage coil that will be made of drivers, namely, relays  
10 placed vis-a-vis the solid state component, components that  
11 were used by Westinghouse, but as the generic issue progressed  
12 through its process of definition and subsequently more  
13 importantly, through its process of the resolution phases, it  
14 evolved somewhat and it evolved in the sense that the staff  
15 felt there were some additional options that ought to be  
16 considered, and the two increased to six, and then we had some  
17 more comment, but I'll discuss these options just as we go  
18 here.

19 (Slide)

20 MR. BASDEKAS: As I mentioned, there were ultimately  
21 six options that were evaluated that came out initially, but  
22 as well as in the process of our evaluation of the initial two  
23 options as we were going through the evaluation of this issue  
24 and as we, the staff and others were going through their  
25 evaluation of the licensee responses or compliance with the



1 requirements of Generic Letter 83-28, then some additional  
2 options were suggested to us which we undertook also to  
3 evaluate in a large initial scope of this issue.

4 The first option I already touched on briefly, was  
5 a, simply the replacement of the existing undervoltage driver  
6 cards in the logic cabinets supplied by Westinghouse to avoid  
7 the problem of shortened output of that card and damaging the  
8 transistor, the output transistor of that card that would have  
9 resulted in undetected failure leading perhaps to failure of  
10 the trip if it was, if both cards were involved, both things,  
11 so Westinghouse had recommended a new design of a card that  
12 simply incorporated the fusible, the output of that cards so  
13 that the particular failure mode would be eliminated. It  
14 would still open up and not be able to, you know, to stop the  
15 reactor, but nonetheless, it would have eliminated, does  
16 eliminate the possibility of having undetected failure that  
17 results in a failure of the breaker to trip.

18 Our survey showed that some of the licensees have  
19 chosen to modify the operating procedures and introduce test  
20 procedures that will avoid shorting of the output, but some  
21 others, and I think they are the minority, chose to purchase  
22 these new modified cards from Westinghouse and install them in  
23 their system, so it is, it has been a mix, and--

24 MR. CARROLL: One of the things that was not clear  
25 to me in going through this material was what was the nature

1 of or what really caused these various failures?

2 MR. BASDEKAS: It was during the periodic testing  
3 process that the technician would short out the output and  
4 damage the transistor.

5 CHAIRMAN KERR: In one word, what--

6 MR. BASDEKAS: Pardon me?

7 CHAIRMAN KERR: I said in one word, what caused it?

8 MR. BASDEKAS: Operator, maintenance testing.

9 MR. CARROLL: The statement is made somewhere that  
10 Option 1 would cure four of the five failure situations. What  
11 was unique about the fifth?

12 MR. BASDEKAS: It would not cure all failures. It  
13 will cure the possibility of having the, this particular card,  
14 the transistor in particular, damaged in such a way that it  
15 will not trip when it was supposed to and by fusible link--

16 MR. CARROLL: But of the five actual failures, I  
17 thought I read that Option 1 would have dealt with four of the  
18 five?

19 MR. BASDEKAS: Yes.

20 MR. CARROLL: What was unique about the fifth one?  
21 I didn't find--

22 MR. BASDEKAS: Okay. The fifth one, Don, would you  
23 comment on this one, please, what we have done? Okay. I will  
24 tell this later, but in any event, give a quick response.

25 MR. CARROLL: I can wait if you are going to cover

1 it later.

2 MR. BASDEKAS: Go ahead.

3 MR. RENY: I am Dan Reny from EG and G Idaho. The  
4 fifth failure was a random failure of component in the  
5 undervoltage driver card unrelated to the other four failures  
6 which caused the transistor switch problem, so the fix would  
7 not affect that fifth failure.

8 MR. CARROLL: On page 25 of the NUREG, which of  
9 those failures is that?

10 MR. BASDEKAS: Referring to NUREG or NUREG/CR?

11 MR. CARROLL: NUREG/CR.

12 MR. BASDEKAS: Okay.

13 DR. KERR: Do you have a copy readily available, Mr.  
14 Reny?

15 MR. RENY: I do.

16 (There was a brief pause in the proceedings.)

17 MR. RENY: The first one, the diode failure.

18 MR. CARROLL: Okay. That's what I guessed. All  
19 right. Thank you.

20 MR. BASDEKAS: We do have a--okay--details under the  
21 specific options, and they are proposed, what the staff  
22 outlined and we have examined here--we can cover later, and I  
23 do have some other--the last six vugraphs are back-up  
24 vugraphs, schematics of each one of the options, so let me go  
25 quickly over the other options we have examined.



1           Now Option No. 2 involved, I referred to earlier as  
2     a diverse undervoltage driver, relays to be installed in  
3     parallel with the existing solid state undervoltage driver  
4     cards.

5           Option No. 3 involves the diverse RTB actuation  
6     mechanism that involved the incorporation of another current  
7     type of circuitry that will burn up a fusible link in the same  
8     line as the RTBs.

9           Option No. 4 involved the deployment of an extensive  
10    diverse redundant trip logic system constructed of relays that  
11    will be the redundant and diverse counterpart of the existing  
12    solid state universal trip logic system that comes closer  
13    basically to what now Westinghouse plants would be required to  
14    do.

15          Option No. 5 involved the replacement of the  
16    undervoltage driver, the undervoltage coil, the undervoltage  
17    trip device which turned out to be the most unreliable in the  
18    particular part of the system, with a device of similar design  
19    as the shunt trip device.

20          And Option No. 6 involved the replacement of one  
21    reactor trip breaker with a contactor, and that presently you  
22    may recall we do have a configuration of one of the two--we  
23    have two reactor trip breakers in series and two bypass  
24    breakers in series connected in parallel, so this is, we have  
25    replaced one reactor trip breaker and one bypass breaker with

1 a contactor being a simpler device, device existing for  
2 reactor trip breakers, the best approach we took.

3 MR. WYLIE: Would this be a time to talk about the  
4 question about why other options were not considered?

5 MR. BASDEKAS: I'll be glad to answer you.

6 MR. WYLIE: Do you want to restate the question?

7 MR. LIPINSKI: My question is why didn't you add a  
8 third diverse trip system? Let me point out these two  
9 mechanical breakers are the weak link in this entire system.  
10 Just scanning over your data, in fact your data factor under  
11 there is something like five times ten to the minus 3  
12 probability of failure to demand on both of them.

13 MR. BASDEKAS: No. I think the numbers, we have  
14 got--

15 MR. LIPINSKI: You did your analysis but giving two  
16 breakers in series, and if I take their independent product  
17 and use it the way the new data compares, you should end up  
18 with five times ten to the minus 3. When you get to the  
19 analysis, we will take a closer look.

20 MR. BASDEKAS: Let's do that. I think we will be  
21 delighted to do that. It's an issue that has been debated  
22 extensively. It's a good legitimate question and we will  
23 address it. Can we take a few minutes as we go through it and  
24 and come to a point where we can do that?

25 MR. LIPINSKI: Sure, but the point is using my

1 contention that the two breakers are the weak link in the  
2 system, you would have to go in with a third system that would  
3 be diverse and not subject to the common cause failure.

4 MR. BASDEKAS: I understand your point.

5 MR. LIPINSKI: Let's talk about common cause  
6 failures. You are looking at a single plant. I am going to  
7 postulate that Westinghouse came up with a new super lubricant  
8 and then sent a letter out to all the operators saying here is  
9 this lubricant, install it in your breakers, but this  
10 lubricant has a peculiar property. It works nice for one  
11 year, after one year, turns to a property like epoxy, so now I  
12 not only have a common mode on the single plant, I have a  
13 common mode on a population of plants due to this common  
14 cause.

15 That type of analysis is not factored in, but given  
16 a diverse system, I think you have a lot more to offer in  
17 terms of going to a diverse trip.

18 MR. BASDEKAS: Well, let me defer responding in  
19 detail to your question, and I think already in this case Don  
20 will be also helping with the presentation because he will  
21 give you, when we come to it, a detailed step by step  
22 description of how we have done this analysis, the assumptions  
23 we made, if any, and the data we used, how we model the  
24 system, how we derive better factors for common cause  
25 failures, and will give you the reasons why our data turned



1 out to be based on what you cited for the two breakers  
2 combined, which is basically the trip function of, the good  
3 part of trip function, of the trip function of the reactor  
4 itself, the unreliability of that. Then we will show you that  
5 our numbers are different markedly from yours by--

6 MR. LIPINSKI: Let me ask you this question. Your  
7 report does not deal with sizes. What is the interrupting  
8 current and voltage that goes through a breaker?

9 MR. BASDEKAS: Well, it is 480 volts. I don't  
10 remember the amperage, but it is certainly--Don, do you happen  
11 to remember?

12 MR. RENY: I believe it is 600 amps.

13 MR. BASDEKAS: So we have examined the existing, you  
14 know, breakers, and we have examined operational experience.  
15 We have examined the potential failure modes that may be  
16 involved. We have used an approach for figuring out the  
17 common mode factors the other factors.

18 MR. LIPINSKI: We will talk about common mode later?

19 MR. BASDEKAS: Sure.

20 MR. LIPINSKI: In terms of waiving--but diverse is  
21 not coming into the picture other than in your one case.

22 MR. BASDEKAS: We did provide in one case, you will  
23 notice we provided a fusible link for both trains.

24 MR. LIPINSKI: That doesn't get rid of my mechanical  
25 breaker common mode.

1 MR. BASDEKAS: But it is a diverse way of  
2 interrupting power.

3 MR. LIPINSKI: It does not guarantee the two  
4 mechanical devices will function if I have done something  
5 wrong to them.

6 CHAIRMAN KERR: Why don't you, as you said, look at  
7 this in detail? There is a more logical matter.

8 MR. BASDEKAS: I will come to it and I will keep it  
9 in mind to revisit the question.

10 The best approach we took here was to--

11 MR. OAKES: Demetrius, I wanted to ask a question.  
12 Perhaps it isn't the correct time to ask it, either, but maybe  
13 we will take the issue up later.

14 Are you going to discuss these options in more  
15 detail, or is that the last time you are going to talk about  
16 the options?

17 For example, Option 1, one's sensibility is  
18 offended by the fact that we have solved a, what appears to be  
19 an incompetence problem in maintenance by adding a  
20 non-testable device, a fuse.

21 MR. BASDEKAS: No. It is not--well, they, they have  
22 provisions for considering the fuse and make sure that it is--

23 MR. OAKES: What I was going to ask is--perhaps this  
24 isn't germane to our discussion, but have other options for  
25 limiting the current been looked at, something that is

1 testable by current limiters, and does one know that the fuse  
2 will always blow before the resistor is damaged in this case?  
3 Are there data to support it?

4 MR. BASDEKAS: It is a quality assurance question.

5 MR. OAKES: Have tests actually been made to show  
6 that it will or not in most cases blow before it damages the  
7 resistor?

8 MR. BASDEKAS: I'm not aware of any test performed  
9 by Westinghouse or anybody else, but the description of the  
10 quality assurance is programs, they do address the integrity  
11 of the new design, notably the fuse.

12 CHAIRMAN KERR: Mr. Reny, you were about to make a  
13 comment?

14 MR. RENY: Yes. The fuse was added to prevent the  
15 use of the undervoltage driver after a short circuit has been  
16 applied to it such that the undervoltage driver would have to  
17 be removed and tested prior to its use again, so the fuse  
18 prevents the use of the cards in case the transistors have  
19 been damaged before the fuse blew.

20 MR. LIPINSKI: You are saying short, but you can  
21 have various degrees of shorting which are not necessarily  
22 zero ohms that draw current.

23 The question is can you draw the current through  
24 that fuse damage, the output transistor, and not blow the  
25 fuse?



1 MR. BASDEKAS: The size of fuse was determined on  
2 the basis for such as the--

3 MR. LIPINSKI: Zero ohms, that is an assumption on  
4 your part--they are very low in peak shorts that draw high  
5 currents.

6 MR. BASDEKAS: That's a good point, but I think it  
7 has been provided as part of the design. Faust Rosa?

8 CHAIRMAN KERR: Faust, will you come to a mike,  
9 please, sir?

10 MR. ROSA: I am Faust Rosa, Chief of the Electrical  
11 Systems Branch in NRR.

12 I recall the presentation that Westinghouse made on  
13 the subject of these driver cards some years ago, and as I  
14 recall, the fuse is rated at about five milliamperes, and the  
15 transistor can withstand up to around 20 milliamperes, so  
16 there is, there is very little change that a short circuit  
17 will not blow the fuse before it damages the transistor.

18 MR. WYLIE: Let me ask a question in that regard.  
19 You know, they have a habit of opening when you don't want  
20 them to open.

21 Do you know whether Westinghouse or anybody looked  
22 at the increased probability of SCRAM rates due to the  
23 addition of these fuses to opening when you don't want them to  
24 open?

25 MR. ROSA: I'm not aware of any Westinghouse study

1 on that.

2 MR. BASDEKAS: However, they did make a provision,  
3 Charlie, that they do X-ray them in case there is some defect.

4 MR. WYLIE: You know, fuses as they age, at least my  
5 experience has been that strange things happen. They open  
6 when you don't want them to open. They all are good when they  
7 are new, but generally these are silver sand fuses or some  
8 other type of fuse, and after some years, why they start  
9 opening, and I wondered whether anybody looked at that as to  
10 what the risk associated with increased SCRAM rates are by  
11 adding fuses.

12 MR. KNIEL: I think about--

13 CHAIRMAN KERR: Microphone, please, sir. We record  
14 these priceless words.

15 MR. KNIEL: According to an INPO document, 25  
16 percent of the SCRAMs come from various malfunctions in the  
17 reactor protection system at this stage, so--I think it is 22  
18 percent to be exact, so I don't think that this hypothetical  
19 mechanism you are talking about is going to have very  
20 significant impact on something that is already pretty, pretty  
21 dominant.

22 MR. WYLIE: You mean by increasing the scam rate?

23 MR. KNIEL: Right. And the SCRAM rate deficiencies,  
24 I mean the deficiencies from the SCRAM rate come from other  
25 components in the reactor protection system, principally the

1 instrumentation and the, and the lines that bring in the  
2 instrumentation and that kind of stuff; doesn't come from the  
3 reactor protection system, the SCRAM breakers.

4 CHAIRMAN KERR: Let me say I wasn't sure I  
5 understood what you said. Twenty-five?

6 MR. KNIEL: Twenty-two percent is the number.

7 CHAIRMAN KERR: Twenty-two percent of the false  
8 SCRAMs, what other term we were using, come from malfunctions  
9 of the trip breaker?

10 MR. KNIEL: No--come from malfunction of the reactor  
11 protection system.

12 CHAIRMAN KERR: Oh, okay.

13 MR. KNIEL: Only a very small fraction of those come  
14 from the breaker malfunctions. This is the existing data that  
15 we have today.

16 CHAIRMAN KERR: I don't know what 25 percent means.

17 MR. KNIEL: I think right now what is it, like four  
18 SCRAMs per reactor year? Per plant; roughly in the ballpark,  
19 so--

20 CHAIRMAN KERR: If you had an additional SCRAM, it  
21 would increase things by 20 percent? Twenty-five percent I  
22 guess?

23 MR. KNIEL: Yes.

24 MR. LIPINSKI: Per year?

25 CHAIRMAN KERR: Yes.



1 MR. KNIEL: What I am trying to point out is that  
2 this small slight increase in possibility of the fuse failing  
3 and SCRAMing the plant, what appears to me a microscopic  
4 number compared to what we have in the existing--

5 CHAIRMAN KERR: The response to Mr. Wylie's question  
6 is nobody has looked at it?

7 MR. KNIEL: That is correct.

8 CHAIRMAN KERR: Which is what he asked, if anybody  
9 had looked at it, and the answer is nobody is?

10 MR. KNIEL: Well, I am trying--

11 CHAIRMAN KERR: Perhaps for good reason.

12 MR. KNIEL: I am trying to give you the facts as I  
13 understand today as reported in the INPO report, and the  
14 implication is that the mechanism that suggested would have a  
15 very minor--

16 CHAIRMAN KERR: He is not the sort of person that  
17 goes around making implications. He just asked a question.

18 MR. KNIEL: Okay. I am trying to give the--

19 MR. BASDEKAS: Let me reiterate what I said earlier.  
20 It is a concern, good one. It is a valid one shared by  
21 Westinghouse. They provided, they have a provision as part of  
22 their quality assurance program to X-ray these fuses before  
23 installation.

24 Now whether or not this calls for priority X-ray, I  
25 am not in a position to say, but that we will find out. I

1 will let you know, Charlie, so that we close the loop on this  
2 question, but as I said, it is a concern that is shared by  
3 Westinghouse and the staff and to address it at least in a  
4 practical, meaningful way, will be to have the X-ray at least  
5 before installation. I'm not sure if that entails also  
6 X-raying priority thereafter.

7                   Going back to the--

8                   MR. CARROLL: I have one thing that was troubling  
9 me. I guess I heard that Westinghouse rates the fuse, what  
10 was it, 5 milliamps? And the transistor is quote, good for 20  
11 milliamps, and that really doesn't tell the whole story.

12                   The fuse blows, it doesn't heat, which is there is  
13 some relationship between current and resistance and time, and  
14 the transistor is damaged because of heat which is some other  
15 relationship involving current and resistance and heat and  
16 time.

17                   I'm not sure a 5 amp, quote, 5 amp fuse protects a  
18 quote, 20 amp rated transistor on the face of it.

19                   MR. BASDEKAS: Well, I do not have that direct  
20 knowledge, but I think based on my understanding of what the  
21 process of sizing design in this particular modified card, we  
22 went to the sizing of the fuse.

23                   I cannot--Faust--

24                   MR. CARROLL: Did Westinghouse run tests that would  
25 make me feel better if they did?

1 MR. BASDEKAS: I cannot answer the question.

2 MR. ROSA: Yes, Westinghouse did run tests, and the  
3 addition of this, this fuse in the output driver card is their  
4 recommendation, which they have transmitted to all of their  
5 licensees.

6 MR. LIPINSKI: Let me pursue that question because I  
7 would venture probably the test that Westinghouse ran was a  
8 steady state test, but you put a transistor test on, you have  
9 a momentary short and release it; did they look at it as a  
10 function of time, zero out in terms of mode seconds  
11 application of the short?

12 MR. ROSA: I have no idea of the details of the  
13 test.

14 MR. LIPINSKI: Then it is a race between the heating  
15 of the fuse and the heating of the transistor as to who goes  
16 first.

17 MR. BASDEKAS: I think the fuse will go first.

18 MR. LIPINSKI: But the point is if I only have a  
19 momentary and then heat the fuse long enough to open it, but I  
20 could blow the transistor which is faster responding  
21 temperature-wise--

22 MR. BASDEKAS: Your point is well taken, but we do  
23 have fuse and fuse, we have quick response fuse and slow  
24 burning fuses.

25 MR. LIPINSKI: Right now we are discussing the



1 critical point in the decision.

2 MR. WYLIE: What kind--

3 MR. ROSA: Demetrius, about seven or eight  
4 Westinghouse plants have installed these driver cards. They  
5 have been installed for some five years.

6 MR. BASDEKAS: It varies. Not necessarily; some  
7 perhaps as long as five, some perhaps as long as one or more.

8 MR. ROSA: We haven't had any reports of a failure  
9 of one of those fuse scausing a spurious SCRAM.

10 MR. CARROLL: But the other variation of that is to  
11 disable the driver cards and don't know it. In other words,  
12 making this mod seems to me to give people a false sense of  
13 security.

14 MR. BASDEKAS: If the fuse, if the fuse burns or if  
15 the fuse does not burn, it does not burn, you are no worse  
16 than what you have with the fuse.

17 MR. ROSA: The fuses in this series is with the,  
18 with the trip coil, the undervoltage trip coil, so if the fuse  
19 blows, you get a SCRAM, period.

20 MR. CARROLL: But the transistor is damaged.

21 MR. ROSA: Then you must rely on your periodic  
22 testing which occurs every two months, every two months now.

23 MR. BASDEKAS: Highly unlikely occurrence, Mr.  
24 Carroll.

25 MR. LIPINSKI: Let's get back to the testing mode.

1 Are both--

2 MR. BASDEKAS: Of what?

3 MR. LIPINSKI: Undervoltage drivers; are they both  
4 tested at the same time, or tested on alternate months?

5 MR. BASDEKAS: Alternate months.

6 MR. LIPINSKI: So they can't be subject to the same  
7 failure at the same time?

8 MR. BASDEKAS: That is correct. The basic approach  
9 we took in resolving of this issue, as you know, it is  
10 basically that one deploys, of course, the cost/benefit the  
11 methodology, and to accomplish that we perform a reliability  
12 analysis of the reactor trip system. We started with the base  
13 case and we have done the same thing for the options as  
14 modified based on the proposed modifications.

15 We did core damage frequencies for each one of them.  
16 We proceeded to the consequences based on a site, typical  
17 Midwestern site characteristics. We did perform a cost  
18 analysis for each option, and we did perform a scientific  
19 analysis to show us the level of confidence we can attach to  
20 the results we are getting and to see which parts of the  
21 system are the most contributing to risk in this particular  
22 system.

23 And finally, we, and I see a mistake here which on  
24 the slide we have a discussion with the decision rationale and  
25 the recommendation we developed as a result of this analysis.

1 (Slide)

2 MR. BASDEKAS: I will try to discuss next the steps  
3 we went through to have the, this process accomplished, and  
4 the first thing we have done was to evaluate the, the base  
5 case six options.

6 The base case includes the automatic shunt trip  
7 function which was added after the 1983 events at Salem. That  
8 particular addition alone contributes significantly to the  
9 improvement of the trip reliability.

10 We have made some assumptions here that we find them  
11 reasonable, and they are namely, we assume that all electrical  
12 power sources were available to allow the reactor protection  
13 system to function properly, and we have also assumed that  
14 once the trip is initiated, it will go to completion as far as  
15 movement of the control rods. In other words, our scope of  
16 work did not include the mechanical part of the actual rods  
17 per se, move it into the core.

18 The next vugraph shows the functional diagram and  
19 one that we used--the reactor protection system, and one that  
20 we used to model it for purposes of analyzing its reliability.

21 (Slide)

22 MR. DAVIS: Excuse me. I have a question on your  
23 previous slide.

24 MR. BASDEKAS: Previous slide, yes, sir.

25 MR. DAVIS: Did you assume that if SCRAM failed, you



1 would always get core damage?

2 MR. BASDEKAS: No.

3 MR. DAVIS: Because I believe for Westinghouse  
4 plants, they can ride through it and not guarantee it is  
5 unfavorable.

6 MR. BASDEKAS: That is correct. We took that into  
7 account, and we can cover it as we go down the line in the  
8 consequences and the calculations.

9 MR. DAVIS: You may want to revise the last  
10 paragraph, Roman 12, of your NUREG 1341 because it says there  
11 that SCRAM must take place within one minute to avoid core  
12 damage.

13 MR. BASDEKAS: I see--in most cases.

14 MR. DAVIS: I'm not sure it is in most cases.

15 MR. BASDEKAS: At least in selected cases.

16 MR. MINNERS: Don't rewrite it now.

17 MR. BASDEKAS: It is intended to show it is  
18 important as far as the operator action goes. It is part of  
19 the operator take some action within one minute.

20 DR. KERR: No matter what it is intended to show, if  
21 it is incorrect, I expect you will want to look at it again.

22 MR. BASDEKAS: We will certainly look at it.

23 MR. DAVIS: Westinghouse has made a big case for  
24 installing the AMSAK system that will allow them to ride  
25 through the SCRAM failure.

1 MR. BASDEKAS: That is exactly right. We will  
2 discuss that in the Executive Summary as well as in--

3 MR. MINNERS: What was the page again?

4 MR. DAVIS: Roman 12, the last paragraph; thank you.  
5 You have answered the question.

6 MR. BASDEKAS: Sure. Thank you.

7 (Slide)

8 MR. BASDEKAS: Okay. This document shows the best  
9 portions of the reactor protection system are on the basis  
10 of--which our contractor developed the reliability model that  
11 was implemented in the IRIS computer code. That stands for  
12 Integrated Reactor Risk Analysis System, and this has been  
13 very useful in being able to analyze the various options as  
14 well as the sensitivity of the system to various parameters  
15 that are involved here.

16 Basically as you see here, as you have seen before,  
17 is the channels, and the number of them varies from design to  
18 design. Some, they have three. Some may have four, or even  
19 two in some instances.

20 Then you have the input relays and universal logic,  
21 part of which is the undervoltage driver cards on both trains,  
22 and finally, the two reactor trip breakers.

23 As you notice there, the operator enters and can  
24 override or compensate for a failure in the system starting  
25 with the input relays up to and including the undervoltage

1 driver cards. This was part of the considerations we had to,  
2 we did make and carry a number of these calculations starting  
3 with the particular ability core damage frequency consequences  
4 and cost benefits with or without operator action. We felt  
5 strongly that operator error here can have some significant  
6 impact, and we have carried this throughout.

7 The next--

8 MR. CARROLL: With regard to the operator action,  
9 I'm sure it doesn't apply or doesn't have a major effect, I  
10 guess I would point out that in projects with a high seismic  
11 design, the operator ain't there. He is on the floor.

12 MR. BASDEKAS: For most cases--

13 MR. CARROLL: Is not available to intervene and  
14 initiate a SCRAM.

15 MR. BASDEKAS: Sure. That is correct. That's, for  
16 those cases, we have calculation performed without operator  
17 action, and the attendant numbers, string of numbers that we  
18 have calculated, so the sensitivity of operator error of  
19 omission or just inability to perform a safety action, it's  
20 reflected in our calculations.

21 (Slide)

22 MR. BASDEKAS: Moving on here, I think the next  
23 slide will show an apportionment of the unreliabilities of the  
24 reactor trip system. As you see here, common mode failures  
25 dominate the risk contributions. The reactor trip break is



1 common cause failure rate ten to the minus 5 and represents 40  
2 percent of the total, and so does the analog channel common  
3 mode failure distribution, and only 20 percent is represented  
4 by others, principally independent failures as well as some  
5 common cause failures that are rather weakly linked in the  
6 contributions.

7 The reactor trip and unreliability results are, for  
8 the base case, are calculated in the performance slide. I am  
9 just going through the slides quickly just for the sake of  
10 completion. You have seen them tabulated in the reports  
11 before, and I don't want necessarily to be repetitious of what  
12 is in the report because you have seen them or you would have  
13 seen them I assume.

14 And the contributions, here we are talking, well,  
15 the unreliabilities of the base case before everything, any of  
16 the options were incorporated there and analyzed, without  
17 operator action were five times ten to the minus 5, and with  
18 operator action, 2.5 times ten to the minus 5, so the operator  
19 action there accounts for a factor of two in the total  
20 unreliability of the function.

21 (Slide)

22 MR. BASDEKAS: The next slide shows the same numbers  
23 for each of the options, and I would like to draw your  
24 attention to the bottom line there, the total, and most  
25 specifically the delta from the base case, the change from the

1 base case which these numbers here are, the minus sign denotes  
2 a reduction in the unreliability, and you will see here that  
3 all options have a minus sign in front of them except for  
4 Option No. 5, which have an increase in risk.

5 Well, that's an eye opener for us because the  
6 situation for that option is that if we replace the  
7 undervoltage trip device which had proven to be the most  
8 troublesome in the reactor trip breaker failure rate, the  
9 studies, if we replace that with a shunt trip device which  
10 turned out to be something like ten times more reliable than  
11 the undervoltage device, then we felt perhaps we are moving  
12 the reactor and therefore we increase the reliability of the  
13 system.

14 Well, it turns out by removing the undervoltage  
15 device and replacing it with a shunt trip, we were removing an  
16 important diversity from the system, so the common cause--

17 CHAIRMAN KERR: Diversity which you quantified by  
18 guess?

19 MR. BASDEKAS: Pardon?

20 CHAIRMAN KERR: And a diversity which the  
21 contribution you quantified by a guess?

22 MR. BASDEKAS: No. Was not quantified by guess.  
23 Was quantified by rational experience.

24 CHAIRMAN KERR: Operational experience in terms of?

25 MR. BASDEKAS: Yes, operational experience, the same

1 event and the benefit factor.

2 CHAIRMAN KERR: The same event, you were saved by  
3 having a shunt trip.

4 MR. BASDEKAS: Well, let me put it in perspective.  
5 There was no shunt trip in the same event because the shunt  
6 trips were still late, so it was at undervoltage devices or  
7 except for manual.

8 CHAIRMAN KERR: I thought you were going to convince  
9 me of the shunt trip. You are convincing me now that the  
10 undervoltage trip is unreliable, and I don't have to be  
11 convinced of that. I am already convinced of that.

12 MR. BASDEKAS: We removed the undervoltage and  
13 replaced it with the shunt which was more reliable.

14 CHAIRMAN KERR: That makes the whole thing less  
15 reliable, and I am saying that conclusion is reached by, based  
16 on the contribution that you give to diversity, and that is  
17 unquantifiable.

18 MR. BASDEKAS: Well, we used persistent sets of data  
19 as far as, as far as the benefit factors of the--

20 CHAIRMAN KERR: Consistency can be both wrong and  
21 right. You know, you could be consistently wrong.

22 MR. BASDEKAS: Right, and we can be consistently  
23 right, which we hope that was the case, and since you brought  
24 up the subject here, it may be a good time to ask Dr. Reny  
25 very shortly to give his brief presentation of our, exactly



1     what data were used for components. In other words, the  
2     undervoltage, the shunt trip, and the overall breaker  
3     reliability, you know, as well, one by one based on  
4     operational experience were extracted from whatever source you  
5     could get, including the NPRDS data, so let me finish this  
6     here and point out the fact that okay, all options showed a  
7     favorable result here except one, and I do appreciate your  
8     statement that the benefit factor is something that had some  
9     uncertainty associated with it, but to offset it in more  
10    concrete and specific terms, I would like to ask at this time  
11    Don Reny to give you a brief discussion of what they have done  
12    for us in this area, and hopefully we will answer your  
13    questions in a way that I believe will be an intelligent and  
14    defensible conclusion.

15                 Go ahead.

16                 MR. LIPINSKI: The data factors were confirmed  
17    statistically?

18                 MR. BASDEKAS: Why don't we let Don--

19                 MR. MINNERS: Let's finish up your presentation,  
20    okay?

21                 MR. BASDEKAS: We will make the presentation. Fine.

22                 MR. MINNERS: Why don't you finish up and then we  
23    can do this sidebar stuff at the end?

24                 MR. BASDEKAS: Okay. The next step in the process  
25    applied earlier was to perform core damage frequency results,

1 and these analyses included directions of the NTC and the  
2 overall thermal hydraulic behavior of Westinghouse plants, and  
3 the results that we got here are, do show, the minus sign here  
4 denotes an increase in CDF, and you see Option 5 reflects the  
5 same type of behavior that we showed earlier in the  
6 reliability calculations.

7 (Slide)

8 MR. BASDEKAS: The consequences--okay. The  
9 cost/benefit evaluation methodology involves specific  
10 analysis. This is basically summarizing these specific steps.

11 The ATWS event consequences, the core damage  
12 analysis, the generic consequences analysis which I referred  
13 to earlier as a set of characteristics for a typical  
14 Mid-western site, the proposed analysis for each proposed  
15 option, and the proposed options cost/benefit results--the  
16 approach here was taken in an analytical sense, it was to vary  
17 the reactor trip reliability and cost for each option and hold  
18 the rest of the parameters constant, and finally evaluate the  
19 option changes from the base case.

20 MR. DAVIS: I have a question on your consequence  
21 analysis. I realize this is a difficult one, but I noticed  
22 that your consequences varied quite a bit and you had to  
23 select a number, I think it was 2.4 ten to the minus 6 or ten  
24 to the plus 6 person-rem per event or something like that.

25 MR. BASDEKAS: All right. Yes.

1           MR. DAVIS: And that was based on an analysis done  
2 with the CRAC code. Of course, now the last couple of years  
3 that code has been replaced by the MACKS code which actually  
4 produced higher consequence because of the revised lung dose  
5 models.

6           MR. BASDEKAS: Right.

7           MR. DAVIS: I am wondering if you looked at, for  
8 example, NUREG 1150 results to see if there is a big  
9 difference between what you use and what is now being  
10 calculated for that accident?

11          MR. BASDEKAS: Your observations with respect to the  
12 CRAC code are correct, and we had our Idaho people follow us  
13 as close as practically, as practical, what analysis were  
14 done, as part of the 1150 work were done. Would you like to  
15 comment some specifically, if it is a quick response?  
16 Otherwise we will cover it later.

17          MR. RENY: Yes. There is a wide spread. However,  
18 the two low points of the four consequence data points I used  
19 here were taken from NUREG 1150 for the Surry and Sequoyah  
20 plants, consequence analysis for ATWS events that led to core  
21 damage, so the NUREG 1150 studies actually showed lower  
22 consequence results for ATWS events that led to core damage.

23          MR. DAVIS: I think those were the previous system  
24 results and not the most recent. Maybe they haven't changed  
25 that much, but the reference you gave for those two cases was



11 1 a report by Benjamin I believe, which is 1986, so it must have  
2 been the original NUREG 1150 calculations. I don't want to  
3 belabor it now, but I think the concern is that you can get  
4 substantial variation in consequences, and that has a linear  
5 input on your cost/benefit analysis.

6 MR. MINNERS: Is that something new, Pete? The last  
7 time I talked to the people who I thought knew something about  
8 variance he said there wasn't that big a difference between  
9 the two.

10 MR. BASDEKAS: In the ATWS at least category, that  
11 was our impression. Now we will check it out.

12 MR. DAVIS: You could be right. I have not myself  
13 seen the NUREG 1150 results for ATWS, for Westinghouse plants.

14 MR. BASDEKAS: We made the point since a  
15 particularly--because of the group that was doing the work for  
16 us were sitting next door to the ones working 1150 and the  
17 successful thing to do at least keep an eye and talk to one  
18 another as to what was going on, and I think what Dr. Reny  
19 says basically is that--and what Warren Minners also said,  
20 they were not too far off in the ATWS.

21 MR. DAVIS: My impression is the number you used is  
22 possibly conservative, which would--

23 MR. BASDEKAS: As a matter of fact, it is. There  
24 are--

25 MR. DAVIS: Tend to support your overall conclusion.

1 MR. BASDEKAS: That is exactly right, because we  
2 knew over the 25 rem, you know, limitation, placed under the  
3 CRAC calculations, we are mindful of that, but we will make  
4 allowances to compensate so that we have, you know, a more  
5 conservative outcome, but your point is well taken.

6 Here we show briefly the cost results. I'm not sure  
7 if we need to go through number by number under the  
8 option-by-option basis.

9 (Slide)

10 MR. BASDEKAS: We did get some estimates that we  
11 call the best, but there are some things and some, some people  
12 can argue that well, it is too high, some people, it is too  
13 low. We took the respondents' view into account, and our own  
14 independent judgment, and came up with a low, best, and high,  
15 and it was one distribution, a triangular, linear type  
16 distribution that was used later on in a separate analysis.

17 The next, I think the next few tables are just  
18 reductions of what was in the main two documents that we have  
19 seen, but I think it will be worthwhile to go selectively over  
20 some of them, and what we see on this particular table is the  
21 cost/benefit calculations we received both in terms of  
22 person-rem reduction without operator action, and with  
23 operator action, so as I indicated earlier, we made the point  
24 to carry this throughout and observe the sensitivity of  
25 operator action, you know, as we went down the line basis

1       rather than just do it once and forget about it.

2               MR. DAVIS: I have a question on that table. The  
3 numbers don't seem to agree with the table on page 12 of your  
4 NUREG 1341 report in the cost/benefit per person-rem column.

5               MR. BASDEKAS: With or without operator? Because  
6 there perhaps we give only--I don't remember. Okay.

7               MR. DAVIS: Neither one of them agree, although the  
8 with operator SCRAM is much closer. I don't know if I am  
9 comparing it right or these tables are directly comparable or  
10 not, but you might want to check on that.

11              MR. BASDEKAS: Okay. Let me make a note and check  
12 on this because we have different, we presented the results in  
13 different ways, and what may be the page number what--you said  
14 page what?

15              MR. DAVIS: Roman Numeral 12.

16              MR. BASDEKAS: Okay.

17              MR. MINNERS: Table 10 on page 21 is the same  
18 number.

19              MR. BASDEKAS: Later on--okay.

20              MR. MINNERS: We just screwed it up in the Executive  
21 Summary.

22              MR. BASDEKAS: Well, I'm not prepared to say. Let's  
23 not resolve this right here and now. If it is a mix-up of  
24 tables, we can fix this up, but they came from the same  
25 source, and as Warren points out, on page 21 and this slide,



1 they are consistent. We will check it out.

2 MR. MINNERS: Must be a different table. On page 14  
3 they have got the same numbers.

4 MR. BASDEKAS: It probably is, but Warren, let me  
5 take your advice seriously and say let's go on with the  
6 presentation and we will resolve this later.

7 MR. CARROLL: Now on the thousand dollars per  
8 man-rem basis, doesn't that suggest Option 3 at least--

12  
9 MR. BASDEKAS: It shows that it would be cost  
10 beneficial, but there is a good reason why we decided that it  
11 was not. This was based on point estimates that we received  
12 from a single source, the source being the proprietary of the  
13 particular option, when performing a sensitivity analysis,  
14 receiving independent cost estimates in writing, and we made  
15 our own judgment.

16 It turned out both in terms of say new point  
17 estimates, more particularly the uncertainty mean numbers we  
18 received or we got from the low and high numbers of the range,  
19 of course, for a particular option showed it not to be cost  
20 effective ultimately, and I believe that we have a discussion,  
21 decision rationale for that particular option and point out  
22 why we chose a different number than the one that appears in  
23 this particular table.

24 MR. CARROLL: I read all that. Then I see you are  
25 presenting this table again.

1 MR. BASDEKAS: Okay. As I said, it is a progression  
2 of things we have done, and here this table historically  
3 speaking did not include an uncertainty analysis, not yet.

4 MR. CARROLL: All right.

5 (Slide)

6 MR. BASDEKAS: Now we will come to the uncertainty  
7 analysis. I think the uncertainty here is two basic  
8 components that draws the set from--that's the model, the  
9 model that we started earlier, used for reliability  
10 calculations for the system, and the other is the ATWS events  
11 sequence model that we used as consequence analysis, that we  
12 do have some uncertainties.

13 Then the other group of uncertainties come from the  
14 data that we used such as operational experience. The failure  
15 rates were calculated and so forth, so there is uncertainty.  
16 Uncertainty was calculated for each option based on the base  
17 case risk uncertainty and on the option risk uncertainty.

18 The cost uncertainty steps I said, described earlier  
19 from the cost data we have received from various sources, some  
20 better than others, of course, and these were evaluated  
21 quantitatively, and the cost/benefit uncertainty is the cost  
22 uncertainty divided by the risk uncertainty.

23 Now the data uncertainty, and I don't want to--but  
24 it is important to describe, that is the basic process we went  
25 through here.

1 (Slide)

2 MR. BASDEKAS: In calculating the data uncertainty;  
3 there were three basic steps, and each of the steps involved a  
4 distribution of a given parameter, namely, step A  
5 included--and I have an attachment here for the lack of  
6 anything better or anything, Monte Carlo calculations to the  
7 two mode distributions to come up with a third distribution,  
8 and the UNC standards for uncertainty in brackets throughout  
9 this particular slide are intended for whatever operations  
10 were necessary in the analysis, statistical analysis, the  
11 data--I took them up with it basically, so the uncertainty of  
12 the core damage frequency was calculated by performing an  
13 uncorrelated Monte Carlo random sampling of the distribution  
14 for the reactor trip unreliability, and for the initiating  
15 event sequences.

16 There was a log normal distribution assumed for the  
17 reactor trip unreliability and almost normal distribution for  
18 the initiating event sequences resulting in a distribution and  
19 attendant uncertainty on the right-hand side of the equation  
20 of the core damage frequency.

21 The next step involved a single operation here  
22 involving the core damage frequency distribution which we  
23 derive from A, the consequences distribution times the reactor  
24 years. We figure it out in terms of for all plants, and that  
25 was the uncertainty and the risk, and finally, step number C



1 included a similar operation, but this one here was a  
2 correlated Monte Carlo random sampling because both the base  
3 case and the option case risk, associated risks were not  
4 independent. They were correlated, so that was the basic  
5 analytical process used here to calculate uncertainties of the  
6 various, of the various steps of analysis.

7 (Slide)

8 MR. BASDEKAS: Here we show the base, the results of  
9 the base case uncertainty results with and without operator  
10 action, again emphasizing the system sensitivity in operator  
11 errors, and just summarizes the bottom line data in terms of  
12 the mean values, the 5th and 95th and 50th percentiles. These  
13 were used later as you will see in the cost/benefit  
14 uncertainty analysis, and the results of that analysis are  
15 shown in the next slide.

16 (Slide)

17 MR. BASDEKAS: This vugraph shows both with and  
18 without operator action on the cost/benefit in terms of  
19 dollars per person-rem reduction for each option along with  
20 the percent probability to be between zero and a thousand  
21 dollars and probability of to be more than a thousand dollars,  
22 and you can see that we have a wide variation in this, the  
23 distribution parameters in here.

24 On the next slide we make comparison of the point  
25 estimates and the uncertainty means. Here you will see we do

1 have a--well, okay--here we have point estimate to mean, but  
2 to take it as the point estimate, the mean is there just for I  
3 guess, I think it slipped into our tabulation to indicate that  
4 we are going to make the point estimate, you hope you are  
5 close to the mean, but talk basically in one column we have  
6 the point estimate, in the other, the mean derived from the  
7 distributions, and the statistical analysis you perform on the  
8 data data that we analyzed, so in responding to or follow-up  
9 on Mr. Carroll's statement, it was this step of the results  
10 that prompted us to make judgments well, on all six, but I  
11 believe you referred to Option 3 that exhibited a point  
12 estimate favorable cost/benefit ratio, so based on the results  
13 we have seen, both in the statistical analytical sense, but  
14 equally important, if not more so, in the judgments we had and  
15 we did make, based on insights we have gained during this  
16 process of going through step by step and perform these  
17 analyses, we have concluded that there were no backfit  
18 requirements based on the requirements of the backfit rule or  
19 the guidelines, the guidance of the backfit rule.

20 However, as I indicated, a PRA analysis is useful in  
21 ways other than just the ability to come up with a set of  
22 numbers, is the opportunity that it offers you to gain  
23 insights of how the system works, where the sensitivities are,  
24 and how you can best fix it if you please to get the most  
25 benefit for the money, and based on this collective body of

1 work and knowledge we derived from that, as I said earlier, we  
2 have come to the conclusion that no backfit requirements are  
3 warranted.

4 Okay. That's fine. And I think we have gone  
5 through some agonizing discussions--well, not very agonizing,  
6 but nonetheless, some, you know, extensive discussions as to  
7 why we should accept and what numbers we should accept as  
8 valid numbers, and where are those conclusions?

9 However, in the process of doing so, and based upon  
10 the insights we have gained, we felt that even though we can  
11 not impose regulatory requirements, it would have been  
12 wasteful if we did not make our insights available to other  
13 parts of the Agency, and indeed others for that matter, so  
14 this last vugraph here called further work, it is something  
15 that goes beyond the, you know, the strict resolution of this  
16 issue.

17 This issue we consider resolved which by taking, by  
18 proposing no new regulatory requirements. However, there is  
19 some related to this issue, activities going on within the  
20 Agency that we have been involved in helping formulate their  
21 actions, and/or vice-versa, getting inputs from them, namely  
22 and most specifically, Mr. Rosa here, and his people, and as  
23 well as another group within NRR dealing with revising  
24 technical specification test requirements and this type of  
25 thing, and too, the insights that we have gained prompted us



1 and it will bring to the attention and as you probably read in  
2 the draft document that we are submitting to EDO and the  
3 Director of NRR, we are bringing to their attention the fact  
4 that it will be worthwhile to have further activities that we  
5 have ongoing within the, within the Agency to consider these  
6 things that I list here, namely, the first one I believe that  
7 it will be very useful and perhaps productive to consider the,  
8 decreasing the reactor trip test frequency in conjunction with  
9 the addition of a trip function in the M/G set breaker or  
10 breakers as the case may be, either the breaker or the  
11 generator or, the output breaker or the generator for the M/G  
12 set, and this compensates for the increase in the interval  
13 between tests of the RTBS and perhaps at the same time, the  
14 increase of, somewhat the increase of the time out of service  
15 interval because of the industry has been making the point and  
16 the staff has been presented with the fact that if there is  
17 not enough time available for technicians to perform the tests  
18 and they are rushing, they are increasing the likelihood of  
19 making an error, and in the process, you know, causing a  
20 problem.

21 MR. LIPINSKI: If M/G trip causes a shutdown, you  
22 are going to do that once per refueling?

23 MR. BASDEKAS: As far as the--

24 MR. LIPINSKI: Testing.

25 MR. BASDEKAS: Not necessarily; you have this

1 option. That's one, an option, but not necessarily because as  
2 a matter of fact, after the main study was completed, we asked  
3 Daniel to take a quick look at this and we have been provided  
4 with bypass arrangements. It will be costlier, but it can be  
5 done, can test it during operation.

6 MR. LIPINSKI: How are you going to bypass--

7 MR. BASDEKAS: Put in parallel breakers and  
8 parallel--and pretty much the same way you bypass the reactor  
9 trip breakers; very comparable arrangement.

10 MR. LIPINSKI: Okay.

11 MR. BASDEKAS: But it will cost more.

12 CHAIRMAN KERR: Is that the same, roughly the same  
13 sort of breaker that was being used in the existing trip  
14 circuit?

15 MR. BASDEKAS: No. They are different. Some of  
16 them use contractors, and if there isn't a--we have not come  
17 out and said here is Option 7 and we have done this and we  
18 have given one for a long time that, it was that--would not  
19 have at least for the short time that was available to us, and  
20 this was--as a matter of fact, during the last meeting we had  
21 to run off the resolution of this issue. Somebody came from  
22 Europe and pointed out that some European plant was using  
23 this, this approach to enhance the reliability and also extend  
24 the life of the HTGs.

25 CHAIRMAN KERR: What is the current, site current of

1 the generator? Is it, it is not 600 amps?

2 MR. BASDEKAS: No. That is very small.

3 MR. WYLIE: Twenty maybe I guess.

4 CHAIRMAN KERR: It would be different?

5 MR. BASDEKAS: It is a different, all together  
6 different kind and different size.

7 CHAIRMAN KERR: Different breaker, not necessarily  
8 any more reliable, just depending on diversity here?

9 MR. BASDEKAS: That is exactly right.

10 MR. LIPINSKI: This is the GE fix to ATWS.

11 MR. BASDEKAS: Yes, sir, for recirculation pumps.

12 MR. LIPINSKI: They didn't want to interrupt the  
13 main current and they said gee, we can interrupt the field  
14 current, and that's where they stand.

15 MR. CARROLL: But in the case of Westinghouse, is  
16 this quick enough? How fast output voltage delay?

17 MR. BASDEKAS: That's one of things we have not been  
18 able to do yet. We did not go into this because we are  
19 getting--we decided to prolong the resolution of this issue  
20 and schedule, but they are not sacred, but we are getting to  
21 the point where we will be designing the system for a utility  
22 and we decided to, to look at the main pictures if you please  
23 or say shortcomings as the case may be of this particular  
24 scheme that at least one European plant has used, and bring it  
25 to the attention of our people in NRR and the industry, and we



1 thought that would be a good example of industry initiatives  
2 to do more of the nitty-gritty type of work that along the  
3 lines you are asking your questions, and to come back with a  
4 proposal to the staff and say here is what we are proposing to  
5 do.

6 MR. LIPINSKI: Westinghouse plants can withstand--  
7 so whether it is a minute or not, immediate effect.

8 MR. BASDEKAS: The time will be short, but I don't  
9 know.

10 MR. LIPINSKI: You would like it to be as fast as  
11 your system if you have got a redundant diverse system. I  
12 don't know that we are talking about having it happen in  
13 milliseconds.

14 MR. CARROLL: Well, Westinghouse plants, based on  
15 ATWS considerations, can have a delayed SCRAM, but there are  
16 other things that we consider, like damage or overpower  
17 transients that result in--

18 MR. BASDEKAS: Mr. Carroll, I think the reason that  
19 we felt, the additional reason we felt more comfortable is we  
20 received unofficial, informal information, and that's why we  
21 are not presenting this part of our resolution package, okay.  
22 It is up to--the Europeans have gone through and given, tested  
23 the system.

24 MR. WYLIE: Basically what you are recommending is  
25 diverse--let me see if, let me state what I think you are

1 recommending.

2 You are recommending a diverse system?

3 MR. BASDEKAS: No, we are not recommending.

4 MR. MINNERS: We don't use the word recommend.

5 MR. BASDEKAS: Bring it to the attention of to  
6 consider.

7 CHAIRMAN KERR: Please let Mr. Wylie finish his  
8 statement before you respond to it.

9 MR. BASDEKAS: All right, sir.

10 MR. WYLIE: It says conclusion and recommendations  
11 in your--

12 MR. CARROLL: As we have the following  
13 recommendations.

14 MR. WYLIE: I assume you are recommending it.

15 MR. KNIEL: In this slide it says further work. We  
16 neglected to cross out the recommendation in the other part.

17 MR. WYLIE: What I am--as I understand it, what you  
18 are, you are recommending is a consideration of a diverse  
19 means of removing power to the control rods by the use of  
20 existing equipment in the plant.

21 MR. BASDEKAS: With some modifications.

22 MR. WYLIE: But it is the existing equipment,  
23 breakers or contactors or whatever it happens to be, between  
24 the field circuits or output breakers or M/G sets or whatever,  
25 but there are ways of doing that also like driving the voltage

1 regulator to zero, for example.

2 MR. BASDEKAS: I'm not going to dispute there are  
3 ways.

4 MR. WYLIE: Yes, but I mean rather than prescribing  
5 a way to do it, it seems like to me you would prescribe the  
6 criteria you are trying to achieve, which is as I stated it,  
7 diverse means of removing the power from the control rods  
8 using the existing equipment as much as possible and let the  
9 applicants or the licensees come in with recommendation in  
10 which way they prefer to do it.

11 MR. BASDEKAS: Absolutely.

12 CHAIRMAN KERR: This apparently implies that either  
13 the number currently used for trip breaker reliability is  
14 inadequately large or it is too large, or else the uncertainty  
15 is too great or something. Otherwise you wouldn't need to do  
16 anything.

17 MR. BASDEKAS: Well, the--okay. I'm sorry.

18 MR. MINNERS: That is what we are proposing is to do  
19 nothing, okay, so you, I don't understand your statement. We  
20 are not proposing to do anything.

21 CHAIRMAN KERR: It says NRR--and that's not you I  
22 realize--NRR is considered decreasing the test frequency in  
23 conjunction with--

24 MR. MINNERS: Correct.

25 CHAIRMAN KERR: All right.



1 MR. MINNERS: Correct. So if people want, it is my  
2 understanding that people, licensees want to come in and  
3 increase their test interval, okay, as a compensating feature,  
4 people would say hey, put some more reliability into your  
5 system.

6 CHAIRMAN KERR: This is just for information? It  
7 says NRR is considering this?

8 MR. MINNERS: That's right.

9 CHAIRMAN KERR: Sort of an oh, by the way?

10 MR. MINNERS: That's right.

11 MR. BASDEKAS: Additional insights.

12 MR. MINNERS: That's the message we are trying to  
13 give you.

14 MR. BASDEKAS: The bottom line as far as the  
15 resolution of this issue goes, you know, we said the  
16 conclusion was that no backfit requirements are warranted, and  
17 we are away from that.

18 Now having said, that we are sharing some of the  
19 insights we have gained because we have seen documents within  
20 the Agency in the tech specs as well as the advanced reactor,  
21 light water reactor activities that these insights may have a  
22 constructive bearing on, and if it weren't, for instance, to  
23 prolong the useful life of the RTB if a utility wants to do  
24 that and they feel it is desirable to extend the test  
25 frequency in attempt for that, we have to do something else,

1 and we are saying--

2 CHAIRMAN KERR: Let's suppose that one concludes  
3 that decrease in, increase in test frequency, in testing  
4 interval, made the breakers more reliable. Would you still  
5 want to do something?

6 MR. BASDEKAS: I understand, but I think this is  
7 perhaps that--

8 MR. MINNERS: Ask NRR.

9 MR. BASDEKAS: The NRR people are in the process of  
10 developing the bulletin along these lines, and perhaps Mr.  
11 Rosa, may wish to--

12 CHAIRMAN KERR: If they are in the process, I will  
13 wait.

14 MR. BASDEKAS: It is still a pre-decisional insight  
15 type of conversation still going on.

16 CHAIRMAN KERR: It is also true I think that NRR is  
17 looking at the question of should testing and power be  
18 decreased if feasible? And I certainly think that's a wise  
19 move.

20 MR. BASDEKAS: I'm sure that's part of it.

21 MR. WYLIE: What is the test rate now on the  
22 breakers?

23 MR. BASDEKAS: It's alternating every month. Every  
24 two months a breaker is tested.

25 MR. WYLIE: It is about six times a year?

1 MR. BASDEKAS: A year.

2 MR. OAKES: Demetrius, maybe I missed it in your  
3 write-up, but have you mentioned anywhere how the Europeans  
4 make the transition from the analog signals to making the  
5 interruption of the field coils or the output of the M/G, the  
6 parallel with the current UV cards or put in?

7 MR. BASDEKAS: Undervoltage, it is my understanding  
8 that they use the same undervoltage drivers to accomplish both  
9 trips if you please in parallel.

10 MR. OAKES: If that's the case, how does this change  
11 the basic reliability problem introduced by the unreliable UV  
12 card?

13 MR. BASDEKAS: It will make up--well, well, okay.  
14 Speaking of unreliability of UV card, we are saying that it  
15 will be prudent to consider it, implementation of Option 1,  
16 namely, the installing the Westinghouse cards that will be  
17 more reliable. And secondly, the, primarily thrust of adding  
18 of this parallel trip function to the M/G set breaker, okay,  
19 is to compensate for what the expectations will be to have a  
20 decrease in the reliability of the RTBs by increasing  
21 substantially perhaps the test interval.

22 MR. OAKES: Basically it looks like a good idea to  
23 me, and I would think it would go some distance in meeting  
24 Walt's earlier comment.

25 MR. BASDEKAS: That's why we, I said wait until the



1 end and we can get down to some of the nitty-gritty  
2 discussion if necessary.

3 So basically, with this last slide, which we include  
4 our insights beyond the conclusion, which is basically the  
5 resolution of the issue of no backfit requirements; basically  
6 that's the extent of what we have done, and then some, okay.  
7 for resolving Generic issue 115.

8 This is basically the extent of the formal  
9 presentation, Dr. Kerr, and there is still some desire to hear  
10 the specifics of what we have done in analyzing common mode  
11 failures and the like for the reactor trip breakers.

12 CHAIRMAN KERR: You are going to tell me whether you  
13 looked at a common mode failure or--

14 R. BASDEKAS: Yes. Indeed I think that's the, the  
15 subject I think that is contained in a brief presentation that  
16 we asked Doctor, I meaning Mr. Reny to prepare.

17 CHAIRMAN KERR: I would certainly be interested in  
18 that. I don't know about my colleagues.

19 MR. MINNERS: Do you want to have that now?

20 CHAIRMAN KERR: If that is the only thing left, yes.

21 CHAIRMAN KERR: Let's take about a 15 minute break  
22 at this point.

23 (A brief recess was taken.)

24 CHAIRMAN KERR: Shall we continue? We lost the  
25 principle actor?

1 (There was a brief pause in the proceedings.)

2 CHAIRMAN KERR: Whenever you are ready Mr. Reny.

3 MR. RENY: Okay. The first question I think you  
4 wanted to have answers on was the reactor trip breaker  
5 reliability, and what we did with that in our analysis.

6 This is a simplified schematic of the Westinghouse  
7 system. There are two trip breakers that do the job. Each  
8 breaker has an undervoltage device, and the shunt trip device  
9 to actuate them. These devices work quite differently. The  
10 undervoltage device is a mechanical spring loaded type of  
11 device which is held back with a solenoid type of latch such  
12 that the 48 volts trip signal here is holding this device  
13 open, and when the signal is removed, the latch releases and  
14 the spring force causes the breaker to trip.

15 The shunt trip is different in the fact that it's a  
16 solenoid actuated device where 125 volts is applied through a  
17 relay which causes the shunt trip to actuate and trip the  
18 reactor.

19 The relay that actuates the shunt trip device is  
20 powered off of the undervoltage driver cards, the same 48  
21 volts signal that supplies power to the undervoltage device.

22 (Slide)

23 MR. RENY: We took a look at the data and we took a  
24 look at it for the three devices--the undervoltage trip device  
25 on the breaker, the shunt trip device, and the actual

1 remaining parts of the breaker, the mechanical actuation  
2 devices.

3 The NUREG 1000 study from the Salem events has 26  
4 failures to open on demand and 6,000 estimated demands for the  
5 undervoltage trip device.

6 Now this was actually the entire reactor trip  
7 breaker failure data for Westinghouse because the undervoltage  
8 trip device at that time was the only device actuating the  
9 breaker, and all the failures were attributed to that device.

10 After the Salem ATWS events, we collected NPRDS data  
11 from 1984 through 1987 and we were able to find eight more  
12 events in approximately 4,000 estimated demands of  
13 undervoltage device failures. Now these were, were actual  
14 undervoltage device failures, but were not necessarily reactor  
15 trip breaker failures because of the fact that the shunt trip  
16 may or may not have been available during these breakers to  
17 actuate.

18 So if we combine these two sets of data, prior to  
19 1983, and then '84 to '87, we come up with an undervoltage  
20 device failure rate here of 3.4 times ten to the minus 3.  
21 Rather now we took a look at shunt trip devices and prior to  
22 the Salem, event there was not any recorded history on shunt  
23 trip devices because they were not considered safety devices  
24 and information was not reported.

25 We did collect it for the same time period that we



1 did for the UV device, from '84 to '87, and we found two  
2 failures and 4,000 demands, and associated failure rates. We  
3 collected other types of reactor trip breakers not associated  
4 with the UV device or the shunt trip device, and found an  
5 additional two failures in 4,000 demands that prevented the  
6 breaker from operating, and so we have a failure rate for  
7 that.

8 MR. CARROLL: How would those failure rates change  
9 as a result of the improved testing and maintenance that has  
10 gone on in the industry since the time of the Salem event?

11 MR. RENY: Well, in the undervoltage trip device,  
12 which was what most of the direction of the testing and  
13 maintenance was geared for, was for preventing that failure,  
14 we see a slight improvement in reliability at that particular  
15 device.

16 As far as the shunt trip or mechanical components,  
17 we have nothing to, no previous history really to base that on  
18 except for the fact that undervoltage trip device was by far  
19 the dominant and probably the only failure mode from breakers  
20 such that it failed so often that maybe it masked other types  
21 of failures the breaker might have had if it was able to  
22 operate longer, and we see some mechanical failures down here  
23 which were not present in data previous to '83.

24 MR. LIPINSKI: What were those mechanical failures?

25 MR. RENY: The McGuire event, which was a shaft weld

1 failure which caused mechanical binding of the shaft, it was  
2 an event where both the undervoltage and shunt trip devices  
3 worked, but the shaft bound up and it never tripped.

4 MR. LIPINSKI: And the other one?

5 MR. RENY: The other one was a problem with a, a  
6 contactor in the trip breaker itself such that when the  
7 breaker is pushed into the cubicle, it makes contact with all  
8 of its electrical signals such that it tells the operators  
9 that everything is go, that it is sitting in position and it  
10 should work correctly, whereas in fact there was a mechanical  
11 failure in there with one of the, one of the contacts which  
12 prevented the breaker from operating, and was not shown up  
13 anywhere until they actually had a demand and the breaker  
14 didn't work, so this was another type of mechanical failure,  
15 but actually not due to the binding or the actual operating  
16 mechanism, but due to the breaker itself.

17 MR. LIPINSKI: How frequently are these breakers  
18 reacting?

19 MR. RENY: Quite frequently. There are 280 some odd  
20 maintenance reports or events in NPRDS which have to do with  
21 reactor trip breakers for all PWR plants over a three or  
22 four-year period, so any--and that's what has been reported,  
23 so each one of those actions means that breakers react in or  
24 out, worked on one way or another.

25 MR. LIPINSKI: The event you have observed here

1 could be repeated as these breakers age?

2 MR. RENY: Definitely.

3 MR. WYLIE: Which event are you talking about?

4 MR. LIPINSKI: Business of racking it out, not  
5 having the contacts meet up after it is racked back into--

6 CHAIRMAN KERR: That turned out to be a mistake in  
7 construction as I remember, isn't that correct?

8 MR. RENY: I believe there was a QA problem with the  
9 breaker.

10 MR. WYLIE: You are talking about the two at  
11 McGuire?

12 MR. LIPINSKI: I am talking about the last one he  
13 talked about, racked back in and it didn't make up--.

14 MR. WYLIE: I don't know about that.

15 CHAIRMAN KERR: The same one I saw; it turned out  
16 that they built something onto the enclosure that they weren't  
17 supposed to have built and it was interfering with the breaker  
18 activity, and that was corrected.

19 MR. LIPINSKI: It is not a question of a routine  
20 activity that says do this often enough and you can expect to  
21 see this again?

22 CHAIRMAN KERR: If you are thinking of the same one  
23 I am--I think that's the case.

24 MR. LIPINSKI: If it was a design deficiency, then  
25 it was corrected, that's one thing, but if we are seeing an



1 event that occurs from racking inn and out, you can see it  
2 occur again in the future.

3 MR. WYLIE: Also the McGuire event as I recall was a  
4 quality control problem in the manufacturing of the breakers  
5 originally, wasn't it, where the shaft was out of round and  
6 caused a binding of the breaker? That was my recollection.

7 CHAIRMAN KERR: I'm sure you are right. I don't  
8 know whether you can avoid those or not.

9 MR. WYLIE: Well, yes. Well, well, as I recall the  
10 history of the thing, Westinghouse had switched their breaker  
11 manufacturing operation from Pittsburgh to Puerto Rico. They  
12 had a new factory start up. QA, QC was not that good, and  
13 they shipped a lot of breakers that had that problem that were  
14 poorly manufactured, and then when they ran into the problem,  
15 they then improved all of that, and they are now manufactured  
16 back at Pittsburgh on one of the reactor trip breakers that I  
17 think has taken care of that problem.

18 MR. BASDEKAS: It was a weld problem I think that  
19 caused--

20 MR. WYLIE: The ones I saw was the shafts that were  
21 out of round and somebody had taken a file to it, that kind of  
22 thing.

23 MR. RENY: To continue, so we took the data that we  
24 found and plugged it into our model.

25 (Slide)

1           MR. RENY: Our model currently shows the  
2           undervoltage trip coil and shunt trip coil in parallel such  
3           that either of the devices can actuate a breaker, and then the  
4           mechanical components in series there, these are the failures  
5           that regardless of the actuation mechanism, still cause  
6           failure of the breaker.

7           And we see here we have independent cut sets which  
8           are very small, which is current, which is consistent with the  
9           redundant model. We have common cause failure cut sets and  
10          the dominant one here being between the mechanical components,  
11          common cause failure of McGuire type event or the other type  
12          of event, here one times ten to the minus 5th; prior to  
13          Generic Letter 83-28, we only had the undervoltage trip coils  
14          actuating here on an automatic signal. The shunt trip was  
15          only actuated on a manual signal, so in that situation the  
16          undervoltage coils then were the dominant common cause  
17          failure.

18          Now with the shunt trip diversity in there, they are  
19          not the common cause dominant failure. The mechanical  
20          components are, and our model shows that because you need a  
21          common cause failure of both shunt trip devices and UV coil  
22          devices to have system failure now; the component failure data  
23          here from the previous chart, beta factors that were used for  
24          common cause failure.

25          MR. LIPINSKI: Where did you get the beta factors?

1           MR. RENY: The beta factors came primarily from the  
2           ATWS rulemaking analysis SECY document. I can't recall the  
3           number, and current PRAs, Seabrook being the latest one that  
4           had Westinghouse reactor trip breaker component failure  
5           history with a beta factor.

6           MR. LIPINSKI: Where is the justifications for the  
7           two others? You are saying you are lifting it from another  
8           report?

9           MR. RENY: There is no justification besides the  
10          fact that that was what was derived and used in the ATWS  
11          rulemaking.

12          MR. MINNERS: Have we ever had a common cause  
13          mechanical failure of breakers?

14          MR. RENY: No.

15          MR. MINNERS: We have had what, sir? We have had  
16          6,000 operations?

17          MR. RENY: Ten thousand or more.

18          MR. MINNERS: Ten thousand operations?

19          MR. WYLIE: You know, Warren, that's a good  
20          question. But going back to the McGuire event now, the McGuire  
21          event was reported because the plant was starting up and then  
22          operational.

23          Now after that event, and they shipped some of those  
24          things back to Pittsburgh, they found the same thing on a lot  
25          of breakers and they corrected it, but they didn't get into



1 NPRDS because it wasn't in an operating plant, so I mean the  
2 potential is there, but that again is due to the manufacturing  
3 quality control, which--

4 MR. MINNERS: But they did catch it before they went  
5 into the plant.

6 MR. WYLIE: Well, it was during the investigation of  
7 the problem at McGuire that they looked at other breakers that  
8 they had on site and shipped them back up to Pittsburgh, they  
9 found the same thing, so the potential for common cause  
10 failure was there.

11 MR. CARROLL: This is other DB 50s that weren't  
12 used.

13 MR. WYLIE: Breakers at McGuire and Catawba hadn't  
14 been used yet.

15 MR. CARROLL: They were spares for reactor trip  
16 breakers?

17 MR. WYLIE: You have got two units. One unit  
18 started up and the other unit was sitting there.

19 MR. MINNERS: GE wasn't as lucky when they shifted  
20 their operation to Puerto Rico, and glued their breakers  
21 together on Monticello, you know, they had a, well, that plant  
22 hadn't started up, either. That was during testing, but  
23 that's what operating experience means. I mean however you  
24 catch it, that gets it included in operating experience.  
25 Agreed the potential is there, but there are already a lot of

1 other controls and things going on and operating experience  
2 that just people--

3 CHAIRMAN KERR: And the potential doesn't count.

4 MR. MINNERS: No, I wouldn't say it doesn't count.

5 CHAIRMAN KERR: It doesn't count in beta. Potential  
6 doesn't.

7 MR. MINNERS: If it didn't count, we wouldn't have  
8 .02 here.

9 CHAIRMAN KERR: But that is not from beta.

10 MR. MINNERS: Correct.

11 MR. WYLIE: I think the point here, though, is that  
12 you found two failures out of so many from NPRDS, but the  
13 thing it didn't show was the number of failures that that same  
14 family of breakers had that they caught because of that  
15 failure that they did catch in operation.

16 MR. BASDEKAS: NPRDS were not the only source of  
17 data. We had the same for bulletins going out and this was  
18 another source of information that was going to these people  
19 to make sure that we are catching all relevant information as  
20 far as operations go.

21 MR. WYLIE: But I suspect in your data base is not  
22 the failures they caught when they were doing the testing of  
23 these Pittsburghs, that they didn't report them.

24 MR. BASDEKAS: That is correct. For those, that is  
25 correct.

1 CHAIRMAN KERR: Why don't you continue, Mr. Reny? I  
2 think we need a complete session some day on beta factors.

3 MR. RENY: The current method of deriving beta  
4 factors is somewhat uncertain. It is based on the potential  
5 for common cause, and that potential can be taken from a  
6 review of operating history failures.

7 For example, in the undervoltage trip device, we  
8 have a large number of failures, 30 or 40 different failures  
9 to look at, and we do have a common cause failure of the Salem  
10 events. That's a fairly high number. We have other types of  
11 devices like the shunt trip and the mechanical components,  
12 breakers that have very few failures to look at, one or two or  
13 so failures, and the potential has to be derived from looking  
14 at that experience here.

15 The current industry accepted method, though, has  
16 been to put some type of potential on there for a conservative  
17 appraisal or estimation of what the common cause contribution  
18 could be.

19 MR. DAVIS: I would like to say a couple of words  
20 about that. One of the numbers that gets used for beta  
21 factors frequently is .1, and that in fact was used in the  
22 Seabrook PRA as their generic beta factor.

23 Now they at the same time used different numbers  
24 where they had good data or where they thought they had good  
25 data, but their data base was developed by Lowe and Garrick



1 and it's proprietary so I don't know that anyone has been able  
2 to really see it.

3 MR. RENY: I could shed some light on that. That .1  
4 was derived as an average of the beta factors scaled for  
5 mainly mechanical components used in a typical BWR PRA, and  
6 the dominant contributors to that beta factor were high  
7 pressure injection pumps, RHR pumps, reactor trip breakers,  
8 and mechanical components of that type, so in my view, in this  
9 analysis, the .1 was not applicable to electrical components  
10 as such here, but more applicable to large mechanical  
11 components, somewhat applicable to electro-mechanical  
12 components.

13 MR. DAVIS: Well, my only point was there is a  
14 reasonable base to argue for a .1. On the other hand, I'm not  
15 disagreeing that .02 is also reasonable.

16 Did you examine in your uncertainty analysis a range  
17 of beta factors?

18 MR. RENY: Yes.

19 MR. DAVIS: What was that range?

20 MR. RENY: We looked at a range I believe that went  
21 from .1 I believe at the top end to .005 at the low end.

22 MR. DAVIS: Thank you.

23 MR. RENY: I'm not exactly sure. I would have to  
24 refer back to the report.

25 MR. DAVIS: That would be a reasonable range.

1 CHAIRMAN KERR: Please continue.

2 MR. RENY: Well, basically that was now we modeled.  
3 The conclusion out of this was that prior to Generic Letter  
4 83-28, the dominant failure mode was the undervoltage trip  
5 device. A single RTB had a failure rate in the order of four  
6 times ten to the minus 3. This number here for single RTB  
7 prior to Generic Letter 83-28 was reported as five times ten  
8 to the minus 3, and the ATWS study and the Salem study was on  
9 the order of 4.6 or 7 times ten to the minus 3 and the  
10 Seabrook PRA, so four to five times ten to the minus 3 is  
11 about the range for an undervoltage trip device.

12 With that the only device actuating the breaker, we  
13 had a high common cause of failure of the system due to both  
14 RTB failing due to the undervoltage trip device. After  
15 Generic Letter 83-28, the mechanical bind in the shaft  
16 mechanism and other types of failures dominate the failure  
17 mode. The single RTB failure rate now has increased by order  
18 of magnitude. By adding the automatic shunt trip device, the  
19 common cause failure of both RTBs is now in the order of ten  
20 to the minus 5th rather than ten to the minus 4th.

21 MR. LIPINSKI: Were they both used with the .02?

22 MR. RENY: This one was used with undervoltage trip  
23 device beta factor, and this one was used with the mechanical  
24 device beta factor, so this one has the .02 and this one has  
25 the .145.

1 MR. LIPINSKI: But in the top one, you also had to  
2 include a common cause for the trip breakers, too, in order to  
3 do your analysis dominated by the other one I assume .02 then,  
4 and then swamped by the undervoltage.

5 MR. RENY: That is correct. That would be included  
6 in here except for prior to Generic Letter 83-28 that  
7 mechanical failure mode was not exhibited.

8 CHAIRMAN KERR: Now if you take off your PRA hat and  
9 put on your, some other hat, you really believe that ten to  
10 the minus 5?

11 MR. RENY: Pardon me?

12 CHAIRMAN KERR: Do you believe that ten to the minus  
13 5?

14 MR. RENY: Ten to the minus 5?

15 CHAIRMAN KERR: Yes.

16 MR. RENY: Current state of the knowledge, yes.  
17 With the automatic shunt trip device, what I believe is the  
18 relative difference between the numbers and not the absolute  
19 value. If you believe that the undervoltage trip device in  
20 the breaker prior to the automatic shunt trip device was this  
21 number, then I believe that after the automatic shunt trip  
22 device, it is this number.

23 MR. LIPINSKI: That says you have gotten rid of  
24 everything and you are just left with the mechanics.

25 MR. RENY: Basically, yes.



1                   CHAIRMAN KERR: The reason I asked is because we  
2 demand quite a lot of these trip systems. We demand that they  
3 be more reliable than any other system in the reactor by at  
4 least an order of magnitude, and yet you tell me you are  
5 unwilling to comment on what you think the absolute number is  
6 or that's the number you used to arrive at these conclusions.

7                   I am not being critical of you. I am simply saying  
8 that number sticks out it seems to me if you look at risk  
9 contributors to the reactor operations, not that it is  
10 necessarily wrong, but it places a very high reliability on a  
11 fairly important system, much higher than any other important  
12 system I know of.

13                  MR. RENY: I agree, and there is some uncertainty  
14 included within all of these numbers. These are the point  
15 estimate numbers of which there are uncertainty bounds.

16                  CHAIRMAN KERR: And I say this in context which I  
17 believe that something could be done about this in the next  
18 generation of reactors. I think you can design them so you  
19 don't have to depend on this system, but that's a side issue  
20 to this discussion.

21                  MR. LIPINSKI: Take the mechanistic approach,  
22 failure of the single active component, calculate what you  
23 have left, it would be single breaker, forgetting about  
24 reliability.

25                  CHAIRMAN KERR: I would hope that we abandon the

1 single--okay.

2 Continue, please.

3 MR. RENY: Well, this was all I had to present on  
4 reactor trip breakers.

5 CHAIRMAN KERR: That's interesting. I'm glad to see  
6 what is there. I asked if somebody would comment on whether  
7 we looked at what I call at least the common mode failure such  
8 as overtemperature in these solid state devices causing the  
9 failure of air conditioning systems.

10 MR. RENY: We applied a beta factor for common cause  
11 failure across the logic components, and within the  
12 application of that beta factor would be included common cause  
13 effects such as common air conditioning failures and other  
14 type of environmental impacts.

15 A beta factor for a common cause includes all of the  
16 postulated common effects that could affect both of those  
17 components, so within that application, yes, the beta factor  
18 does account for possible environmental conditions affecting  
19 common cause failure, both logic components.

20 CHAIRMAN KERR: I assume you would give me the same  
21 answer if I asked you lightning and electrical surges?

22 MR. RENY: That is correct.

23 CHAIRMAN KERR: You wouldn't feel good about that  
24 answer, though, would you?

25 MR. RENY: No. A beta factor is a catchall.

1           CHAIRMAN KERR: Has there been any serious work on  
2     the affect of lightning on some of the solid state components  
3     generally, not restricted to this? I ask out of ignorance.  
4     Has the staff--

5           MR. ROSA: This is Faust Rosa again.

6           CHAIRMAN KERR: I don't mean lightning direct  
7     strikes, but lightninginduced transients.

8           MR. ROSA: The best study we have is the EMP study,  
9     and that indicated that lightning, well, that lightning that  
10    strikes out in the switch yard or on the distribution system  
11    from a switch yard to the first transformer is less severe  
12    from the standpoint of the transient input into the plant than  
13    an EMP pulse, and therefore, the EMP study indicated that we  
14    had nothing to fear from the EMP transmitted into the plant on  
15    the power system.

16           Now those failures of instrumentation channels that  
17    have occurred due to lightning strikes were primarily due to  
18    strikes on a containment building which somehow or other  
19    reached the penetration areas and directly impinged on the  
20    circuits in those instruments.

21           CHAIRMAN KERR: So they don't count?

22           MR. ROSA: They count yes, sir, but every time it  
23    happens, the licensees are required to upgrade their lightning  
24    protection system on that particular building, and that's it.

25           MR. RENY: I might add that the logic channels are



1 isolated from the analog instrumentation such that that pulse  
2 could not be propagated through.

3 CHAIRMAN KERR: It is the position of the staff then  
4 that the solid state circuitry, generally solid state  
5 components are no more vulnerable to lightning-induced pulses,  
6 analog instrumentation or whatever?

7 MR. ROSA: Given the surge protection devices that  
8 are in series with the power circuits yes.

9 CHAIRMAN KERR: Are there further questions?

10 MR. CARROLL: What has been the utilities'  
11 experience in using solid state transmission protection  
12 devices as far as lightning is concerned?

13 Has that been generally favorable, or has that been  
14 looked at in terms of lightning?

15 MR. BASDEKAS: I don't believe we have an answer for  
16 that, Mr. Carroll, but we will try to get you one.

17 As Mr. Rosa outlined earlier, there is, there are  
18 requirements for such protection throughout the plant. I do  
19 recall there were some operational experiences involved in the  
20 use of walkies-talkies in control room proximity, and those  
21 problems were resolved many years ago as part of the FFTF  
22 start-up experience in other plants I'm sure, but nonetheless,  
23 I think these are very good, you know, technical problems to  
24 work on, but as far as the scope of this particular issue, as  
25 I was careful to point out at the beginning, it was rather

1 limited to address 70 percent that stemmed from the Salem  
2 events and subsequent operational experience with the drivers,  
3 but nonetheless, your concern is well taken.

4 CHAIRMAN KERR: Further questions?

5 MR. CARROLL: Just for my edification Bill--I don't  
6 know if others want to hear it or not, but I guess I would  
7 like to understand a little better the situation on the  
8 Combustion and B&W plants, just for background purposes.

9 CHAIRMAN KERR: Insofar as the solid state device is  
10 concerned? They don't use them, do they?

11 MR. BASDEKAS: I'm sure they use them, yes.

12 MR. WYLIE: I think B&W originally used extensive  
13 solid state logic in the protection systems.

14 CHAIRMAN KERR: Did they use this kind of card?

15 MR. WYLIE: I don't know about this specific card.

16 CHAIRMAN KERR: This is a rather specialized--

17 MR. BASDEKAS: Westinghouse plants specifically I  
18 think; as far as Westinghouse plants go, but to the best of my  
19 knowledge--

20 MR. CARROLL: You are happy with what both  
21 Combustion and B&W have in their circuitries similar to this?

22 MR. BASDEKAS: No, we are not saying that, Mr.  
23 Carroll. Personally I cannot voice an opinion on the relative  
24 merits of other designs. Perhaps someone else here might shed  
25 some light, but this issue was oriented specifically toward

1 Westinghouse plants.

2 MR. DAVIS: I think the other designs with, by ATWS  
3 rule to have a diverse mechanism--

4 MR. BASDEKAS: For installing a totally diverse  
5 parallel system and that will take away a lot of the--

6 MR. DAVIS: Westinghouse was exempted from that  
7 requirement on the basis of--

8 MR. BASDEKAS: Yes.

9 MR. CARROLL: Exempted on the basis?

10 MR. DAVIS: On the basis of their enhancability to  
11 ride through it like a SCRAM and installation of the automatic  
12 feedwater--

13 MR. BASDEKAS: And turbine trip.

14 MR. WYLIE: B&W plants originally had a driver trip  
15 system as their original design.

16 MR. ROSA: That's right.

17 MR. LIPINSKI: The Combustion Engineering plant at  
18 Arkansas has the protection system and it is very similar and  
19 the equipment was in the same room, had an air conditioner  
20 oversize link, were getting spurious trips.

21 MR. BASDEKAS: Some events as recent as last month  
22 or so continue to exist for that type of system.

23 CHAIRMAN KERR: Further questions or comments? Mr.  
24 Reny, did I understand correctly that the staff did look at  
25 the possibility of replacing or that you did perhaps, the



1 undervoltage coil and another shunt coil and have concluded  
2 that because of common mode failures, that that would actually  
3 decrease reliability?

4 MR. RENY: That is correct, and I wanted to address  
5 that. The model for that option looked like this except there  
6 was a shunt trip here and a shunt trip here, double redundant  
7 shunt trip devices on each breaker.

8 Now if you follow the beta factor methodology, you  
9 would have to assume a common cause failure mode between those  
10 four shunt trip devices where, whereas with an undervoltage  
11 and a shunt trip coil those devices, being diverse, you would  
12 assume no common cause failure modes between those two.  
13 Therefore, the assumption of the common cause failure mode  
14 between like devices there would have an additional  
15 contribution to common cause failure over here, which made it  
16 a slight increase in unreliability.

17 CHAIRMAN KERR: I just wanted to to make sure I  
18 understood the conclusion and the basis for it.

19 MR. MINNERS: Do you use the .145?

20 MR. RENY: For shunt trip? We used the .065 for  
21 shunt trip. However, that number was used for the likelihood  
22 of failure of two shunt trips. We used the number slightly  
23 smaller by a factor of ten for the likelihood of failure of  
24 three or more, four shunt trip devices, so it followed what is  
25 called the multiple Greek letter method, which is an extension

1 of beta factor to higher redundancy systems.

2 CHAIRMAN KERR: Suppose instead of using it to  
3 control the reactor, you were using it say to control your  
4 furnace at home? Which of these two systems would you refer?  
5 The one with four shunt trips, or one with two undervoltage  
6 trips and two shunt trips?

7 MR. RENY: I would prefer the diverse system, this  
8 one undervoltage and shunt.

9 CHAIRMAN KERR: You are consistent anyway.

10 MR. RENY: I think the diversity has a lot of merit  
11 as far as preventing common cause failure, failure mechanisms,  
12 and at this point in time, that seems to be the extent of the  
13 defense for common cause is its diversity.

14 CHAIRMAN KERR: I agree with you wholeheartedly.  
15 The diversity can prevent certain kinds of common cause  
16 failures, but my objective is reliability rather than  
17 diversity, and I'm not sure that they increase the  
18 reliability, but maybe it does.

19 Any further questions? Well, that concludes the  
20 staff's presentation. I want some comments from some of you,  
21 but I'm sorry that we took up most of Mr. Kniel's and his  
22 colleagues this afternoon, but it has at least been  
23 educational for us, and perhaps we have a better understanding  
24 of the logic.

25 Personally I have no quarrel with the decision that

1 was reached on this rather narrowly defined generic issue on  
2 the basis of what occurred, but--and I think that's enough  
3 recording. Thank you ma'am.

4 MR. WYLIE: Someone mentioned that the staff was  
5 prepared to tell us something about the recommendation  
6 regarding some testing of the reactor trip breakers?  
7 Somebody? Anybody in Research or something?

8 MR. ROSA: We had a research review group meeting  
9 last, two weeks ago during which part of the--well, on aging.  
10 It was a three-day meeting, and one of the presentations  
11 described the life testing that was being performed on some  
12 SCRAM breakers. They were Westinghouse DS type breakers. I  
13 forget exactly what the number, but that's intended to, to  
14 arrive at a, at a life test based on how many cycles the  
15 breakers can withstand, given periodic mechanical maintenance.  
16 That test will not, will not take into account the  
17 undervoltage trip attachment or the shunt trip attachment  
18 reliability.

19 MR. WYLIE: What is the purpose of the test?

20 MR. ROSA: Just to arrive at a, a number of life  
21 cycles for the mechanical portions of the breaker.

22 MR. CARROLL: So you are simulating the actual  
23 surveillance test on the breaker where you are not  
24 interrupting current?

25 MR. ROSA: That's essentially it, yes. Current



1 interruption capability has never been a problem on reactor  
2 trip breakers to my knowledge.

3 MR. WYLIE: These breakers.

4 MR. ROSA: The actual contact.

5 MR. WYLIE: It is a very large breaker current-wise.  
6 As I recall, 1200 amps, something like that; only seeing what,  
7 less than six I guess?

8 MR. ROSA: Yes.

9 MR. LIPINSKI: Is this a single breaker?

10 MR. ROSA: I believe they are testing three  
11 breakers, two or three types.

12 MR. LIPINSKI: And they came out of the shop, the  
13 best QA?

14 MR. BASDEKAS: No, no. They had some already for  
15 their own use at laboratory and pulled them out, spares or  
16 whatever, and tested them and DB 50s DS 3416s and otherwise.

17 MR. LIPINSKI: Random sample; it is not the best.

18 MR. WYLIE: It is interesting they are testing only  
19 the breakers itself rather than undervoltage device which has  
20 been really the culprit.

21 MR. ROSA: Well, I believe it is considered that the  
22 undervoltage device unreliability has been pretty well  
23 established.

24 MR. WYLIE: I don't know whether it has with age or  
25 not. It may get better with age. I don't know.

1 MR. CARROLL: Make it smarter in terms of--

2 MR. LIPINSKI: Whether they are physically tripping  
3 the breaker; they have got to get in there somehow.

4 MR. POSA: I believe they have rigged up some sort  
5 of electro-mechanical trip device; probably just a shunt trip.

6 MR. LIPINSKI: Something special; isn't normal  
7 tripping.

8 MR. WYLIE: They were using the shunt trip. That  
9 ought to give you some better indication of the reliability of  
10 the shunt trip, which I would suspect is much better than the  
11 numbers we have seen here frankly because when this problem  
12 came up with the reactor trip breakers, I had never heard of  
13 these type of breakers ever failing to trip.

14 MR. ROSA: The age research program is rather  
15 extensive. Each element of it is going to produce a separate  
16 NUREG report so we will have all of that data when they get  
17 finished.

18 MR. CARROLL: DB 50s have a bad name in fossil  
19 plants.

20 MR. WYLIE: I guess depending how they maintain--

21 MR. OAKES: What is the environment?

22 MR. ROSA: Oh, probably just a shop environment. I  
23 don't know any of the details. They do intend to perform the  
24 periodic maintenance that they expect a good utility would  
25 perform while they are doing this.

1 MR. CARROLL: How do you define that? We are going  
2 to talk about the maintenance rule tomorrow.

3 MR. ROSA: I don't know. We will have to wait for  
4 that research report.

5 MR. OAKES: What is the definition of a failure?  
6 The time response becomes too long, or has that been  
7 established?

8 MR. ROSA: The presentation did cover that. I would  
9 expect just an immediate opening would be all that's required.  
10 You don't expect any, any delay in the actuation. It is like  
11 you get with the undervoltage trip attachment when it gets  
12 hung up. I couldn't give you the details on that.

13 MR. OAKES: Are they expecting to do any incipient  
14 failure diagnosis on the test?

15 MR. ROSA: I don't know. The periodic examinations  
16 that will be conducted during the maintenance periods during  
17 the tests will look for incipient failures like cracking welds  
18 or cracked welds or things that nature.

19 MR. WYLIE: While we are talking about breakers, I  
20 talked to the maintenance people at Oconee and they had  
21 problems with those. Now those are GEA 25 breakers, which is  
22 smaller breakers than these DB 50s, but they had considerable  
23 problems with them, and their problem was just the breaker  
24 itself. The frame was not substantial enough. When you took  
25 it out and you calibrated it on the test bed, that would test



1 perfectly. Then you put it back into the breaker rack, it  
2 would just warp enough it would change the setting, and they  
3 had--I don't know whether they still have a problem. They had  
4 extensive problems with those breakers because of that.

5 MR. ROSA: I might add one other bit of information.  
6 You know, NRR contacted Westinghouse management some months  
7 ago about QA problems in their, in their breaker manufacturing  
8 facilities, and Westinghouse came in and made a presentation  
9 and they described how breakers coming off the, their regular  
10 production line in Puerto Rico or wherever before being sold  
11 to a nuclear utility for application in the safety-related  
12 circuit go through a special inspection and test at  
13 Westinghouse right on the outskirts of Pittsburgh, so to that  
14 extent, that QA problems for safety-related breakers are being  
15 corrected by Westinghouse.

16 MR. CARROLL: There is a potential gap in all of  
17 that. Does the utility industry know that there are two kinds  
18 of DB 50s? The one that has got special nuclear treatment and  
19 the ones that they might have bought for a fossil plant and  
20 have urgent need at a nuclear plant and said a DB 50 is a DB  
21 50?

22 MR. WYLIE: That has an N stamp on it.

23 MR. CARROLL: Not necessarily from what he  
24 described.

25 MR. MINNERS: I don't think that--

1 CHAIRMAN KERR: Any further questions relating to  
2 the issue at hand?

3 We have scheduled an hour for discussion of this  
4 issue at the Full Committee meeting. Do we need to ask the  
5 staff for a presentation or can the Subcommittee handle the  
6 discussion?

7 MR. WYLIE: I would recommend the staff might have a  
8 presentation, 45 minutes or whatever.

9 CHAIRMAN KERR: Is the staff willing to do that?  
10 Okay. I think with not a great deal of condensation if those  
11 present today will keep quiet at the Full Committee meeting,  
12 you can cover most of the material that you covered in your  
13 presentation. I can't promise that they will.

14 MR. CARROLL: I wish Lewis had been here before you  
15 made that assessment.

16 CHAIRMAN KERR: Lewis will have different questions.  
17 They won't be the ones that they raised today. Do we need to  
18 cover anything else? Okay.

19 MR. BASDEKAS: For the purchase of the presentation  
20 to the Full Committee meeting, you normally allow 50 percent  
21 of the time for questions and discussion and 50 percent of the  
22 time for presentation.

23 Would it be then appropriate to gauge say half an  
24 hour presentation and half an hour discussion or thereabouts?

25 CHAIRMAN KERR: I would say about 35 minutes of

1 presentation, and hope.

2 MR. BASDEKAS: We may have to condense some of the  
3 slides that we have.

4 CHAIRMAN KERR: I think so.

5 MR. BASDEKAS: Thanks.

6 CHAIRMAN KERR: Again, we thank you for coming, and  
7 for the presentation.

8 MR. BASDEKAS: Thank you.

9 CHAIRMAN KERR: No more recording.

10 (Whereupon, at 3:30 p.m., the recorded portion of  
11 the meeting was adjourned.)

12

13

14

15

16

17

18

19

20

21

22

23

24

25



CERTIFICATE

This is to certify that the attached proceedings before the  
United States Nuclear Regulatory Commission in the matter  
of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

Name: SUBCOMMITTEE ON INSTRUMENTATION AND CONTROL SYSTEMS

Docket Number:

Place: Bethesda, Maryland

Date: April 5, 1989

were held as herein appears, and that this is the original  
transcript thereof for the file of the United States Nuclear  
Regulatory Commission taken stenographically by me and,  
thereafter reduced to typewriting by me or under the  
direction of the court reporting company, and that the  
transcript is a true and accurate record of the foregoing  
proceedings.

*1s/ Catherine S. Boyd*

(Signature typed):

CATHERINE S. BOYD

Official Reporter

Heritage Reporting Corporation

**A PRESENTATION TO THE SUBCOMMITTEE  
ON INSTRUMENTATION AND CONTROL SYSTEMS  
ADVISORY COMMITTEE ON  
REACTOR SAFEGUARDS**

**ON  
THE PROPOSED RESOLUTION OF GENERIC ISSUE 115  
ENHANCEMENT OF THE RELIABILITY OF  
THE WESTINGHOUSE SOLID STATE PROTECTION SYSTEM  
APRIL 5, 1989**

**BY  
DEMETRIOS L. BASDEKAS  
REACTOR AND PLANT SYSTEM BRANCH  
DIVISION OF SAFETY ISSUE RESOLUTION  
OFFICE OF NUCLEAR REGULATORY RESEARCH**

# **GENERIC ISSUE 115 DESCRIPTION**

## **BACKGROUND**

- SALEM ATWS EVENTS AND GENERIC LETTER 83-28
- SHUNT TRIP COIL GIVEN AUTOMATIC TRIP SIGNAL
- UV DRIVER CARDS IN W SHOW PROBLEM
- NRC STAFF AND W RECOMMEND IMPROVEMENTS

## **OBJECTIVE**

- EVALUATION OF CERTAIN OPTIONS TO ENHANCE THE RELIABILITY OF THE W SOLID STATE PROTECTION SYSTEM (SSPS) AND THEIR POTENTIAL FOR RISK REDUCTION



## OPTIONS EVALUATED

<u>OPTION NO.</u>	<u>DESCRIPTION</u>
1	UV DRIVER CARD MODIFICATION RECOMMENDED BY WESTINGHOUSE
2	DIVERSE UNDERVOLTAGE DRIVER
3	DIVERSE RTB ACTUATION MECHANISM
4	DIVERSE SSPS TRIP LOGIC AND UV TRIP FUNCTION
5	DUAL SHUNT TRIP ACTUATION FOR EACH RTB (REPLACING UV COIL)
6	REPLACEMENT OF ONE RTB WITH A CONTACTOR

## **BASIC APPROACH**


- **COST/BENEFIT METHODOLOGY**
- **REACTOR TRIP RELIABILITY (BASE CASE AND OPTIONS)**
- **CONSEQUENCE ANALYSIS**
- **COST ANALYSIS**
- **UNCERTAINTY AND SENSITIVITY ANALYSIS**
- **DIVISION RATIONALE/RECOMMENDATIONS**

## **REACTOR TRIP RELIABILITY**


- **EVALUATED BASE CASE AND 6 OPTIONS**
- **BASE CASE CONFIGURATION INCLUDES  
AUTOMATIC SHUNT TRIP**
- **ASSUMED ALL ELECTRIC POWER  
SOURCES ARE AVAILABLE**
- **ASSUMED CONTROL ROD INSERTION IS  
SUCCESSFUL (NO FAILURE  
CONTRIBUTION) IF REACTOR TRIP IS  
INITIATED**



# REACTOR TRIP RELIABILITY BLOCK DIAGRAM



# BASE CASE REACTOR TRIP UNRELIABILITY RESULTS WITH OPERATOR ACTION



CCF= COMMON CAUSE FAILURE

# REACTOR TRIP UNRELIABILITY RESULTS

- CALCULATED RELIABILITY WITH AND WITHOUT  
OPERATOR ACTION (FAILURES PER DEMAND)

- BASE CASE CONTRIBUTORS

- COMMON CAUSE FAILURES (CCFs)

- ANALOG INSTRUMENTATION CHANNELS

- UNIVERSAL LOGIC CARDS

- REACTOR TRIP BREAKERS

- UNDERVOLTAGE DRIVER CARDS

- INPUT RELAYS

- ALL OTHER FAILURES

	WITHOUT OPERATOR ACTION	WITH OPERATOR ACTION
	1.0E-5	1.0E-5
	1.0E-5	7.3E-7
	1.0E-5	1.0E-5
	6.1E-6	4.3E-7
	1.1E-6	7.5E-8
	1.3E-5	4.1E-6
TOTAL	5.0E-5	2.5E-5



# REACTOR TRIP RELIABILITY RESULTS (CONT'D)

## ● OPTIONS CONTRIBUTIONS

OPTIONS (WITH OPERATOR ACTION)

	1	2	3	4	5	6
— COMMON CAUSE FAILURES (CCFs)						
ANALOG INSTRUMENTATION CHANNELS	1.0E-5	1.0E-5	1.0E-5	1.0E-5	1.0E-5	1.0E-5
UNIVERSAL LOGIC CARDS	7.3E-7	7.3E-7	7.3E-7	~0	7.3E-7	7.3E-7
REACTOR TRIP BREAKERS	1.0E-5	1.0E-5	0	1.0E-5	1.1E-5	0
UNDERVOLTAGE DRIVER CARDS	8.6E-8	0	4.3E-7	~0	4.3E-7	4.3E-7
INPUT RELAYS	7.5E-8	7.5E-8	7.5E-8	7.5E-8	7.5E-8	7.5E-8
— ALL OTHER FAILURES	<u>4.1E-6</u>	<u>4.0E-6</u>	<u>4.5E-6</u>	<u>3.0E-6</u>	<u>8.5E-6</u>	<u>3.8E-6</u>
TOTAL	2.5E-5	2.4E-5	1.5E-5	2.3E-5	2.9E-5	1.5E-5

△ FROM BASE CASE

(2.5E-5)

—5.4E-7 —1.0E-6 —1.1E-5 —2.0E-6 +4.0E-6 —1.0E-5

# CORE DAMAGE FREQUENCY RESULTS

## CORE DAMAGE FREQUENCIES<sup>a</sup> (EVENTS/REACTOR YEAR)

	<u>BASE CASE</u>	<u>OPTION 1</u>	<u>OPTION 2</u>	<u>OPTION 3</u>	<u>OPTION 4</u>	<u>OPTION 5</u>	<u>OPTION 6</u>
WITHOUT OPERATOR ACTION TO MANUALLY SCRAM	9.9E-6	8.3E-6	7.9E-6	7.5E-6	4.8E-6	1.1E-5	8.1E-6
CHANGE IN CORE DAMAGE FREQUENCY	—	1.6E-6	2.0E-6	2.4E-6	5.1E-6	-1.1E-6	1.8E-6
WITH OPERATOR ACTION TO MANUALLY SCRAM	5.0E-6	4.9E-6	4.8E-6	2.9E-6	4.6E-6	5.9E-6	2.9E-6
CHANGE IN CORE DAMAGE FREQUENCY	—	1.0E-7	2.0E-7	2.1E-6	4.0E-7	-9.0E-7	2.1E-6

<sup>a</sup>FOR COMPARISON, THE ATWS GOAL ESTABLISHED BY THE NRC IS 1.0E-5 EVENTS/REACTOR YEAR (REF. 12 NUREG-1341)

# **COST/BENEFIT EVALUATION METHODOLOGY**

## **SPECIFIC ANALYSES:**

- REACTOR TRIP RELIABILITY ANALYSIS
- ATWS EVENT SEQUENCE (CORE DAMAGE) ANALYSIS
- GENERIC CONSEQUENCE ANALYSIS
- PROPOSED OPTIONS COST ANALYSIS
- PROPOSED OPTIONS COST/BENEFIT RESULTS

## **APPROACH:**

- VARY REACTOR TRIP RELIABILITY AND COST FOR EACH OPTION AND HOLD REST OF PARAMETERS CONSTANT
- EVALUATE OPTION DELTAS FROM THE BASE CASE



## COST RESULTS

### COST PER PLANT (\$K)

<u>OPTION</u>	<u>LOW</u>	<u>BEST</u>	<u>HIGH</u>
1	33	50	166
2	43	81	298
3	72	132	379
4	795	1,084	2,296
5	109	201	475
6	130	243	531

# COST-BENEFIT INCLUDING AVERTED ONSITE COSTS (\$/PERSON-REM REDUCTION)<sup>a</sup>

	PERSON-REM REDUCTION WITHOUT OPERATOR			PERSON-REM REDUCTION WITH OPERATOR		
	COST \$K <sup>b</sup> (30 PLANTS)	SCRAM (30 PLANTS)	COST-BENEFIT (\$/PERSON-REM)	COST \$K <sup>b</sup> (30 PLANTS)	SCRAM (30 PLANTS)	COST-BENEFIT (\$/PERSON-REM)
OPTION 1	1,020	3,189	320	1,470	193	7,616
OPTION 2	1,830	3,944	464	2,394	242	9,893
OPTION 3	3,240	4,700	689	3,360	4,036	833
OPTION 4	31,000	10,000	3,100	32,398	673	48,140
OPTION 5	5,751	-1,869	- <sup>c</sup>	5,757	-1,803	- <sup>c</sup>
OPTION 6	6,750	6,504	1,038	6,690	4,112	1,626

<sup>a</sup> THE RESULT OF SUBTRACTING THE AVERTED ONSITE COSTS CHANGES THE COST-BENEFIT RESULTS. IT DOES NOT CHANGE THEIR POSITION RELATIVE TO THE \$1,000/PERSON-REM NOMINAL COST - BENEFIT SCREENING VALUE

<sup>b</sup> USING COST FROM TABLES 4 AND 5 OF NUREG 1341

<sup>c</sup> NO BENEFIT

# UNCERTAINTY ANALYSIS

## RISK UNCERTAINTY —

### — MODELING UNCERTAINTY

- REACTOR TRIP RELIABILITY MODEL
- ATWS EVENT SEQUENCE MODEL
- CONSEQUENCE ANALYSIS

### — DATA UNCERTAINTY (QUANTITATIVELY EVALUATED)

- ALL DATA USED IN QUANTIFICATION

## RISK UNCERTAINTY —

$$\begin{array}{rcl} \text{BASE CASE RISK} & - & \text{OPTION RISK} \\ \text{UNCERTAINTY} & & \text{UNCERTAINTY} \end{array} = \Delta \text{ RISK UNCERTAINTY}$$

## COST UNCERTAINTY —

### — ALL COST DATA (QUANTITATIVELY EVALUATED)

## COST/BENEFIT UNCERTAINTY —

$$\frac{\text{COST UNCERTAINTY}}{\Delta \text{ RISK UNCERTAINTY}}$$



# DATA UNCERTAINTY CALCULATION

$$\text{A. UNC} \left[ \begin{array}{c} \text{REACTOR TRIP} \\ \text{UNRELIABILITY} \\ \text{(PER DEMAND)} \end{array} \right] \times \left[ \begin{array}{c} \text{INITIATING} \\ \text{EVENT SEQUENCES} \\ \text{(DEMANDS PER} \\ \text{REACTOR YEAR)} \end{array} \right] = \text{UNC} \left[ \begin{array}{c} \text{CORE DAMAGE FREQUENCY} \\ \text{(EVENTS PER REACTOR YEAR)} \end{array} \right]$$

$$\text{B. UNC} \left[ \begin{array}{c} \text{CORE DAMAGE FREQUENCY} \\ \text{(EVENTS PER FACTOR} \\ \text{YEAR)} \end{array} \right] \times \left[ \begin{array}{c} \text{CONSEQUENCES} \\ \text{(PERSON-REMS PER} \\ \text{EVENT)} \end{array} \right] \times \left[ \begin{array}{c} \text{REACTOR YEARS} \\ \text{(ALL PLANTS)} \end{array} \right] = \text{UNC} \left[ \begin{array}{c} \text{RISK} \end{array} \right]$$

$$\text{C. UNC} \left[ \text{BASE CASE RISK} - \text{OPTION RISK} \right] = \left[ \Delta \text{RISK} \right]$$

# BASE CASE RISK UNCERTAINTY RESULTS

- RISK CALCULATED FOR REMAINING LIFE OF ALL 30 PLANTS
- MONTE CARLO UNCERTAINTY WITH 3000 TRIALS

## UNCERTAINTY DISTRIBUTION RESULTS (PERSON-REMS)

	<u>MEAN</u>	<u>5TH</u>	<u>50TH</u>	<u>95TH</u>
WITH OPERATOR ACTION	16,831	600	5,700	59,100
WITHOUT OPERATOR ACTION	28,561	1.100	10,900	108,600

# COST-BENEFIT UNCERTAINTY RESULTS

COST/BENEFIT (\$/PERSON-REM REDUCTION)

## DISTRIBUTION PARAMETERS

OPTION	MEAN	5TH	50TH	95TH	% PROBABILITY FROM \$0 TO \$1,000	% PROBABILITY MORE THAN \$1,000
--------	------	-----	------	------	--------------------------------------	------------------------------------

### WITHOUT OPERATOR ACTION

1	6,750	201	2,280	26,200	26	74
2	10,020	278	3,320	38,300	20	80
3	22,100	600	6,010	85,600	8	92
4	42,200	1,300	14,300	167,000	4	96
5	NO POSITIVE BENEFIT					
6	131,000	7,100	70,900	505,000	0	100

### WITH OPERATOR ACTION

1	146,000	4,430	44,000	579,000	0	100
2	159,000	4,600	50,600	649,000	0	100
3	78,000	3,400	33,900	301,000	1	99
4	526,000	17,300	171,000	2,030,000	0	100
5	NO POSITIVE BENEFIT					
6	127,000	4,100	41,400	467,000	0	100



# POINT ESTIMATE/UNCERTAINTY RESULTS COMPARISON

OPTION	COST/BENEFIT (\$/PERSON-REM REDUCTION)	
	POINT ESTIMATE MEAN	DISTRIBUTION MEAN
WITHOUT OPERATOR ACTION		
1	320	6,750
2	464	10,200
3	689	22,100
4	3,100	42,200
5	NO BENEFIT	NO BENEFIT
6	1,038	131,000
WITH OPERATOR ACTION		
1	7,616	146,000
2	9,333	159,000
3	883	78,200
4	48,140	526,000
5	NO BENEFIT	NO BENEFIT
6	1,626	127,000

## **CONCLUSION**

- **NO BACKFIT REQUIREMENTS  
ARE WARRANTED**


## **FURTHER WORK**

- **NRR CONSIDERING DECREASING THE RTB TEST FREQUENCY IN CONJUNCTION WITH ADDITION OF M/G SET BREAKER TRIP FUNCTION (DESIGN ADOPTED IN A EUROPEAN PLANT)**
- **IMPLEMENTATION OF OPTION 1 REQUISITE FOR ADDITION OF M/G SET BREAKER TRIP**
- **NRR CONSIDERING ABOVE OPTIONS FOR ALWR**





BACKUP VIEWGRAPHS

# OPTION 1-UV DRIVER CARD MODIFICATION RECOMMENDED BY WESTINGHOUSE




# OPTION 2-DIVERSE UV DRIVER







# OPTION 3-DIVERSE RTB ACTUATION MECHANISM



# OPTION 4-DIVERSE SSPTS LOGIC AND UV TRIP FUNCTION



# OPTION 5-DUAL SHUNT TRIP ACTUATION FOR EACH RTB





# OPTION 6-REPLACEMENT OF ONE RTB WITH A CONTACTOR

