



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 7, 1989

Docket

Docket No. 50-382

Mr. J. G. Dewease
Senior Vice President - Nuclear Operations
Louisiana Power and Light Company
P. O. Box 60340
New Orleans, Louisiana 70160

Dear Mr. Dewease:

SUBJECT: GENERIC LETTER 83-28, ITEM 1.1 POST TRIP REVIEW

By letter dated June 2, 1989, the Louisiana Power and Light Company (LP&L) provided a response to the above Generic Letter item for Waterford 3 by establishing a Post Trip Review Task Group to review unscheduled reactor trips. We have reviewed this response and the LP&L response in a letter dated October 15, 1985 and we find them acceptable to resolve the deficiencies noted in our Safety Evaluation transmitted to LP&L by letter dated October 3, 1985.

The LP&L procedure extends the independent assessment to any unscheduled reactor trip and goes beyond our criteria for the group to examine only those for which a cause cannot readily be determined. In the event a change to procedure may be contemplated, our criteria remains acceptable. Changes to the Task Group may also be made by providing for similar authority and experience.

On the basis of the above, we find the LP&L response to Generic Letter 83-28, Item 1.1 to be acceptable. This closes the action under TAC 57698. We have also recorded your implementation date as July 17, 1989 as noted in the June 2, 1989 LP&L letter.

Sincerely,

Frederick J. Hebdon

Frederick J. Hebdon, Director
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

cc: See next page

JFol
1/0

June 7, 1989

Docket No. 50-382

Mr. J. G. Dewease
Senior Vice President - Nuclear Operations
Louisiana Power and Light Company
P. O. Box 60340
New Orleans, Louisiana 70160

Dear Mr. Dewease:

SUBJECT: GENERIC LETTER 83-28, ITEM 1.1 POST TRIP REVIEW

By letter dated June 2, 1989, the Louisiana Power and Light Company (LP&L) provided a response to the above Generic Letter item for Waterford 3 by establishing a Post Trip Review Task Group to review unscheduled reactor trips. We have reviewed this response and the LP&L response in a letter dated October 15, 1985 and we find them acceptable to resolve the deficiencies noted in our Safety Evaluation transmitted to LP&L by letter dated October 3, 1985.

The LP&L procedure extends the independent assessment to any unscheduled reactor trip and goes beyond our criteria for the group to examine only those for which a cause cannot readily be determined. In the event a change to procedure may be contemplated, our criteria remains acceptable. Changes to the Task Group may also be made by providing for similar authority and experience.

On the basis of the above, we find the LP&L response to Generic Letter 83-28, Item 1.1 to be acceptable. This closes the action under TAC 57698. We have also recorded your implementation date as July 17, 1989 as noted in the June 2, 1989 LP&L letter.

Sincerely, Original Signed By
Frederick J. Hebdon
Frederick J. Hebdon, Director
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File
G. Holahan
D. Wigginton
ACRS (10)

NRC PDR
L. Rubenstein
OGC-Rockville
PD4 Plant File

Local PDR
F. Hebdon
E. Jordan

PD4 Reading
P. Noonan
B. Grimes

PD4/LA *PH*
PNoonan
06/6/89

PD4/PM *W*
DWigginton:sr
06/6/89

PD4/D *W*
FHebdon
06/7/89

Mr. Jerrold G. Dewease
Louisiana Power & Light Company

Waterford 3

cc:

W. Malcolm Stevenson, Esq.
Monroe & Leman
201 St. Charles Avenue, Suite 3300
New Orleans, Louisiana 70170-3300

Mr. E. Blake
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW
Washington, D.C. 20037

Resident Inspector/Waterford NPS
Post Office Box 822
Killona, Louisiana 70066

Mr. Ralph T. Lally
Manager of Quality Assurance
Middle South Services, Inc.
Post Office Box 61000
New Orleans, Louisiana 70161

Chairman
Louisiana Public Service Commission
One American Place, Suite 1630
Baton Rouge, Louisiana 70825-1697

Mr. R. F. Burski
Nuclear Safety and Regulatory Affairs Manager
Louisiana Power & Light Company
317 Baronne Street
New Orleans, Louisiana 70112

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director for
Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. William H. Spell, Administrator
Nuclear Energy Division
Office of Environmental Affairs
Post Office Box 14690
Baton Rouge, Louisiana 70898

President, Police Jury
St. Charles Parish
Hahnville, Louisiana 70057

William A. Cross
Bethesda Licensing Office
3 Metro Center
Suite 510
Bethesda, Maryland 20814